

I'll now the maximum generation is :-		13792.0		20:00 Hrs on 27-Apr-21		Date : 28-Jan-22	
The Summary of Yesterday's		28-Jan-22		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	7718.0 MW	Hour :	12:00	Min. Gen. at	4:00	5727 MW	
Evening Peak Generation :	8683.0 MW	Hour :	19:00	Available Max Generation		12341 MW	
E.P. Demand (at gen end) :	8683.0 MW	Hour :	19:00	Max Demand (Evening) :		9800 MW	
Maximum Generation :	8683.0 MW	Hour :	19:00	Reserve(Generation end)		2541 MW	
Total Gen. (MKWH) :	177.3	System Load Factor	85.09%	Load Shed		0 MW	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR							
Export from East grid to West grid :- Maximum		-322 MW		at	18:30	Energy	MKWHR.
Import from West grid to East grid :- Maximum		-		at	-	Energy	- MKWHR.
Level of Kaptai Lake at 6:00 A.M on		29-Jan-22					
Actual :	94.19	Rule curve :	97.60	Ft.(MSL)			
Gas Consumed : Total =		724.56 MMCFD.		Oil Consumed (PDB) :			
				HSD :		Liter	
				FO :		Liter	
Cost of the Consumed Fuel (PDB+)		Gas : Tk90,110,020					
		Coal : Tk64,122,670					
				Oil : Tk340,742,849		Total : Tk494,975,539	
Load Shedding & Other Information							
Area		Yesterday		Today			
		Estimated Demand (S/S end)		Estimated Shedding (S/S end)		Rates of Shedding	
MW		MW		MW		(On Estimated Demand)	
Dhaka	0	0:00	3538	0	0%		
Chittagong Area	0	0:00	1200	0	0%		
Khulna Area	0	0:00	1075	0	0%		
Rajshahi Area	0	0:00	971	0	0%		
Cumilla Area	0	0:00	877	0	0%		
Mymensingh Area	0	0:00	708	0	0%		
Sylhet Area	0	0:00	400	0	0%		
Barisal Area	0	0:00	182	0	0%		
Rangpur Area	0	0:00	546	0	0%		
Total	0		9497	0			
Information of the Generating Units under shut down.							
Planned Shut- Down				Forced Shut-Down			
				1) Barapukuria ST: Unit-1,2 2) Ghorasal-3,5,7 3) Ashuganj-4, 4) Baghabari-71 MW & 100 MW 5) Shajibazar 330 MW GT-2 6) Raozan unit- 1,2 7) Sirajganj Unit 1 & 2 8) Summit Bibiyana-3 9) Haripur 412 MW EGCB			
				10) Meghnaghat Summit 305 MW CAPP			
Additional Information of Machines, lines, Interruption / Forced Load shed etc.							
a) Ashuganj-Sirajganj 230 kV Ckt-2 was under shut down from 09:06 to 14:37 for D/W. b) Ashuganj-Kishoreganj 132 kV Ckt-2 tripped at 08:45 from both ends showing Dist. A,B-phase at Ashuganj end & Dist. A-phase at Kishoreganj end and was switched on at 08:56. c) Hathazari 132 kV Bus-1 was under shutdown from 08:41 to 10:18 for D/W. d) Hathazari 230/132 kV MT-02 transformer was under shut down from 08:41 to 10:15 for D/W. e) Khagrachori 132/33 kV T-2 transformer was under shut down from 09:03 to 17:50 for protection test. f) Sonargaon 132/33 kV T-1 transformer was under shut down from 09:30 to 11:43 for A/M. g) Matuail 132/33 kV T-2 transformer was under shut down from 10:12 to 16:37 for A/M. h) Rangpur-Lalmonirhat 132 kV Ckt was under shut down from 08:19 to 16:56 for C/M.				About 35 MW power interruption occurred under Lalmonirhat S/S area from 08:19 to 16:56. About 30 MW power interruption occurred under Pabna S/S area from 08:32 to 14:41.			
i) Pabna 132 kV Bus was under shutdown from 08:32 to 14:41 for A/M. j) Satmosjid 132/33 kV T-1 transformer was under shut down from 11:32 to 13:19 for A/M. k) Sonargaon 132/33 kV T-2 transformer was under shut down from 11:49 to 14:08 for A/M. l) Hathazari-Baroiarhat 132 kV Ckt-2 is under shut down since 08:36 for C/M at Hathazari end. m) Satmosjid 132/33 kV T-2 transformer was under shut down from 14:11 to 14:56 for C/M. n) Bheramara HVDC Auxiliary T-2 transformer was under shut down from 15:38 to 18:20 for C/M. o) Patuakhali-Payra 132 kV Ckt-2 was under shut down from 19:01 to 21:47 due to R/H maintenance at Payra CB(Y-phase). p) Kahirpur-Kodda 132 kV Ckt-1 tripped at 03:48(29/01/2022) from Kahirpur end showing Dist. B,C-phase and was switched on at 04:09(29/01/2022). q) Dohazari-Cox's Bazar 132 kV Ckt-1 is under shut down since 06:14(29/01/2022) for D/W. r) Bhulta 400/132 kV T-02 transformer is under shutdown since 07:32(29/01/2022) for C/M.				About 74MW power interruption has been running under Cox'sBazar &Matarbari S/S area since 06:14(29/01/22).			
<div style="display: flex; justify-content: space-between;"> <div>Sub Divisional Engineer Network Operation Division</div> <div>Executive Engineer Network Operation Division</div> <div>Superintendent Engineer Load Despatch Circle</div> </div>							