

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel - 9564667, 9551095

Month February, 2022		Day : Friday				Date : 04.02.22						
Probable Maximum Demand :		8500 MW		Probable Maximum Generation : 12447 MW				Rule Curve = 96.58 ft				
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 93.45 ft		Today = 93.33 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.02.22 (Yesterday)		04.02.22 (Today)		03.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :			
				Day		Evening		Gas/Water/Coal limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	220	222	220	220			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Harijpur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Harijpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	260	267	300	300	93	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	220	225	225	225	225	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Harijpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage	
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	40			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	60	60	60	60			
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102			
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	34	34	35	35			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	20	20			
20	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105			
23	Kodda 150MW PP	HFO (BPD- RPCL)	9x17.06	149	149	140	133	150	150			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	48	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	285	300	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	135	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	27	200	300			
28	Branhangan 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
29	Aurath 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	60	100	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	17	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	90	144	160	160			
34	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	26	0	30	0			
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	55	55	55	55			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	42	47	51	51			
Dhaka Zone Total				5853	5696	2141	2463	2776	2846	2175	598	
37	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184	Low water level & maint.	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Racoon 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	17	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.69	50	50	39	38	40	40			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	76	105	105	105			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HQPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	281	268	260	300			
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	10	100	100			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	76	90	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51			
50	Hafazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment issue	
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	19	20			
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	10	10	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	90	95	97	97			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	54	54			
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	57	110	110			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	40	70	100	100			
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	116	116	116	116			
Chattogram Zone Total				2442	2382	861	994	1240	1266	544	473	
57	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5	40	Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	196	155	220	220			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	295	300	360	360	60	Gas Shortage	
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	210	220	235	260	140	Gas Shortage	
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	5	5	5	5	50	Gas Shortage	
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20x9.73+1x16	195	195	16	16	16	16	179	Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	142	140	150	150			
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	50	50	50	50			
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	137	129	135	135	34	Gas Shortage	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	154	142	200	200			
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	21	21			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	25	25	25			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	52	52	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9			
74	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	96x1.4+6x1.915+15x1.096	200	200	0	0	100	200			
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	114	70	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12x9.78+2x3.1	113	113	8	108	113	113			
77	Bhiarob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
	Chandpur 115(Doreen)	HFO (IPP)				42	0	0	0			On Test
**	Import (Tripura)	India		160	160	96	104	138	134			
Cumilla Zone Total				2944	2899	1617	1627	2027	2148	766	0	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	84	66	110	110	136	Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. 8MW
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	109	109	110	110			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	192	200	200	200			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Suitakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	16	0	50	0			
85	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	22	22	22	22			
Mymensingh Zone Total				717	622	447	419	516	464	136	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.02.22 (Yesterday)		04.02.22 (Today)		03.02.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	30	30		40	GT 1 Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	30	30	30	30			GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	51	53	51	51			Gas Shortage	
89	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage	
90	Hobganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	46	67	70	70				
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	137	137	135	135	193		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	76	78	75	80				
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	177	177	180	180	54		Gas Shortage	
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	290	330	330				
99	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
100	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total					2422	2377	1371	1409	1466	1471	329	40	
102	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	0	0	0	0	410		Gas Shortage	
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	34	0	35				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220				
107	Neopara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.516	100	100	0	70	80	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	91	92	105	105				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	47	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	736	737	751	751				
Khulna Zone Total					2233	2229	878	933	1036	1351	410	0	
111	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	20	20	24				
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	91	91	90	92				
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	86	25	76	76				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	420	400	620	620	844		Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
117	Bhola 220MW CAPP (Nutan Bidyut BC Gas/HSD)	Gas/HSD (IPP)	2x75+1x70	220	220	13	220	220	220				
Barishal Zone Total					2046	2046	626	756	1136	1292	0	844	
118	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	34	34	34	34				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	27	46	50	50				
122	Chapaiwawaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	100	90	100				
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	40	0	40				
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	30	31				
126	Siraggonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127	Siraggonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
128	Siraggonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	129	119	140	140	101		Gas Shortage	
129	Siraggonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	241	217	325	325	197		Gas Shortage	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	18	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	113	113				
135	Siraggonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
Rajshahi Zone Total					2129	2129	806	870	1236	1281	899	0	
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal shortage	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15			Condenser mode	
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	113	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
141	Majpara, Talula 8 MW Solar PP (Sympa Power Energyrac Power Venture Thakurgonj Ltd)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
Rangpur Zone Total					685	605	339	313	321	328	159	85	
Sub-total: Plants in operation					21471	20985	9086.0	9784	11754	12447	5418	2040	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							8973	9662	11607	12292			
(B) Plants under long term maintenance/contract expired													
142	Bosila 106MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
143	108Rirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
147	Khulna 115 MW PP (KPLC-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Annura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired					595	50	0	0	0	0	0	0	
Gross Total					22066	21035	9086	9784	11754	12447	5418	2040	
(C) Actual data of 03.02.22 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	: 9784.00	MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 9662.00	MW, at = 19:00 hrs		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	: 9784.00	MW, at = 19:00 hrs		MW	MW	MW		MW	MW	MW		
04.	Minimum Generation (Generation end)	: 6186.00	MW, at = 5:00 hrs		Dhaka	3605	3605	0	Mymensingh	777	777	0	
05.	Day-peak Generation (Generation end)	: 9086.00	MW, at = 12:00 hrs		Chattoagram	1059	1059	0	Sylhet	338	338	0	
06.	Evening-peak Generation (Generation end)	: 9784.00	MW, at = 19:00 hrs		Khulna	1139	1139	0	Barishal	245	245	0	
07.	Evening Peak Load-shed (Sub-station end)	: 0.00	MW, at = 19:00 hrs		Rajshahi	999	999	0	Rangpur	720	720	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	: 5908.00	MW, at = 5:00 hrs		Cumilla	780	780	0					
09.	Generation shortfall at evening peak due to:								Total	9662	9662	0	
a)	Gas Limitation	: 5075	MW		13.	Fuel cost:	(a) Gas = 97679000	Taka	(c) Coal = 71733766	Taka			
d)	Coal supply Limitation	: 159	MW				(b) Oil = 483121960	Taka	Total = 652534725	Taka			
b)	Low water level in Kaptai lake	: 184	MW										
c)	Plants under shut down/ maintenance	: 2040	MW		14.	Maximum Temperature in Dhaka was :	26.6° C						
10.	Total Energy (Generation + India Import)	: 198.87	MKWh		15.	Export through East-West interconnections :							
	By Gas = 94.679	MKWh	By Oil = 67.145	MKWh		At evening peak-hour :	-374	MW, at 19:00 hrs					
	By Coal = 15.201	MKWh	By Hydro = 1.083	MKWh		Maximum :	-439	MW, at 18:30 hrs					
	By Solar= 0.957	MKWh				Energy :	0.921	MKWh					
11.	Total Gas Supplied	: 790.25	MMCFD										
(D) Forecast of 04.02.22 (Today) Friday :													
01.	Maximum Demand	: 8500	MW (Generation end)	04.	Maximum Load-shed	: 0	MW	At evening peak (Sub-station end)					
02.	Maximum Generation	: 12447	MW (Generation end)	05.	Total Generation	: 172.77	MKWh						
03.	Maximum Shortage	: -3947	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	24.1° C							

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation