

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month April, 2022			Day : Thursday				Date : 14.04.22					
Probable Maximum Demand :			14000 MW				Probable Maximum Generation : 15487 MW					
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 81.37 ft				Today = 81.13 ft				Rule Curve = 85.40 ft	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.04.22 (Yesterday)		14.04.22 (Today)		13.04.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	233	232	230	230			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	270	270	270	270			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	100	104	100	100			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Harijpur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	92	312	320	320			
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Harijpur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	398	396	400	400			
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	65	0	0	110		
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	320	330	330			
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	140	140	140	140	195	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	82	92	93	93			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	19	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.9+1x4.73	80	80	53	53	55	55			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	49	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	105	100	100			
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	98	150	150	150			
23	Kamaalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	35	54	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	278	278	300	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
26	Karangonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	204	300	300			
27	Bramanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
29	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	17	55	55	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	92	104	104	104			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	162	162			
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	29	0	30	0			
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55			
35	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
36	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	96	100	100			
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	89	94	100	100			
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	78	64	80	80			
Dhaka Zone Total				6055	5898	2903	4204	4350	4320	210	785	
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	67	69	70	70	161	Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
43	Telraaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	37	38	40	40			
45	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	51	105	105	105			
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
47	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	213	203	215	215			
48	Anwara 300 MW PP (Uniled)	HFO (IPP)	17x17.076+3x8.94	300	300	300	300	300	300			
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	76	90	90	90			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	84	51	85			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	40	0	35			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
*	Malancha, Ctg.EPZ (Uniled)	Gas	5x8.73+3x9.34			2	28	20	30			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	79	82	80	86			
54	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
57	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	110	113	113	113			
Chattogram Zone Total				2342	2282	1249	1441	1398	1458	341	330	
58	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26			
60	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+175	221	221	175	215	210	210			
61	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	0	0	320	320	360	Under maint.	
62	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	310	280	320	320			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	48	30	55	55			
64	Ashuganj 198MW PP (APSCL-Uniled)	Gas (IPP)	20'9.73+11'6	195	195	8	8	8	8	187	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	138	150	130	150			
67	Titus 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	27	49	40	40			
68	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	21	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	24	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	40	38	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.40x1.015+15x1.058	200	200	0	100	100	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	64	62	80	80			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	71	115	113	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	36	36			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	96	101	90	100			
**	Impport (Tripura)	India		160	160	156	166	143	166			
Cumilla Zone Total				3059	3014	1516	1712	2051	2204	450	523	
80	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	103	133	100	120	69	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20			
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			
83	Jamalpur 115 MW PP (Uniled)	HFO (IPP)	12x9.87	115	115	106	105	106	115			
84	Mymensingh 200 MW PP (Uniled)	HFO (IPP)	21x9.780	200	200	189	170	190	190			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	32	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	10	22	22			
Mymensingh Zone Total				717	622	451	438	490	467	69	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.04.22 (Yesterday)		14.04.22 (Today)		13.04.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	0	0	0	0	70	GT1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	41	40	40	40	50	GT4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	10	10	10	10			
91	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109-1x54	163	163	163	163	163	163			
92	Hobgonj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	60			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	262	158	160	160	172	Gas Shortage	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	84	86	86			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142-1x89	231	231	219	140	140	140			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20	Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	23	23	23			
100	Bibiyana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	275	270	310	320			
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	371	371	370	370			
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	385	394	400	400			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	26	27	27	27	23	Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	3	3	3	3	41	Gas Shortage	
Sylhet Zone Total					2522	2477	1938	1764	1823	256	220	
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	365	255	400	400	155	Gas Shortage	
108	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	0	40			
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	40	0	30			
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	200	200	200			
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	10	100	100			
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	94	105			
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	89	67	105			
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	100	0	100	0			
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	96	115	115			
116	Noapara 40 MW PP (Kharjahan Ali)	HFO (NENP)	5*8.5	40	40	8	40	40	40			
**	Bheramara (HVDC)	India		1000	1000	922	922	941	941			
Khulna Zone Total					2388	2384	1667	1795	2057	155	0	
117	Barsail 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	48	110			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	37	33	33			
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	84	88	90	90			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	480	622	622	660	622	Line Overload	
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	90	17	100		Line Overload	
122	Bhola 220MW CAPP (Nutan Bidyt Bl)	Gas/HSD (IPP)	2x75-1x70	220	220	213	220	220	220			
Barishal Zone Total					1958	1958	832	1105	1030	1213	0	622
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	71		Gas Shortage	
123	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	34	43			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	50	150	170			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	29	30	40	40			
127	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	93	90	92			
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40			
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	40	43			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	30	36			
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	130	213	220	220		Running on HSD	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	169	136	180	180	84	Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	415	414	414			
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22			
136	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
137	Natore 52 MW PP (Rajarjika)	HFO (IPP)	6x8.92	52	52	43	52	43	52			
138	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113			
139	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0			
Rajshahi Zone Total					2129	2129	1045	1392	1506	1589	465	0
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	77	80	82			
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0	274	Under maint.	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	17	0	17			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	110	113	113			
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	8	0	10			
146	Majpara, Tatala 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	4	0	8	0			
147	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	115	115	115	115			
Rangpur Zone Total					800	720	231	327	316	337	0	359
Sub-total: Plants in operation					21970	21484	11832.0	14178	15010	15487	1946	2839
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							11414	13677	14479	14940		
(B) Plants under long term maintenance/ contract expired												
148	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage
149	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired
150	Jaldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired
151	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
152	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired					378	0	0	0	0	0	0	0
Gross Total					22348	21484	11832	14178	15010	15487	1946	2839
(C) Actual data of 13.04.22 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	: 14178 MW, at = 21:00 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 13677 MW, at = 21:00 hrs										
03.	Highest Generation (Generation end)	: 14178 MW, at = 21:00 hrs										
04.	Minimum Generation (Generation end)	: 10229 MW, at = 8:00 hrs	Dhaka	4848	4848	0				Mymensingh	1071	1071
05.	Day-peak Generation (Generation end)	: 11832 MW, at = 12:00 hrs	Chattogram	1310	1310	0				Sylhet	558	558
06.	Evening-peak Generation (Generation end)	: 14178 MW, at = 21:00 hrs	Khulna	1797	1797	0				Barishal	417	417
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 21:00 hrs	Rajshahi	1610	1610	0				Rangpur	706	706
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10230 MW, at = 5:00 hrs	Cumilla	1360	1360	0						
09.	Generation shortfall at evening peak due to :									Total	13677	13677
a)	Gas limitation	: 1785 MW								(c) Coal =	72911874	Taka
d)	Coal supply Limitation	: 0 MW								(b) Oil =	1095960998	Taka
b)	Low water level in Kaptai lake	: 161 MW										
c)	Plants under shut down/ maintenance	: 2839 MW										
10.	Total Energy (Generation + India Import)	: 299.05 MKWh										
	By Gas = 145.703 MKWh	By Oil = 108.668 MKWh										
	By Coal = 15.934 MKWh	By Hydro = 1.577 MKWh										
	By Solar = 1.241 MKWh											
11.	Total Gas Supplied	: 1077.57 MmCFD										
(D) Forecast of 14.04.22 (Today) Thursday :												
01.	Maximum Demand	: 14000 MW (Generation end)								04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)
02.	Maximum Generation	: 15487 MW (Generation end)								05.	Total Generation	: 295.30 MKWh
03.	Reserve / Shortage	: 1487 MW (Generation end)								06.	Probable Max. Temperature in Dhaka	: 36.4° C

* Captive Power ** Imported Power

#Remarks: Highest Generation 14423 MW on 12-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation