

Reporting Date : 26-Apr-22

Water Level of Kaptai Lake at 6:00 A M on		26-Apr-22			
Actual :	77.32	Ft.(MSL) ,	Rule curve :	83.00	Ft.(MSL)

Coal	181,003,481,109	Oil	181,003,481,109	Total	181,003,481,109
Load Shedding & Other Information					

Load Shedding & Other Information

Area	Yesterday		Today	
	MW	Estimated Demand (S/S end)	MW	Rates of Shedding (On Estimated Demand)
Dhaka	0	0:00	5436	0%
Chittagong Area	0	0:00	1773	0%
Khulna Area	0	0:00	1717	0%
Rajshahi Area	0	0:00	1539	0%
Cumilla Area	0	0:00	1402	0%
Mymensingh Area	0	0:00	1149	0%
Sylhet Area	0	0:00	565	0%
Barisal Area	0	0:00	342	0%
Rangpur Area	0	0:00	848	0%
Total	0		14772	0

Information of the Generating Units under shut down.

Planned Shut- Down	Forced Shut- Down	
	1) Barapukuria ST: Unit-2 2) Ghorasal-3,5 3) Ashuganj-4,5 4) Baghabari-71,100 MW 5) Raozan unit- 1,2 6) Siddhirganj 210 MW 7) Sakalaha-150 MW 8) Ashuganj South	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

- a) GPH 230/132 kV T-1 transformer was under shut down from 11:14 to 11:56 for C/M.
- b) Ullon-Dhanmodi 132 kV Ckt-3 was under shut down from 08:33 to 08:47 for protection test.
- c) Polashbari 132/33 kV T-2 transformer was under shut down from 09:15 to 10:03 due to red hot maintenance at 33 kV bushing.
- d) Sirajganj 132/33 kV T-4 transformer was under shut down from 08:51 to 09:54 due to red hot maintenance at 33 kV bushing.
- e) Fayal-Gopalganj 132 kV Ckt-1 & 2 were under shut down from 08:05 to 15:56 for D/W.
- f) Gopalganj 400/132 kV T1 transformer was under shut down from 10:15 to 11:32 due to oil leakage maintenance at radiator pipe.
- g) Jhenaidah (O)-Jhenaidah(N) 132 kV Ckt-3 was shut down at 10:32 for C/M.
- h) Hathazari-Kaptai 132 kV Ckt-2 was under shut down from 12:30 to 12:43 for C/M.
- i) Sikabaha 132/33 kV T-4 transformer tripped at 12:35 from both end showing O/C, E/F relays and was switched on at 14:02.
- j) Payra-Gopalganj 400 kV Ckt-2 was switched on at 14:57.
- k) Bhandaria 132/33 kV T1 transformer was under shut down from 16:25 to 17:38 due to oil leakage maintenance at CT.
- l) Siddhirganj S/S-Siddhirganj Peaking 132 kV Ckt-1 & 2 tripped at 19:32 showing master trip relay and was switched on at 20:06.
- m) Siddhirganj S/S-Siddhirganj Dutch Bangla 132 kV Ckt-1 & 2 tripped at 19:32 showing O/C, E/F relay and was switched on at 06:37(26-04-2022).
- n) Jhenaidah (O)-Jhenaidah(N) 132 kV both Ckt was under shut down from 14:21 to 19:34 for C/M.
- o) Chandpur CCPP 150 MW GT synchronized at 17:16.
- p) Sirajganj unit-1 tripped at due to GBC problem and GT & ST were synchronized at 15:03, 16:45 respectively.
- q) Payra unit-2 was synchronized at 15:49.
- r) Sylhet-Chatak 132 kV Ckt-1 tripped at 01:52(26-04-2022) from Sylhet end showing Dist. Z1, C-phase relays and was switched on at 02:04(26-04-2022)
- s) Sreemangal 132/33 kV T2 transformer tripped at 02:54(26-04-2022) showing E/F, O/C relays and was switched on at 02:58(26-04-2022)
- t) Koddra 33 kV Bus of T2 transformer was under shut down at 06:16(26-04-2022) to 08:25 for C/M.
- u) Joydevpur 132 kV Bus, 1321/33 kV T2, T3 transformer were under shut down at 05:28(26-04-2022) to 06:50(26-04-2022) for C/M.
- v) Dharmai 33 kV Bus was under shut down from 07:08(26-04-2022) to 10:48 for C/M.
- w) Fairpur-Rajbari 132 kV Ckt-1 was under shut down from 07:16(26-04-2022) to 10:22 for C/M.
- x) Barapukuria 230/132 kV T01 transformer was under shut down from 05:43(26-04-2022) to 09:57 for C/M.
- y) Barapukuria 132 kV Bus-1 was under shut down from 05:51(26-04-2022) to 09:58 for C/M.
- z) Keraniganj 132/33 kV T-1 transformer was under shut down from 07:26(26-04-2022) to 09:59 for C/M.
- aa) Khulna 225 MW STG was synchronized at 07:17.

About 15 MW power interruption occurred under Sikalbaha S/S area from 12:35 to 14:02.

About 12 MW power interruption occurred under Kodda S/S area from 06:16(26-04-2022) to 08:25.
About 20 MW power interruption occurred under Joydevpur S/S area from 05:28(26-04-2022) to 06:50.

**Sub Divisional Engineer
Network Operation Division**

Executive Engineer
Network Operation Division

Superintendent Engineer
Load Despatch Circle