POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT QF-LDC-08 Page -1 
 Till now the maximum generation is: 14782.0

 The Summary of Yesterday's
 4-May-22
 Generation & Demand

 Day Peak Generation:
 6447.0 MW

 Evening Peak Generation:
 9810.0 MW

 Post Compand (at gen end):
 9810.0 MW

 Post Compand (at gen end):
 9810.0 MW
 Reporting Date : 5-May-22 21:00 Hour 12:00 Hour: Hour: Hour: 21:00 21:00 21:00 21:00 Total Gen. (MKWH) 176.6 System Load Factor EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 76.56% Load Shed 0 MW Export from East grid to West grid :- Maximum -736 MW 20:00 MKWHR Import from West grid to East grid : Maximum

Level of Kaptai Lake at 6:00 A M on MW Energy MKWHR 5-May-22 Ft.(MSL), Actual : 75.30 Rule curve 81.24 Ft.( MSL ) Gas Consumed : Total = 922.05 MMCFD. Oil Consumed (PDB): HSD FO Liter Liter Cost of the Consumed Fuel (PDB+P) Gas Coal Tk123.688.200 Tk98,293,630 Oil : Tk82,580,177 Total : Tk304,562,007 Load Shedding & Other Information Today
Estimated Shedding (S/S end)
MW Area Yesterday Estimated Demand (S/S end) Rates of Shedding Rates of Shedding (On Estimated Demand) 0% 0% 0% 0% 0% 0% 0% 0% MW 3968 1264 1259 MW Dhaka Chittagong Area Khulna Area 0:00 0:00 0:00 0:00 0:00 0:00 0:00 Rajshahi Area 1124 1028 847 410 Cumilla Area Mymensingh Area Sylhet Area 264 Barisal Area 0:00 Rangpur Area 0:00 615 0% Total 10778 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut-Down 1) Barapukuria ST: Unit-2 2) Ghorasal-3,4,5 3) Ashuganj-4,5 4) Baghabari-71,100 MW 5) Raozan unit-1,2 11) Bheramara 410 MW 6) Siddhirganj 210 MW 7) Sikalbaha-150 MW 8) Ashuganj South 9) Sirajganj Unit-1,2,3,4 Additional Information of Machines, lines, Interruption / Forced Load shed etc. a) Rohanpur 400 kV CB was open at 09:58 and was closed at 10:58.
b) Hathazari-Kaptai 132 kV Ckt-2 tripped at 08:18 from both ends showing Dist. Z1, R-phase and was switched on at 10:23.
c) Aurahati-Hasnabad 132 kV Ckt tripped at 06:00 from both ends showing Dist. Z1, L3 and was c) Auranati-Hasnabad 132 kV Ckt tripped at U6:00 from both ends showing Ust. 21, L3 and was switched on at 08:28.
d) Tongi S/S-Tongi 80 MW P.P. 230 kV Ckt was under shut down from 11:10 to 13:21 for C/M by P.P. e) GPH 230/33 kV transformer was under shut down from 11:38 to 12:13 for C/M by GPH. f) Jashore 13/23 kV T-I transformer was under shut down from 10:10 to 11:26 for C/M by PBS. g) Raozan Unit-1 was shutdown at 08:32 due to trouble and was synchronized at 16:34. h) Sylhet 132/33 kV T-1 transformer tripped at 16:25 due to cable burst at 33 kV side(Y-phase) and was About 29 MW power interruption occurred under In Joynet 132:30 Nt 1-14 transformer tripped at 16:20 due to table buss at 33 kV state(+phase) and was switched on at 18:28.

(1) Tangal 132/33 kV T-1, T-2 & T-3 transformers tripped at 16:30 due to 33 kV feeder problem and were switched on at 16:50.

(3) Bottal 132/33 kV T-1 transformer tripped at 18:32 and was switched on at 18:55. Sylhet S/S area from 16:25 to 18:28.
About 50 MW power interruption occu
Tangail S/S area from 16:30 to 16:50. ly Ghorashal Unit-4 was forced shutdown at 18:24 due to exhaust system problem.

1) Ashuganj 225 MW tripped at 07:39(05/05/2022) due to low gas pressure.

m) Sylhet 132/33 kV T-1 transformer is under shut down since 06:51(05/05/2022) for C/M.

**Executive Engineer** 

Network Operation Division

Superintendent Engineer

Load Despatch Circle

Sub Divisional Engineer

Network Operation Division