

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated		Remarks
						MW	KWH	
			Unit No. X Capacity	MW	MW			
1	Ghorasal Repowered CAPP-Unit-3 (GT)	PDB	1'260	260	0	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1'210	180	0	0	0	Under maint.
3	Ghorasal TPP Unit-1	PDB	1'210	180	0	0	4347000	
3	Ghorasal 365 MW CAPP Unit-7	PDB	1'243+1'122	365	300	5084936	0	Machine problem
4	Ghorasal 78.5 MW PP(MAX)	ORPP	2'40	0	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	82	2037590	0	Engine problem
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	0	Under maint.
6	Haripur 412 MW CAPP	EGCB	1'273+1'139	412	404	9865210	0	
7	Haripur 360 MW CAPP(HPL)	IPP	1'235+1'125	360	326	7658000	0	Gas shortage
8	Meghnaghat 450 MW CAPP(MPL)	IPP	2'150+1'150	450	225	5054950	0	Gas shortage & GT-2 S/D.
9	Meghnaghat 100 MW(EL)	NENP	1'28.9	100	72	483840	0	Fuel shortage
10	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	335	0	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	NENP	6'17	102	0	0	0	Under maint.
12	Madanganj 55 MW PP(Summit)	IPP	3'17.08+1'111.3	55	55	1326083	0	
13	Keraniganj 100 MW PP (Powerpac)	GRPP	8'13.45	0	0	0	0	Contract Expired
14	Narsingh 22 MW (Doreen)	SIPP, REB	8'22	22	19	377604	0	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	0	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	90	622080	0	Engine problem
18	Siddhirgonj 335 MW CAPP	EGCB	1'217+1'118	335	0	0	0	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	94	618192	0	Engine problem
20	Katpott 52 MW PP (Sinha)	IPP	7'17.9	0	0	0	0	Fuel shortage
21	Karnalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	35	379080	0	Engine problem
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	150	2647680	0	
23	Maniganj 55 MW PP (Northern)	IPP	3'19.3	55	55	297421	0	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	259508	0	
25	Bosila 108MW PP(CLO)	IPP	12'8.75+1'3.5	0	0	0	0	
26	Summit Power (Machhad-Ashulia)	SIPP, REB	33.67+18.73	80	52	1054320	0	Engine problem
27	Masona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	617600	0	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	22	695300	0	Engine problem
29	Gazipur 52 MW PP	RPCL	6'8.9	52	51	1234080	0	#REF!
30	Tongi 80 MW GTPP	PDB	1'105	105	0	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	240	5838652	0	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	250'1.4	300	0	0	0	Fuel conservation
33	Brambariganj 100 MW PP (Aggreko)	IPP	11'40.959	100	0	0	0	Fuel conservation
34	Aurahat 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	0	Fuel conservation
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	119	2652912	0	Engine problem
36	Gazipur 100 MW PP	RPCL	6'17.5	105	105	2469600	0	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	104	1014720	0	
38	Maniganj 162MW PP(MFGL)	IPP	9'18	162	162	1484640	0	
39	Spectra Solar Plant Ltd	IPP	35	35	35	255981	0	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18'4.3	55	55	1339200	0	
Dhaka area Total				5847	3077	13926179		
41	Chattogram TPP-1	PDB	1'210	180	0	100000	0	Machine problem
42	Chattogram TPP-2	PDB	1'210	180	0	0	0	Gas shortage
42	Raozan 25 MW PP	RPCL	3'8.9	25	25	610948	0	
43	Teknaf 20MW PP (Solartech)	IPP	20	20	0	140670	0	
44	Patenga 50MW PP (Baraka)	IPP	8'9.98	50	37	798800	0	Engine problem
45	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	129	3058182	0	Low water level
46	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	0	HGPI for 30 days.
47	Sikalbaha Peaking GT	PDB	1'150	150	0	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	88	2048245	0	Engine problem
49	Hathazari 100 MW peaking PP	PDB	11'8.9	98	52	1114992	0	Engine problem
50	Dahazari-Kalash 100 MW Peaking	PDB	8'17	102	36	327994	0	Fuel shortage
51	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	44	508560	0	Fuel shortage
52	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8'13.5	100	90	804480	0	Engine problem
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	18	398688	0	Engine problem
*	Malancha, Ctg. EPZ (United)		5'8.73+3'9.34	0	30	466800	0	
54	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	93	2104320	0	Engine problem
55	Kaptai 7 MW Solar PP	PDB	7.4	7	7	36940	0	
56	Anwara 300 MW PP (United)	IPP	17'17.24	300	300	4518873	0	
57	Jodac Power	IPP	3'18.55+1'3.6	54	54	1051074	0	
58	Karnaphuli Power Ltd.	IPP	18'41.5+6+5.5	110	110	2670497	0	
59	Juidah unit-2 (Acorn)	IPP	8'13.6	100	100	840960	0	
60	Anilma Energy Ltd.	IPP	6'21.2	116	108	2586873	0	Engine problem
Chattogram area Total				2382	1314	24185076		
61	Ashuganj TPP Unit-3	APSCL	1'150	0	0	0	0	Contract Expired
61	Ashuganj TPP Unit-4	APSCL	1'150	0	0	0	0	Contract Expired
61	Ashuganj TPP Unit-5	APSCL	1'150	134	0	0	0	Gas shortage
62	Ashuganj 225 MW CAPP	APSCL	1'142+1'175	221	200	4652000	0	#REF!
63	Ashuganj 450 MW CAPP(North)	APSCL	1'360	360	300	7342000	0	Gas shortage
64	Ashuganj 450 MW CAPP(South)	APSCL	1'360	360	320	7189000	0	FGMO
65	Ashuganj 420 MW CAPP(East)	APSCL	284'1+36'1	284	0	0	0	On test.
65	Ashuganj 50 MW PP (I)	APSCL	14'3.968	45	20	849456	0	Gas shortage
66	Ashuganj 55 MW PP (Precision)	ORPP	15'4	55	5	144480	0	Gas shortage
67	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'116	195	8	217454	0	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1232430	0	
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	117	2867054	0	Engine problem
70	Tras 50 MW Peaking PP	PDB	6'8.92	52	46	1116416	0	
71	Chandpur 150 MW CAPP	PDB	11'08+1'157	163	135	3111470	0	Machine problem
72	Chandpur 200MW (Dash energy)	IPP	12'18.4	200	200	3489640	0	
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	18	379044	0	Engine problem
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	221040	0	
**	Impoport (Tripura)	Imported power	0	160	158	3587520	0	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	673400	0	
76	Jangalia 52 MW PP (Lakshinaw)	IPP	8'9.92	52	43	365269	0	Engine problem
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	20	499200	0	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	0	Fuel conservation
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	836760	0	
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	104	2584680	0	Engine problem
81	Bhairab 54.5 MW	IPP	3'18.2	54	35	888480	0	33 kV feeder problem.
82	Chandpur 115(Doreen)	IPP	4'18.5+2'2.5	115	76	1271040	0	Engine problem
Cumilla Area Total				3169	2013	43618153		
83	RPCL 210MW CAPP	IPP	4'35+1'70	202	103	2041920	0	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	346608	0	
85	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	15000	0	
87	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	192	4615200	0	
88	Jamalpur 152MW Solar PP (United)	IPP	9'78'12	115	96	1352000	0	Engine problem
89	Sultajhat 50 MW Solar PP	IPP	50	50	0	262500	0	
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	24	583440	0	
Mymensingh Area Total				614	435	9196758		
91	Fenchugonj CAPP Phase-1	PDB	2'32+1'33	70	43	1020000	0	Machine problem
92	Fenchugonj CAPP Phase-2	PDB	2'35+1'35	90	42	965456	0	Machine problem
93	Kushibara 163 MW CAPP (KP)	IPP	1'109+1'54	163	0	287918	0	Gas shortage
94	Shahbazar 330 MW CAPP	PDB	3'110	330	0	0	0	Under maint.
95	Fenchugonj 51 MW PP (Barakattullah)	RPP	19'2.90	51	53	1119000	0	
96	Fenchugonj 44MW (Energytima)	NENP	12'3.3+5'2	50	45	1017000	0	
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	16251	0	
97	Shahbazar GTPP Unit- 8 & 9	PDB	2'35	66	61	1428664	0	
98	Shahbazar 86MW PP (Shahbazar)	RPP	32'2.90	86	81	1841280	0	
99	Shahbazar 100 MW GTPP	PDB	1'100	100	0	0	0	Under maint.
100	Sylhet 225 MW CAPP	PDB	1'142+1'139	231	220	5254410	0	
101	Sylhet 20 MW GTPP	PDB	1'20	20	18	52000	0	
102	Sylhet 50MW PP (EPL)	NENP	27'2	50	32	580160	0	Gas shortage
102	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	24	377928	0	
103	Bibiana-II 341 MW CAPP (Summit)	IPP	1'222+1'119	341	315	7521000	0	FGMO
104	Bibyanahill 400 MW CAPP	PDB	400 MW	400	404	9431000	0	
105	Sylhet 10MW PP (Desh)	RPP	6'11.95	10	10	243540	0	
106	Bibyanah South 400 MW	PDB	400 MW	383	0	459000	0	Under maint.
Sylhet Area Total				2477	1359	31763807		
**	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2'500	1000	849	21080727	0	
108	Khulna 115 MW PP (KPCL-2)	NENP	7'17	115	63	1092480	0	Fuel shortage
109	Fairpur 50 MW Peaking PP	PDB	6'6.89	46	46	478080	0	Engine problem
110	Khulna 225 MW CAPP	NWPGCL	1'150+1'175	230	0	0	0	Fuel conservation
111	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	58	661248	0	Line O/L
112	Bheramara 410 MW CAPP	NWPGCL	1'278+1'132	410	160	4702464	0	Gas shortage.
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	24	229500	0	Fuel shortage
113	Noapara 100 MW PP (Bangla Trac)							