

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month August, 2022		Day : Friday				Date : 12.08.22					
Probable Maximum Demand :		14200 MW				Probable Maximum Generation : 12925 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 95.69 ft				Today = 95.79 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.08.22 (Yesterday)		12.08.22 (Today)		Rule Curve = 92.52 ft		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation	Machines shut down (MW)	
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	290	300	300		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	82	80	83	83		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	307	206	300	300	154	Gas Shortage
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	258	391	350	390		
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	30	30	30		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	32	8	32	70	Fuel Oil Shortage
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22		
17	Summit Power,(Madhab+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	51	47	50	50		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	16	30	30		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	42	42	42		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	88	88	88		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	127	36	130		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	82	277	82	285		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	43	149	43	149		
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	256x1.4	300	300	300	300	300	300		
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	98	90	100		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	98	0	0		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	33	17	33	71	Fuel Oil Shortage
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	21	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	55	55		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	49	8	50	51	Fuel Oil Shortage
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	7	32	15	32	68	Fuel Oil Shortage
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
<b>Dhaka Zone Total</b>			<b>6004</b>	<b>5847</b>	<b>2522</b>	<b>3206</b>	<b>2559</b>	<b>3265</b>	<b>1519</b>	<b>660</b>	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	107	107	107	107		Unit 1 under rehabilitation
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	110	110	110	110	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	2	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	45	19	45		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	68	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI
47	Amwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	51	214	52	214		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	21	90	21	90		
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51	51	Fuel Oil Shortage
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	25	34	25	34		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15		
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			8	32	15	30		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	7	90	12	90		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	98	20	100		
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	33	33	33	67	Fuel Oil Shortage
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	108	108	108	108		
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>739</b>	<b>1248</b>	<b>763</b>	<b>1248</b>	<b>118</b>	<b>555</b>	
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	36	42	42	42		
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	183	188	190	190		
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	260	270	280	310		
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	280	300	280	320		
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0		On test
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	50	55	55	55		
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	43	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	117	140	118	142		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	47	47	47	47		
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	124	123	130	130		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	200	34	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	10	10	10		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	21	33	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20		
76	Deukandi 200 MW PP (B.Trac)	HSD (IPP)	39x1.4+6x1.015+10x1.06	200	200	0	0	0	0		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	17	114		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	39	105	38	105		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	73	74	74	75		
**	Impoort (Tripura)	India		160	160	90	78	143	166		
<b>Cumilla Zone Total</b>			<b>3193</b>	<b>3169</b>	<b>1513</b>	<b>1923</b>	<b>1635</b>	<b>2083</b>	<b>187</b>	<b>0</b>	
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	63	98	60	90	104	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	78	48	78		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	180	48	180		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutiakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0		
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
<b>Mymensingh Zone Total</b>			<b>622</b>	<b>614</b>	<b>247</b>	<b>390</b>	<b>242</b>	<b>382</b>	<b>104</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.08.22 (Yesterday)		12.08.22 (Today)		11.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)			
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	0	0		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0				
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	62	62	64				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	80				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	221	221	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1x20	20	20	0	0	0	0		20	Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	12	12				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	300	320				
101	Bibyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	395	403	400	400				
102	Bibyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	382	388	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	30	30		50	Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0		50	Gas Shortage	
<b>Sylhet Zone Total</b>				<b>2522</b>	<b>2477</b>	<b>1460</b>	<b>1536</b>	<b>1498</b>	<b>1590</b>	<b>120</b>	<b>669</b>		
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	155	145	155	155		265	Gas Shortage	
108	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	45	0	43				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	72	0	70		37	Maintenance ongoing	
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	228	230	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	94	96	94	94				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	53	17	52				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.445	105	105	67	105	105	105				
114	Mongla Onon 100 MW Solar PP	Solar (IPP)		100	100	60	0	100	0				
115	Khulna 115 MW PP (KPOL-2)	HFO (NENP)	7x17	115	115	16	16	16	32		99	Fuel Oil Shortage	
116	Noapara 40 MW PP (Kharjahan Ali)	HFO (NENP)	5'8.5	40	40	8	8	8	8		32	Fuel Oil Shortage	
**	Bheramara (HVDC)	India		1000	1000	906	907	920	920				
<b>Khulna Zone Total</b>				<b>2388</b>	<b>2384</b>	<b>1551</b>	<b>1677</b>	<b>1640</b>	<b>1704</b>	<b>396</b>	<b>37</b>		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	16	110				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	27	15	20				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	88	88	88	88		106	Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	490	70	620	620				
121	Potashkhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x3.78	150	150	0	116	50	116				
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	218	220	225	0				
<b>Barishal Zone Total</b>				<b>1958</b>	<b>1958</b>	<b>812</b>	<b>631</b>	<b>1014</b>	<b>954</b>	<b>106</b>	<b>0</b>		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	31	31	32	32		18	Turbocharger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	177	133	50	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	34	41	40	40				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	46	80	50	80				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	32	40		10	Under maint.	
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	42	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	34	33	33	34		17	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	152	152	150	150		58	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	209	218	220	220		220	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	147	148	150	150		72	Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	279	308	300	300		106	Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	21	21				
136	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	16	8	16				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	55	95	55	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	50	94	50	90				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
<b>Rajshahi Zone Total</b>				<b>2129</b>	<b>2129</b>	<b>1288</b>	<b>1463</b>	<b>1250</b>	<b>1321</b>	<b>627</b>	<b>45</b>		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	251	250	250				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	56	55	56	56				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara. Tatalia 8MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	17	72	17	72				
<b>Rangpur Zone Total</b>				<b>800</b>	<b>720</b>	<b>327</b>	<b>378</b>	<b>331</b>	<b>378</b>	<b>0</b>	<b>85</b>		
<b>Sub-total: Plants in operation</b>				<b>22058</b>	<b>21680</b>	<b>10459.0</b>	<b>12452</b>	<b>10932</b>	<b>12925</b>	<b>3177</b>	<b>2051</b>		
<b>(B) Plants under long term maintenance/ contract expired</b>													
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0				
<b>Gross Total</b>				<b>22482</b>	<b>21680</b>	<b>10459</b>	<b>12452</b>	<b>10932</b>	<b>12925</b>	<b>3177</b>	<b>2051</b>		

<b>(C) Actual data of 11.08.22 (Yesterday) Thursday :</b>													
Sl. No.	Description	Value	Unit	Time	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :				Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :				
					Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	Zone	
01.	Max. Demand at eve. peak (Generation end)	13450	MW	at =	21:00								
02.	Max. Demand at eve. peak (Sub-station end)	12957	MW	at =	21:00								
03.	Highest Generation (Generation end)	12452	MW	at =	21:00								
04.	Minimum Generation (Generation end)	10280	MW	at =	7:00								
05.	Day-peak Generation (Generation end)	10459	MW	at =	10:00								
06.	Evening-peak Generation (Generation end)	12452	MW	at =	21:00								
07.	Evening Peak Load-shed (Sub-station end)	920	MW	at =	21:00								
08.	Minimum Generation Forecast up to 8:00 hrs.	9620	MW	at =	5:00								
09.	Generation shortfall at evening peak due to :												
	a) Gas limitation	3177	MW										
	d) Coal supply Limitation	0	MW										
	b) Low water level in Kaptai lake	0	MW										
	c) Plants under shut down maintenance	2051	MW										
10.	Total Energy (Generation + India Import)	263.42	MKWh										
	By Gas =	130.584	MKWh										
	By Coal =	14.821	MKWh										
	By Solar =	1.094	MKWh										
11.	Total Gas Supplied	963.93	MMCFD										
12.	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
	Dhaka	4612	4422	190	Mymensingh	1081	891	190					
	Chattogram	1246	1246	0	Sylhet	595	555	40					
	Khulna	1539	1364	175	Barishal	356	356	0					
	Rajshahi	1341	1191	150	Rangpur	908	908	0					
	Cumilla	1280	1105	175									
					<b>Total</b>	<b>12957</b>	<b>12037</b>	<b>920</b>					
13.	Fuel cost :	(a) Gas =	146727449	Taka	(c) Coal =	110843838	Taka						
		(b) Oil =	1377368342	Taka	Total =	1634939629	Taka						
14.	Maximum Temperature in Dhaka was :				33° C								
15.	Export through East-West interconnections :												
	At evening peak-hour		10459	MW	at	21:00	hrs						
	Maximum		98	MW	at	19:00	hrs						
	Energy		0	MKWh									
04.	Maximum Load-shed	1175	MW										
05.	Total Generation	300.40	MKWh										
06.	Probable Max. Temperature in Dhaka :				33.5° C	</							