

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022		Day : Sunday				Date : 14.08.22							
Probable Maximum Demand :		14000 MW				Probable Maximum Generation : 13590 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 95.91 ft				Today = 95.95 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.08.22 (Yesterday)		14.08.22 (Today)		Rule Curve = 93.16 ft.		13.08.22 (Yesterday) Gen. shortfall for : Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Day	Evening	Day	Evening			
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	85	83	88	88				
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contact Expired
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	338	334	330	330				
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225		225		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	403	405	412	412				
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	97	97	97		113		Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335		Gas Shortage
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0		335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	25	30	30	30				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	50	8	16		52		Fuel Oil Shortage
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22				
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x7.73	80	80	49	52	52	52				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	30	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	41	41	41				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88				
22	Kodda 150MW PP	HFO (BRPger)	9x17.06	149	149	16	130	16	130				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	275	80	275				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	33	140	43	149				
26	Keeraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	108	203	300	300				
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	91	50	96	96				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	98	100	0	0				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	16	50	17	50		54		Fuel Oil Shortage
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	20	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	55	55				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	49	8	50		51		Fuel Oil Shortage
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	7	48	7	48		52		Fuel Oil Shortage
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total			6004	5847	2385	3319	2833	3426	1217	660			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	107	106	101	101				Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	107	110	110				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	42	19	45				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	105	17	105				
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225		Awaiting for HGPI
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	135	214	118	214				
48	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	21	90	21	90				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	20	51	17	51		51		Fuel Oil Shortage
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	34	25	34		64		Fuel Oil Shortage
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15				
	* Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			5	32	10	25				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	94	12	94				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55				
55	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	20	100	20	100				
56	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	33	33	33	33		67		Fuel Oil Shortage
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	108	89	108	108				
Chattogram Zone Total			2442	2382	740	1228	767	1241	182	555			
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	42	42	42	42				
60	Ashuganj 225 MW CAPP	Gas (AFSCL)	1x142+1*75	221	221	179	209	200	200				
61	Ashuganj 450 MW CAPP(South)	Gas (AFSCL)	1x360	360	360	310	290	280	300				
62	Ashuganj 450 MW CAPP(North)	Gas (AFSCL)	1x361	360	360	310	290	280	290				
63	Ashuganj 420 MW CAPP(East) GT	Gas (AFSCL)	1x284	284	284	0	0	0	0				On test
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	20	55	55				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8		187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	128	142	134	142				
68	Titab 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	40	48	40	48				
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	30	30				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	0	0	0				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	20x14+6x15.97+1x11.066	200	200	51	200	100	200				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	29	57	30	57				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	46	73	74	75				
**	Impport (Tripura)	India		160	160	156	168	143	166				
Cumilla Zone Total			3193	3169	1697	1918	1787	1984	187	0			
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	70	103	82	100		99		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	22	22				
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	69	78	78	78				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	75	182	48	180				
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
86													

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.08.22 (Yesterday)		14.08.22 (Today)		13.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	MW	MW			
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	31	31	31				
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	63	62	64				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	25	80				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	221	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	9	9	9				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	290	300	320				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	401	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	11	11	11	11		39	Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4*5*2	50	50	10	10	10	10		40	Gas Shortage	
Sylhet Zone Total					2522	2477	1492	1568	1519	1596	99	710	
106	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	145	155	170	170		255	Gas Shortage	
108	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	41	0	43				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	64	0	70		45	Maintenance ongoing	
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	219	227	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	93	64	94	94				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	53	17	52		52	Fuel Oil Shortage	
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	70	105	90	105				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	105	0	100	0				
115	Khulna 115 MW PP (KPOL-2)	HFO (NENP)	7x17	115	115	0	21	16	66		94	Fuel Oil Shortage	
116	Noapara 40 MW PP (Khenjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	8	8		32	Fuel Oil Shortage	
**	Bheramara (HVDC)	India		1000	1000	899	899	912	912				
Khulna Zone Total					2388	2384	1548	1637	1632	1745	433	45	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	110	110				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	21	15	21				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	50	60	88	88		134	Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	570	590	620	620				
121	Potuaikhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	54	50	110				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	202	201	225	225				
Barisal Zone Total					1958	1958	875	974	1108	1174	134	0	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	8	32	32		18	Turbocharger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	172	76	80	177				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	33	33	33				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	45	81	50	80				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	16	40		10	Under maint.	
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	42	42	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	33	33	33	33		17	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	152	152	150	150		58	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	211	215	220	220		220	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	146	147	157	157		73	Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	274	307	330	330		107	Gas Shortage	
135	Bogra 22 MW PP (GGB)	Gas (RPP)	6x4.0	22	22	17	21	21	21				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	16				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	95	55	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0				
Rajshahi Zone Total					2129	2129	1243	1363	1294	1550	629	45	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	70	70				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	55	90	70	90				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Hajpara, Talia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	17	72				
Rangpur Zone Total					800	720	311	412	415	482	0	85	
Sub-total: Plants in operation					22058	21680	10554.0	12811	11649	13590	2980	2100	
(B) Plants under long term maintenance/ contract expired													
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020	
153	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0	
Gross Total					22482	21680	10554	12811	11649	13590	2980	2100	
(C) Actual data of 13.08.22 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	: 13200 MW, at = 21:00 hrs		12.		Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	: 12846 MW, at = 21:00 hrs		Zone		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	: 13000 MW, at = 22:00 hrs		Dhaka		4558	4558	0	Mymensingh	1170	915	255	
04.	Minimum Generation (Generation end)	: 10378 MW, at = 9:00 hrs		Chattogram		1325	1325	0	Sylhet	562	517	45	
05.	Day-peak Generation (Generation end)	: 10554 MW, at = 12:00 hrs		Khulna		1539	1539	0	Barishal	322	322	0	
06.	Evening-peak Generation (Generation end)	: 12811 MW, at = 21:00 hrs		Rajshahi		1417	1417	0	Rangpur	784	726	58	
07.	Evening Peak Load-shed (Sub-station end)	: 358 MW, at = 21:00 hrs		Cumilla		1170	1170	0					
08.	Minimum Generation Forecast up to 8.00 hrs.	: 10268 MW, at = 5:00 hrs							Total	12846	12488	358	
09.	Generation shortfall at evening peak due to :			13.		Fuel cost :							
a) Gas limitation	: 2980 MW				(a) Gas = 149634287 Taka		(c) Coal = 165677147 Taka						
d) Coal supply Limitation	: 0 MW				(b) Oil = 1318573860 Taka		Total = 1633885294 Taka						
b) Low water level in Kaptai lake	: 0 MW												
c) Plants under shut down/ maintenance	: 2100 MW				14.		Maximum Temperature in Dhaka was : 33.6° C						
10.	Total Energy (Generation + India Import)	: 269.37 MMKWh		15.		Export through East-West interconnections :							
	By Gas = 132.980 MKWh	By Oil = 86.952 MKWh			At evening peak-hour		: 10554 MW, at 21:00 hrs						
	By Coal = 20.890 MKWh	By Hydro = 2.485 MKWh			Maximum		: 224 MW, at 22:00 hrs						
	By Solar = 1.080 MKWh			Energy		: 0 MKWh							
11.	Total Gas Supplied	: 995.53 MMCFD											
(D) Forecast of 14.08.22 (Today) Sunday :													
01.	Maximum Demand	: 14000 MW (Generation end)		04.		Maximum Load-shed : 377.84575 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 13590 MW (Generation end)		05.		Total Generation : 290.09 MMKWh							
03.	Reserve / Shortage	: -410 MW (Generation end)		06.		Probable Max. Temperature in Dhaka : 32.0° C							

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation