

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCPP-Unit-3 (GT)	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Under maint.
3	Ghorasal TPP Unit-1	PDB	1'210	180	180	4284000	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	300	7227564	Machine problem
4	Ghorashal 78.5 MW PPI(MAX)	ORPP	2'40	0	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	91	2107636	Engine problem
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	400	9728000	Gas shortage
7	Haripur 360 MW CCPP(HPL)	IPP	1'235+1'125	360	333	7002000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	300	6613650	Dirty gas
9	Meghnaghat 100 MW(IELE)	NENP	1'28.9	100	41	271680	Fuel shortage
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	0	0	Gas shortage
11	Madanganj 102 PPI(Summit)	NENP	6'17	102	0	0	Under maint.
12	Madanganj 55 MW PPI(Summit)	IPP	3'17.08+1'111.3	55	55	1145451	
13	Keraniganj 100 MW PP (Powerpac)	GRPP	8'13.45	0	0	0	Contract Expired
14	Narshingaj 22 MW PP (Doreen)	SIPP, REB	8'20	22	19	428624	Engine problem
15	210 MW Siddhirganj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirganj 2'120 MW GTPP	EGCB	2'105	210	0	673000	Gas shortage
17	Siddhirganj 100 PPI(Dutch Bangla)	NENP	12'8.9	100	40	383702	Fuel shortage
18	Siddhirganj 335 MW CCPP	EGCB	1'217+1'118	335	338	3838283	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	40	384624	Fuel shortage
20	Katpott 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage
21	Karnalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	792720	
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	125	1565760	Engine problem
23	Maniganj 55 MW PP (Northern)	IPP	3'19.3	55	55	887778	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	35	460572	Engine problem
25	Bosila 108MW PPI(OLC)	IPP	12'8.75+1'35.0	0	0	0	
26	Summit Power (Machadi-Ashulia)	SIPP, REB	33.67+1'173	80	52	1119480	
27	Masona 33 MW PPI(Summit)	SIPP, REB	4'8.73	33	33	801100	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	30	707800	
29	Gazipur 52 MW PP	RPCL	6'9.9	52	31	320640	#REF!
30	Tongi 80 MW GTPP	PDB	1'105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	278	4787344	Engine problem
32	Keraniganj 300 MW PP (IPP)	IPP	256'1.4	300	122	2919533	Engine problem
33	Bramhariganj 100 MW PP (Aggreko)	IPP	11'40.969	100	90	1552373	Engine problem
34	Aurahat 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	90	1524872	Engine problem
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	140	2967552	
36	Gazipur 100 MW PP	RPCL	6'17.5	105	105	1086600	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	55	584640	Fuel shortage
38	Maniganj 162MW PPI(MPL)	IPP	9'18	162	162	1946880	
39	Spectra Solar Plant Ltd	IPP	35	35	0	210110	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	55	1325160	
Dhaka area Total							
				5847	3648	69677628	
41	Chattogram TPP-1	PDB	1'210	180	110	2600000	Machine problem
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
42	Raozan 25 MW PP	RPCL	3'8.9	25	25	624898	
43	Teknaf 250MW PP (Solartech)	IPP	20	20	0	118530	
44	Patenga 50MW PP (Baraka)	IPP	9'8.98	50	39	690720	Engine problem
45	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2'40+3'50	230	152	3544669	Low water level
46	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	HGPI for 30 days.
47	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	87	1819091	Engine problem
49	Hathazari 100 MW peaking PP	PDB	11'8.9	98	43	713424	Fuel shortage
50	Dahazari-Kalshah 100 MW Peaking	PDB	8'17	102	51	628480	Fuel shortage
51	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	10	261960	Fuel shortage
52	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8'13.5	100	10	257280	Fuel shortage
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	16	356784	Engine problem
*	Malancha, Ctg. EPZ (United)		5'8.73+3'9.34	0	30	507360	
54	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	95	657600	Engine problem
55	Kaptai 7 MW Solar PP	PDB	7.4	7	0	28664	
56	Anwara 300 MW PP (United)	IPP	17'1+24	300	52	1462800	
57	Jodac Power	IPP	3'18.55+1'3.6	54	17	710766	Engine problem
58	Karnaphuli Power Ltd.	IPP	18.415'6+6.5	110	110	2685552	
59	Juidah unit-2 (Acorn)	IPP	8'13.6	100	10	264000	Engine problem
60	Anilma Energy Ltd.	IPP	6'21.2	116	107	2531673	Engine problem
60	Mirshara 150 MW	BPDB-RPCL	18.5'9	0	0	0	On test.
Chattogram area Total							
				2382	963	20465251	
61	Ashuganj TPP Unit-3	APSCCL	1'150	0	0	0	Contract Expired
61	Ashuganj TPP Unit-4	APSCCL	1'150	0	0	0	Contract Expired
62	Ashuganj TPP Unit-5	APSCCL	1'150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCPP	APSCCL	1'142+1'175	221	209	5000000	#REF!
63	Ashuganj 450 MW CCPP(North)	APSCCL	1'360	360	330	7882300	Gas shortage
64	Ashuganj 450 MW CCPP(South)	APSCCL	1'360	360	305	7196000	FGMO
65	Ashuganj 420 MW CCPP(East)	APSCCL	284'136'1	0	284	0	On test.
65	Ashuganj 50 MW PP	APSCCL	14'3.968	45	40	851112	Engine problem
66	Ashuganj 55 MW PP (Precision)	ORPP	15'4	55	56	1300800	
67	Ashuganj 195MW PP (APSCCL-United)	IPP	20'9.73+1'116	195	8	200727	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1208656	
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	133	3082872	Engine problem
70	Titas 50 MW Peaking PP	PDB	6'8.92	50	46	105342	Engine problem
71	Chandpur 150 MW CCPP	PDB	11'108+1'157	163	136	3343770	Machine problem
72	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	180	2542080	Line O/L
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	471456	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	226880	
**	Imported (Tripura)	Imported power	0	160	148	3550080	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	25	590100	Engine problem
76	Jangalia 50 MW PP (Lakshmi)	IPP	6'8.92	50	8	54034	Fuel shortage
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	17	437880	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	2865408	Reserve.
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	0	172140	Fuel shortage
80	Chowmahani 113 MW	IPP	12'9.78+2'3.1	113	115	1340640	
81	Bharob 54.5 MW	IPP	3'18.2	54	35	887760	33 KV feeder problem.
82	Chandpur 115(Doreen)	IPP	4'18.5+2'22.5	115	77	1983360	Engine problem
Cumilla Area Total							
				3169	1951	46251687	
83	RPCL 210MW CCPP	IPP	4'35+1'70	202	107	2219640	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	0	0	Gas shortage
85	Jamapur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	13900	
87	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	97	1999200	Fuel shortage
88	Jamapur 115 MW PP (United)	IPP	9'78'12	115	109	1711200	Engine problem
89	Sutakhal 50 MW Solar PP	IPP	50	50	0	350030	
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	278160	Engine problem
Mymensingh Area Total							
				614	325	6569130	
91	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	43	1024000	Machine problem
92	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	90	41	737080	Machine problem
93	Kushnara 163 MW CCPP (KP)	IPP	1'109+1'154	163	0	0	Gas shortage
94	Shahbazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	18'2.90	51	5	128400	Gas shortage
96	Fenchugonj 44MW (Energypac)	NENP	12'3.3+5'2	50	0	0	Gas shortage
97	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	0	0	Engine problem
98	Shahbazar GTPP Unit- 8 & 9	PDB	2'35	66	64	1420608	
98	Shahbazar 86MW PP (Shahbazar)	RPP	32'2.90	86	81	1111680	
99	Shahbazar 100 MW GTPP	PDB	1'100	100	0	0	Under maint.
100	Sylhet 225 MW CCPP	PDB	1'142+1'189	231	193	4682210	Machine problem
101	Sylhet 20 MW GTPP	PDB	1'20	20	0	0	Gas shortage
101	Sylhet 50MW PP (EPL)	NENP	27'2	50	6	170200	Gas shortage
102	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	8	186144	Gas shortage
103	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	290	7020000	FGMO
104	Bibiana-III 400 MW CCPP	PDB	400	400	403	9598000	
105	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	243000	
106	Bibiana South 400 MW	PDB	400 MW	383	401	9431100	
Sylhet Area Total							
				2477	1545	35753150	
107	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2'500	1000	887	21536000	
108	Khulna 115 PP MW (RPCL-2)	NENP	7'17	115	16	94080	Fuel shortage
109	Fardpur 50 MW Peaking PP	PDB	8'8.98	54	26	154080	Engine problem
110	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	226	4527360	
111	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	62	539136	Engine problem
112	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	280	6302880	Gas shortage.
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	0	Fuel shortage
113	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	460800	Engine problem
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	17	153680	Fuel shortage
115	Madhumati 100 MW PP	NWPGCL	6'18	105	67	791280	Fuel shortage
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	374400	
117	Khulna 330 MW CCPP (OIL)	BPDB	1'220+1'110	0	0	0	On test.
	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0	
Khulna Area Total							
				2384	1581	34939376	
117	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	32	463392	Line O/L
118	Bhola 33 MW PP (Venture)	NENP	1'34.50	40	22	498847	Engine problem
119	Bhola 225 MW CCPP	PDB	2'63+1'69	194	86	2860656	Gas shortage
120	Bhola 95 MW PP (Aggreko)	ORPP	96'11.00	0	0	0	Contract Expired
121	Payra 1320 MW	BCPCL	2'622	1244	1090	26073300	Line O/L
122	Bhola Nulan Biddut BD LTD	IPP	220	220	191	2985820	Under maint.
123	United Payra Power Ltd.	IPP	8'18.5+1'9.5	150	0	0	Line O/L
Barisal Area Total							
				1958	1421	32881995	
124	Baghabari 71 MW GTPP	PDB	1'71	71	0	0	Gas shortage
124	Baghabari 100 MW GTPP	PDB	1'100	100	0	0	Gas shortage
125	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	32	760880	Engine problem
126	Bera 70 MW Peaking PP	PDB	9'8.29	71	26	307721	Engine problem
127	Amnura 50 MW PPI(Sinha)	QRPP	7'7.9	0	0	0	Contract Expired
128	Katakhal 50 MW PP (Northern)	QRPP	6'8.9	50	42	969072	Engine problem
129	Katakhal 50 MW Peaking PP	PDB	6'8.7	50	32	170290	Engine problem
130	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'175	210	214	5322291	
131	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'175	220	216	4755145	
132	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	190	5024445	Gas shortage
133	Sirajgonj 400 MW CCPP Unit-4	NWPGCL	1'282+1'132	414	419	9750327	
134	Santahar 50 MW Peaking PP	PDB	6'8.7				