

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month January, 2023			Day : Monday				Date : 09.01.23				
Probable Maximum Demand :			10200 MW		Probable Maximum Generation : 9482 MW				Rule Curve = 101.48 ft.		
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 85.76 ft		Today = 85.71 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.01.23 (Yesterday)		09.01.23 (Today)		08.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	200	200	165	ST under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	73	74	70	73	34	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Contract Expired
6	Hariapur GTPP	Gas (PDB)	1x 32	32	20	0	0	0	0	20	Gas Shortage
7	Hariapur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	265	260	260	260	100	Gas Shortage
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hariapur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	346	319	340	340	93	Gas Shortage
11	Siddhirganj 2 120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	Gas Shortage
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	155	156	150	160	179	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8	8	
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19	22	
17	Summit Power,(Madhadi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	46	43	45	48	48	
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	30	25	25		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	30	33		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	50	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	16	16	16		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	17		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	231	98	280	280		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	16	17	17	17		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	163	11	0	100		
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
29	Nababganj 55 MW PP (Southern power )	HFO (IPP)	3x19.3	55	55	17	17	17	35	55	
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	17	17	35	55	
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	17	17		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	22	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	8	8	8		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	9	9	9	9		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	48	60	90	90		
<b>Dhaka Zone Total</b>			<b>6004</b>	<b>5847</b>	<b>1982</b>	<b>1889</b>	<b>1945</b>	<b>2259</b>	<b>1568</b>	<b>848</b>	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	2	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x8.69	50	50	19	20	20	20		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	160	160	161	161		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x6.04	300	300	51	300	51	300		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	51	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	34	34	34	34		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	9	7	10		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	16	17	17	17		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	51	50	51		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25		
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	22	22	22	22		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	45	51	51		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>566</b>	<b>865</b>	<b>611</b>	<b>873</b>	<b>402</b>	<b>330</b>	
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5	40	Gas Shortage
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	192	182	210	210		
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360	Under maint.
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	330	295	330	330		
63	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	265	308	270	300		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	20	5	5	5	50	Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	43	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	55	6	55	95	Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	20	29	31	31		
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	0	0		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	16	25	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	21	21	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+6x11.515+1x1.098	200	200	178	60	100	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	0	0		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	9	9	9		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	16	17	17	17		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	94	94	94	94		
**	Impoort (Tripura)	India		160	160	108	110	135	153		
<b>Cumilla Zone Total</b>			<b>3309</b>	<b>3285</b>	<b>1365</b>	<b>1321</b>	<b>1348</b>	<b>1461</b>	<b>506</b>	<b>523</b>	
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	34	98	70	100	104	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	28	47		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	47	48	48	48		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0		
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
<b>Mymensingh Zone Total</b>			<b>622</b>	<b>614</b>	<b>143</b>	<b>227</b>	<b>232</b>	<b>231</b>	<b>104</b>	<b>0</b>	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.01.23 (Yesterday)		09.01.23 (Today)		08.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening						
88	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	GT-1 Under maint.			
89	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	31	31	31	31		59	GT-4 Under maint.			
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	51	45	45						
91	Kushiara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	2	0	0						
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	62	64	64						
94	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2x.90	86	86	40	84	40	86						
96	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	196	196	200	200						
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	19	19	19	19						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	9	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0						
100	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	341	295	330	310						
101	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0		400	Under maint.			
102	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400						
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0						
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.4+5x2	50	50	46	50	44	44						
<b>Sylhet Zone Total</b>						<b>2522</b>	<b>2477</b>	<b>1193</b>	<b>1199</b>	<b>1183</b>	<b>1209</b>	<b>0</b>	<b>1122</b>		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CCGP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Under maint.			
108	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	26	28	0	40						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	76						
110	Khulna 225 MW CCGP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	40	90	40	90						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	13	10	17	17						
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	75	0	100	0						
115	Khulna 115 MW PP (KFCL-2)	HFO (NENP)	7x17	115	115	32	99	32	100						
116	Noapara 40 MW PP (Khanjehan Ali)	HFO (NENP)	5x8.5	40	40	0	40	40	40						
	Rampal 1320 MW	Coal (BIFPCL)				542	530	0	0						
	Khulna 330 MW CCGP	Gas/HSD (B/PDB)				0	0	0	0						
**	Bheramara (H/DC) India			1000	1000	492	491	489	489						
<b>Khulna Zone Total</b>						<b>2388</b>	<b>2384</b>	<b>1220</b>	<b>1288</b>	<b>718</b>	<b>852</b>	<b>0</b>	<b>410</b>		
117	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	25	19	25						
119	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	162	186	170	180						
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	500	622	622	622						
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload			
	Barisal Electric 307 MW	Coal (IPP)				171	292	250	300						
122	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	223	220	220	220						
<b>Barishal Zone Total</b>						<b>1958</b>	<b>1958</b>	<b>1094</b>	<b>1345</b>	<b>1281</b>	<b>1347</b>	<b>0</b>	<b>260</b>		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	70	0	0	0		71	Gas Shortage			
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage			
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32						
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	50						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	17	0	25						
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	0	80						
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	16	0	40						
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	8	8	8						
130	Santzhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	36						
131	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage			
132	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	220	193	200	180						
133	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.			
134	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	140	433	300	380						
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	18	22	22						
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10						
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	8						
138	Baqura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	35	35	35						
139	Baqura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	35	35						
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0						
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0						
<b>Raishahi Zone Total</b>						<b>2129</b>	<b>2129</b>	<b>515</b>	<b>884</b>	<b>624</b>	<b>941</b>	<b>381</b>	<b>220</b>		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160		114	Coal Shortage			
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	49	34	34						
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tatulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0						
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	115	113	105	115						
148	Malmonhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	30	0	30	0						
	Trestle Solar Limited	Solar (IPP)				161	0	0	0						
<b>Rangpur Zone Total</b>						<b>830</b>	<b>750</b>	<b>504</b>	<b>322</b>	<b>337</b>	<b>309</b>	<b>199</b>	<b>85</b>		
<b>Sub-total: Plants in operation</b>						<b>22204</b>	<b>21826</b>	<b>8582.0</b>	<b>9340</b>	<b>8279</b>	<b>9482</b>	<b>3160</b>	<b>3798</b>		
<b>(B) Plants under long term maintenance/ contract expired</b>															
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
153	Ammura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022		
	Sub-Total: Plants under long term maintenance/ contract expired			404	0	0	0	0	0						
<b>Gross Total</b>						<b>22608</b>	<b>21826</b>	<b>8582</b>	<b>9340</b>	<b>8279</b>	<b>9482</b>	<b>3160</b>	<b>3798</b>		
<b>(C) Actual data of 08.01.23 (Yesterday) Sunday :</b>															
01.	Max. Demand at eve. peak (Generation end)	:	9861	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	9338	MW, at =	20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	9340	MW, at =	20:00 hrs	Dhaka	3325	3191	134	Mymensingh	822	721	101		
04.	Minimum Generation (Generation end)	:	6079	MW, at =	5:00 hrs	Chattogram	953	916	35	Sylhet	355	293	62		
05.	Day-peak Generation (Generation end)	:	8582	MW, at =	12:00 hrs	Khulna	1169	1122	47	Barishal	262	262	0		
06.	Evening-peak Generation (Generation end)	:	9340	MW, at =	20:00 hrs	Rajshahi	956	939	17	Rangpur	672	588	84		
07.	Evening Peak Load-shed (Sub-station end)	:	480	MW, at =	20:00 hrs	Cumilla	825	825	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6187	MW, at =	5:00 hrs					Total	9338	8858	480		
09.	Generation shortfall at evening peak due to :	:								(a) Gas =	112422537	Taka	142551037	Taka	
	a) Gas/LF limitation	:	2761	MW						(b) Oil =	515273932	Taka	Total =	770247506	Taka
	d) Coal supply Limitation	:	199	MW											
	b) Low water level in Kaptai lake	:	200	MW											
	c) Plants under shut down/ maintenance	:	3798	MW											
10.	Total Energy (Generation + India Import)	:	193.33	MKWh											
	By Gas =	106.426	MKWh	By Oil =	35.801	MKWh									
	By Coal =	34.705	MKWh	By Hydro =	0.707	MKWh									
	By Solar =	1.611	MKWh												
11.	Total Gas Supplied	:	821.31	MMCFD											
<b>(D) Forecast of 09.01.23 (Today) Monday :</b>															
01.	Maximum Demand	:	10200	MW	(Generation end)	04.	Maximum Load-shed	:	662	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	9482	MW	(Generation end)	05.	Total Generation	:	211.13	MW					
03.	Reserve / Shortage	:	-718	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka	:	27.7° C						

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation