

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2023				Day : Thursday				Date : 26.01.23			
Probable Maximum Demand : 10300 MW				Probable Maximum Generation : 10300 MW				Rule Curve = 98.60 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 84.27 ft				Today = 84.15 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.01.23 (Yesterday)		26.01.23 (Today)		25.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation		
					Day	Evening	Day	Evening	MW	MW	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	210	210	210	210		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	74	76	50	50	32	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	173	182	200	200		
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Under Maint.
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	331	336	350	350		
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	Gas Shortage
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	137	138	150	150	197	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	48	24	48		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19		
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	51	50	51	51		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	29	30	30	30		
20	Gezipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	33	17	8	17		
21	Gezipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	52	34	52		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	48	16	48		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	107	115	32	66		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	53	52	52	52		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0		
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
29	Nababaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	17	35		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	55	17	55		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	17	17		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	17	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17		
35	Siddhirganj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	8	0	8		
36	Meghnaghat 100 MW (IEL)	HFO (NENP)	12x8.9	100	100	8	9	9	9		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	11	17	17		
Dhaka Zone Total				6004	5847	1580	1663	1450	1639	951	1308
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	33	32	33	33		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	85	32	85		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	226	154	157	157		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	106	284	110	284		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25		
49	Dohazani-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	68	51	68		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	31	31	32	32		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			2	6	5	10		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	92	52	92		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25		
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	22	22	22	22		
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	75	68	51	107		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test
Chattogram Zone Total				2442	2382	764	956	675	1004	402	330
58	Ashuganj TPP Unit- 5	Gas (AFSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (AFSCL)	14x3.968	53	45	10	10	10	10		
60	Ashuganj 225 MW CCGP	Gas (AFSCL)	1x142+17x5	221	221	194	222	200	200		
61	Ashuganj 450 MW CCGP(South)	Gas (AFSCL)	1x360	360	360	0	0	0	0	360	Under maint.
62	Ashuganj 450 MW CCGP(North)	Gas (AFSCL)	1x361	360	360	315	285	290	290		
63	Ashuganj 420 MW CCGP(East)	Gas (AFSCL)	1x284+1x116	400	400	316	327	300	300		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	20	5	5	5	50	Gas Shortage
65	Ashuganj 195MW PP (AFSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6	144	Gas Shortage
68	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	29	19	35	35		
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	13	21	21	21		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	20	20	20		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+86x1.515+15x1.09	200	200	0	10	0	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	25	17	17	17		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	107	9	113		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	94	54	94		
**	Impoport (Tripura)	India		160	160	124	114	135	152		
Cumilla Zone Total				3309	3285	1259	1387	1232	1493	515	523
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	35	104	50	60	98	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	18	18		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	28	47		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	57	48	48		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutahkhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0		
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6		
Mymensingh Zone Total				622	614	136	232	202	179	98	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.01.23 (Yesterday)		26.01.23 (Today)		25.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)			
88	Fenchugoni CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30	40	GT-1 Under maint.		
89	Fenchugoni CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43	47	GT-4 Under maint.		
90	Fenchugoni 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	51	11	11				
91	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	0	0	0	0	0	163	Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	62	62	62				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
95	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	0	10	84				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	140	140	140				
97	Sylhet 20 MW GTPP	Gas (PDB)	1x20	20	20	18	19	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
99	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0				
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	260	290	300				
101	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	385	367	366	366				
102	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work		
104	Fenchugani 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	47	49	10	10				
Sylhet Zone Total					2472	2427	1384	1431	1391	1475	0	680	
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage		
107	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	43	0	45				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	40	0	86				
109	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	0	18				
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	50	85	50	105				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	68	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	16	16	49				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	8				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0	617	Coal Shortage		
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				150	273	0	0				
**	Bheramara (HVDC)	India	1000	1000	904	859	922	922					
Khulna Zone Total					3005	3001	1188	1341	1088	1233	1027	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	22	19	22				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	176	177	190	190				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1010	1244	1150	1190				
121	Potukhali 150MW PP (UPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	17	35	150				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage		
123	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	217	110	110	110				
Barishal Zone Total					2265	2265	1474	1586	1520	1678	307	0	
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	34				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	10	0	17				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	50	10	95				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	40	15	41				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	50	34	50				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	30	0	34				
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage		
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	193	182	196	200				
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	416	365	415	415				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	21	21				
137	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	95	35	95				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	50	50	50				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0				
Rajshahi Zone Total					2129	2129	871	943	798	1068	601	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	76	77	81	81	8	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250	24	Coal Shortage		
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	38	70	35	85				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	112	115	115				
149	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	29	0	30	0				
	Teesa Solar Limited	Solar (IPP)				142	0	130	0				
Rangpur Zone Total					830	750	575	509	649	531	32	85	
Sub-total: Plants in operation					23078	22700	9231.0	10048	9005	10300	3933	2926	
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Kapzoti 32 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	118	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0	0	0	
Gross Total					23482	22700	9231.0	10048	9005	10300	3933	2926	

(C) Actual data of 25.01.23 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	: 10336 MW, at = 20:00 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 9796 MW, at = 20:00 hrs										
03.	Highest Generation (Generation end)	: 10048 MW, at = 20:00 hrs										
04.	Minimum Generation (Generation end)	: 6996 MW, at = 5:00 hrs										
05.	Day-peak Generation (Generation end)	: 9231 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 10048 MW, at = 20:00 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 265 MW, at = 20:00 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 7101 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
	a) Gas/LF limitation	: 3701 MW										
	b) Coal supply Limitation	: 302 MW										
	c) Low water level in Kaptai lake	: 200 MW										
	d) Plants under shut down/ maintenance	: 2926 MW										
	e) Plants under long term maintenance/ contract expired	: 404 MW										
10.	Total Energy (Generation + India Import)	: 208.21 MCKWh										
	By Gas = 112.241 MCKWh	By Oil = 35.790 MCKWh										
	By Coal = 34.504 MCKWh	By Hydro = 0.734 MCKWh										
	By Solar = 1.780 MCKWh											
11.	Total Gas Supplied	: 845.63 MCKWh										
			12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
			Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
			Dhaka	3552	3447	105	Mymensingh	937	828	109		
			Chattogram	948	948	0	Sylhet	375	375	51		
			Khulna	1124	1124	0	Barishal	283	283	0		
			Rajshahi	1023	1023	0	Rangpur	725	725	0		
			Cumilla	830	830	0						
							Total	9796	9531	265		
			13.	Fuel cost :	(a) Gas = 115519218 Taka	(c) Coal = 282373041 Taka						
					(b) Oil = 451685333 Taka	Total = 849575791 Taka						
			14.	Maximum Temperature in Dhaka was :	28.5° C							
			15.	Export through East-West interconnections :								
				At evening peak-hour	: 9231 MW, at 20:00 hrs							