

POWER GRID COMPANY OF BANGLADESH LTD.									
NATIONAL LOAD DESPATCH CENTER									
DAILY REPORT									
Till now the maximum generation is :-				14782.0		21:00		Hrs on 16-Apr-22	
Reporting Date :				6-Feb-23					
The Summary of Yesterday's				5-Feb-23		Generation & Demand			
Day Peak Generation :		9343.0 MW		Hour :		12:00		Today's Actual Min Gen. & Probable Gen. & Demand	
Evening Peak Generation :		10294.0 MW		Hour :		19:00		Min. Gen. at 5:00	
E.P. Demand (at gen end) :		10465.0 MW		Hour :		19:00		Available Max Generation :	
Maximum Generation :		10294.0 MW		Hour :		19:00		Max Demand (Evening) :	
Total Gen. (MKWH) :		211.4		System Load Factor		85.57%		Load Shed (Generation end)	
								Load Shed :	
								0	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from East grid to West grid :- Maximum				710 MW		at 20:00		Energy	
Import from West grid to East grid :- Maximum				-		-		Energy	
Actual :				Water Level of Kaptai Lake at 6:00 A.M on 6-Feb-23		Rule curve :		96.30 Ft.(MSL)	
82.89				Ft.(MSL) :					
Gas Consumed :				Total = 879.99 MMCFD.		Oil Consumed (PDB) :		HSD :	
								FO :	
Cost of the Consumed Fuel (PDB+Pvt) :				Gas : Tk118,307,041		Oil : Tk392,502,575		Total : Tk807,752,186	
				Coal : Tk296,942,570					
Load Shedding & Other Information									
Area Yesterday Today									
		MW		Estimated Demand (S/S end)		Estimated Shedding (S/S end)		Rates of Shedding (On Estimated Demand)	
				MW		MW			
Dhaka		0 0:00		3266		0		0%	
Chittagong Area		0 0:00		925		0		0%	
Khulna Area		0 0:00		1221		0		0%	
Rajshahi Area		0 0:00		1083		0		0%	
Cumilla Area		0 0:00		922		0		0%	
Mymensingh Area		158 0:00		762		0		0%	
Sylhet Area		0 0:00		341		0		0%	
Barisal Area		0 0:00		278		0		0%	
Rangpur Area		0 0:00		602		0		0%	
Total		158		9400		0		0%	
Information of the Generating Units under shut down.									
Planned Shut- Down Forced Shut- Down									
1) Barapukuria ST: Unit- 2									
2) Ghorasal-3,5,7									
3) Ashuganj-5									
4) Baghabari-70,100 MW									
5) Raozan unit-2									
6) Siddhirganj 210 MW									
7) Shajibazar 330 MW									
8) Sirajganj-1,2									
Outage Restore Additional Information of Machines, lines, Interruption / Forced Load shed etc. Remark									
Time Time									
08:24 13:09 Khulshi-Madunaghat 132kV Ckt-2 Scheduled S/D from Khulshi 132/33kV end Due to Annual Maintenance and from Madunagha 132/33kV end Due to Annual maintenance work.									
08:31 21:24 Aminbazar-Mirpur 132kV Ckt-2 Scheduled S/D from Mirpur 132/33kV end Due to 132kV Line DS Change.									
08:33 13:03 Jhenaidah 230/132kV S/S Jhenaidah2-Jashore Ckt-1 Project Work S/D Due to DFDR testing.									
08:40 16:48 Bibiyana-Fenchuganj 230 kV Ckt-2 Scheduled S/D from Fenchuganj 230/132/33kV end Due to Deadline Cheaking and from Bibiana 400/230kV end Due to Annual maintenance.									
08:44 17:04 Goalpara 132/33kV S/S T-5 LT Scheduled S/D Due to tower painting.									
08:45 17:17 Shahjibazar-Sreemangal 132kV Ckt-2 Scheduled S/D from Shahjibazar 132/33kV end Due to S/D taken by Sreemongal Grid and from Sreemongol 132/33kV end Due to for granty structure painting.									
08:45 17:03 Goalpara 132/33kV S/S T-5 HT Scheduled S/D Due to tower painting.									
09:09 09:09 Khulshi 132/33kV S/S 415T (T2) LT is restored.									
09:12 16:37 Gopalganj-Madhumati 132kV Ckt-1 Scheduled S/D from Gopalganj 132/33kV end Due to Line maintenance.									
09:13 21:24 Mirpur 132/33kV S/S Reserve Bus Scheduled S/D Due to 132 KV Aminbazar Ckt-2 Bypass DS Maintenance.									
09:21 17:30 Jamalpur 132/33kV S/S T-1 LT Scheduled S/D Due to for transformer body colour.									
09:21 17:30 Jamalpur 132/33kV S/S T-1 HT Scheduled S/D Due to For transformer body colour.									
09:22 16:32 Fenchuganj 230/132/33kV S/S TR-01 HT Scheduled S/D Due to Annual maintenance.									
09:24 16:32 Fenchuganj 230/132/33kV S/S TR-01 LT Scheduled S/D Due to Annual maintenance.									
09:28 22:40 Kallyanpur-Lalbag 132kV Ckt-1 Scheduled S/D from Kallyanpur 132/33kV end Due to dead line checking work.									
09:42 14:55 Siddhirganj 132/33kV S/S 120MW EGCB GT1 Scheduled S/D Due to Maintenance work.									
09:50 13:30 Rajshahi 132/33kV S/S -Katakhal 50 MW 132 kV Ckt Scheduled S/D.									
11:29 11:29 Chhatak 132/33kV S/S T-2 LT is restored.									
11:41 11:29 Chhatak 132/33kV S/S T-2 HT is restored.									
12:12 13:20 Bashundhara-Rampura 132 kV Ckt-2 Forced S/D from Rampura 230/132kV end Due to Shutdown by NLDC.									
12:17 12:12 Khulshi 132/33kV S/S 415T (T2) HT is restored.									
13:10 12:17 Shahjibazar 132/33kV S/S SPCL 86 MW is restored.									
18:24 13:32 Jhenaidah 230/132kV S/S Jhenaidah (New)-Jhenaidah (Old) Ckt-1 Project Work S/D Due to DFDR testing.									
13:32 13:32 Barishal 132/33kV S/S T-1 (405T) HT is restored.									
13:33 13:33 Barishal 132/33kV S/S T-1 (405T) LT is restored.									
14:46 14:46 Kabirpur-Kaliakoir 132kV Ckt-1 is restored.									
15:05 14:58 Gopalganj-Rampal 400 kV Ckt-1 was closed from both end.									
15:21 15:21 Kishoreganj-Mymensingh 132kV Ckt-1 Forced S/D from Mymensingh 132/33kV end Due to Tree trimming.									
15:13 15:13 Bheramara(GK) 132/33kV S/S TR-3 HT is restored.									
15:20 15:20 Bheramara(GK) 132/33kV S/S TR-3 LT is restored.									
15:28 15:28 Bheramara-GK 132kV Ckt-1 is restored.									
17:22 17:22 Sherpur(Bogura)-Sirajganj 132 kV Ckt-1 is restored.									
17:23 17:23 Sirajganj 132/33kV S/S Sherpur-1 is restored.									
21:50 21:50 Aminbazar 400/230/132kV S/S 230/132kv Tr-01 HT is restored.									
21:51 21:51 Aminbazar 400/230/132kV S/S 230/132kv Tr-01 LT is restored.									
01:25 01:25 Meghnaghat CAPP 450MW GT-1 was sync.									
06:05 06:05 Meghnaghat CAPP 450MW ST was sync.									
07:29 Kabirpur-Kaliakoir 132kV Ckt-2 Scheduled S/D from Kabirpur 132/33kV end Due to Annual maintenance and from Kaliakoir 400/230/132kV end Due to Annual maintenance.									
07:30 07:40 Dhamrai 132/33kV S/S Transformer-2 LT Tripped Due to PBS Dhamrai, Radio, Nabinogor-1, Basic feeder tripping.									
07:30 07:40 Dhamrai 132/33kV S/S Transformer-1 LT Tripped Due to PBS Dhamrai, Radio, Nabinogor-1, Basic feeder tripping.									
07:34 Sirajganj 132/33kV S/S Sherpur-2 S/D Due to project work.									
07:40 Faridpur 132/33kV S/S Transformer-2 HT sheduled shut down due to Project Work.									
07:40 Faridpur 132/33kV S/S Transformer-2 LT sheduled shut down due to Project Work.									
07:47 Bhandaria 132/33kV S/S Transformer-1 LT Scheduled S/D Due to 33 kv WZPDCL Bhandaria CB and DS Installation work.									
07:48 Bhandaria 132/33kV S/S Transformer-1 HT Scheduled S/D Due to 33 KV WZPDCL Bhandaria CB and DS installation work.									
07:50 Faridpur 132/33kV S/S 33 KV Bus shut down due to scheduled shut down.									
Sub Divisional Engineer Network Operation Division			Executive Engineer Network Operation Division			Superintendent Engineer Load Despatch Circle			