POWER GRID COMPANY OF BANGLADESH LTD NATIONAL LOAD DESPATCH CENTER DAILY REPORT 19-Apr-23 Reporting Date Till now the maximum generation is : -The Summary of Yesterday's Day Peak Generation 15304.0 Generation & Demand 13307.0 MW Hour: 12:00 15826.0 MW Hour: 21:00 15826.0 MW Hour: 21:00 15826.0 MW Hour: 21:00 15826.0 MW Hour: 21:00 15828.0 MW System Load Factor 90.08% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 21:00 Hrs on 13-Apr-23 Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at 7:00 Available Max Generation Max Demand (Evening): Reserve(Generation end) Load Shed 12354 15948 15500 448 Evening Peak Generation E.P. Demand (at gen end) Maximum Generation Total Gen. (MKWH) Total Gen. (MKWrs) Export from East grid to West grid - Maximum Import from West grid to East grid - Maximum Water Level of Kaptai Lake at 6:00 A M on Achial : 75.77 20:00 MW Ft.(MSL) 84.40 Ft.(MSL) Gas Consumed : Total = 1174.57 MMCFD. Oil Consumed (PDB): HSD : FO : Cost of the Consumed Fuel (PDB+Pvt) Tk172.690.022 Coal Tk311,027,386 Oil : Tk1,436,626,785 Total : Tk1,920,344,193 Load Shedding & Other Information Today Estimated Shedding (S/S end) MW Area Rates of Shedding (On Estimated Demand) 0% 0% 0% 0% 0% 0% 0% 0% 0% Estimated Demand (S/S end) Dhaka Chittagong Area Khulna Area Rajshahi Area Cumilla Area Mymensingh Area Sylhet Area Barisal Area 0:00 0:00 0:00 0:00 0:00 0:00 0:00 Rangpur Area Total 0:00 Information of the Generating Units under shut down Forced Shut- Down 1) Barapukuria ST: Unit- 1,2 2) Ghorasal-3 3) Bhula Nuton Biddut 4) Baghabari-100 MW & 71 MW 5) Raozan unit-2 6) Siddhirganj 210 MW . 7) Shajibazar 330 MW 9) Stragonia 3 Planned Shut- Down 8) Sirajganj- 3 9) Barishal 307 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc. Remark Outage A-former Comissioning Effect. Chattak-Sylhet 132 kV Ckt-1 Scheduled S/D from Chhatak 132/33kV end Due to Sylhet-chhatak Ckt-1 CB replace work. and from Sylhet 132/33kV end Due to work of chhatak end Jamalpur 132/33kV S/S T-2 LT is restored. 08:23 22:12 08:37 08:37 09:02 09:02 10:48 10:49 13:43 Jamalpur 132/33kV SiS T-2 LT is restored. Jamalpur 132/33kV SiS T-2 HT is restored. Jhenaidah 132/33kV SiS T-3 HT is restored. Jhenaidah 132/33kV SiS T-14/60T) HT Scheduled SID Due to 33kV CT High Junction Temperature Chapai 132/33kV SiS T-1 (405T) HT Scheduled SID Due to 33kV CT High Junction Temperature Chapai 132/33kV SiS T-1 (405T) HT Scheduled SID Due to Same Aminhazar 400/23/0132kV SiS 132 kv Bus 01 Forced SID Due to Cable loop repairung of 132 kv side of 400/132 kv Transformer. Aminbazar 400/2301132kV SIS-132 kv Bus 01 Forced SID Due to Cable loop repairung of 132 kv side of 400/132 kv transforner Shikalabha 230/132kV SIS Interconnection-1 is restored. Interval 12/13kV SIS Interconnection-1 is restored. Interval 12/13kV SIS-13k Bus-2 Scheduled SID Due to Red hot Maintenance Chauddagram 132/33kV SIS-13k Bus-2 Scheduled SID Due to 33 kv Bus-01 red hot Day peak Generation: 13907 MW Ioda shed about 104d MW Chauddagram 132/33kV SIS-13k Bus-11 LT Forced SID Due to 33 kv Bus-01 Red Hot. Barisha 220/132kV SIS-14 LT is restored. Barisha 230/132kV SIS-14 LT is restored. Barisha 230/132kV SIS-14 LT is restored. Sreemongol 132/33kV SIS-132/33kV 7-3 LT is restored. Sreemongol 132/33kV SIS-12/33kV 7-3 LT is restored. Kallynapur 132/33kV SIS-12/13kV 7-1 LT is restored. Kallynapur 132/33kV SIS-12/33kV SIS-12/33kV 7-1 LT is restored. Kallynapur 132/33kV SIS-12/33kV SIS-12/34kV SIS-12/33kV SIS-12/34kV SIS-12 10:42 12:51 13:03 11:02 12:00 12:00 12:01 20.0MW load interrup. 13:03 12:51 12:53 20.0MW load interrup. 14:10 14:30 14:30 15:25 15:15 15:19 19:06 21:00 21:05 07:38 14.0MW load interrup. 23:11 23:14 23:59 23:56 45.0MW load interrup. 45.0MW load interrup. orial places in 32.55 km 3.5 if R-9 HT Public 3rD bitle to IR-94 33 km state bits stratulowin use at inologicity out rescent red in orial international residence in the maintenance. Rampal PS Synchronize. Minimum generation 12354MW Sirajagan 132/33kV SS 12-4(25) LT Forced SiD Due to Red Hot has become visible/measured at 33kV 72+73 connecting bits isolator, all operation has been conducted by the instruction of ALDC, Bogura with the permission of NLDC Dhaka. Baroaulia-Hathazari 132 kV Ckt-1 Forced SiD from Baroaulia 132/33kV end Due to Red Hot in Line Isolator. 02:06 07:00 07:05 07:30 25.0MW load interrup 07:10 40.0MW load interrup. Chattak-Sylhet 132 kV Ckt-1 Scheduled S/D from Chhatak 132/33kV end Due to New Breaker Replacement and from Sylhet 132/33kV end Due to Maintenance for Chhatak SS end.