POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT 21:00 Hrs on 19-Apr-23 Today's Actual Min Gen. 8 Probable Gen. 8 Demand Min. Gen. 4 Probable Gen. 8 Demand Min. Gen. 4 Probable Gen. 8 Demand Min. Gen. 6 Probable Gen. 8:00 Available Max Generation Max Demand (Evening): Reserve(Generation end) Load Shed Till now the maximum generation is : The Summary of Yesterday's Day Peak Generation : Evening Peak Generation : E.P. Demand (at gen end) : Maximum Generation : Total Gen. (MKWH) : 15648.0 Generation & Demand 7917.0 MW 10301.0 MW 10301.0 MW 11257.0 MW Hour Hour Hour Hour 12:00 21:00 21:00 1:00 81.36% 7955 14413 10500 3913 0 Export from East grid to West grid :- Maximum Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M on 29-Jun-23 Ft.(MSL) 74.03 Rule curve : 83.86 Ft.(MSL) Total = Gas Consumed : 1031.48 MMCFD. Oil Consumed (PDB): Cost of the Consumed Fuel (PDB+Pvt) : Tk151,297,906 Tk92,284,339 Total : Tk462,031,219 Oil : Tk218,448,974 Load Shedding & Other Information Today Estimated Shedding (S/S end) MW Area Rates of Shedding (On Estimated Dema Estimated Demand (S/S end) MW 5084 1400 1962 1706 1404 1044 585 488 954 Dhaka Chittagong Area Khulna Area Rajshahi Area Cumilla Area Mymensingh Area Sylhet Area Barisal Area 0:00 0:00 0:00 0:00 0:00 0:00 0:00 0% 0% 0% 0% 0% 0% 0%

Information of the Generating Units under shut down.

Planned	Shut-	Down	

Forced Shut- Down

1) Barapukuria ST: Unit- 2

2) Ghorasal-3,5,7

3) Bhula Nuton Biddut ST

4) Baghabari-71,100 MW

5) Raozan unit-2

6) Siddhirganj 210 MW

7) Shajibazar 330 MW

8) Bibiyana-3

Outage	Restore	Additional Information of Machines, lines, Interruption / Forced Load shed etc.	Remark
Time	Time		
08:32	16:11	Bheramara P/S-Kustia 132 kV Ckt-1 Scheduled S/D from Bheramara 230/132kV end Due to Kushtia 132 kv s/s DC fail.	
08:35		Sikalbaha Gas 225MW ST tripped	
	08:37	Rampal 400/230kV S/S 400KV Bus-2 is restored.	
08:44	16:08	Bheramara P/S-Kustia 132 kV Ckt-1 Forced S/D from Kushtia 132/33kV end Due to DC System fault.	
	09:32	Mongla 132/33kV S/S T-2 HT is restored.	
09:32		Sikalbaha Gas 225MW GT tripped	
	09:33	Mongla 132/33kV S/S T-2 LT is restored.	
09:40	16:40	Thakurqaon 132/33kV S/S 432T HT Tripped showing Tripping Relay relays Due to OTI problem end Due to Breaker open.	
09:51		Natore 132/33kV S/S TR-4 (435 T) HT Tripped showing 86 lockout T-4B relays Due to Bucholz trip.	
10:55	12:19	Chowmuhani-Feni 132 KV Ckt-1 Tripped from Chowmuhani 132/33KV end showing E/F Relay (t) relays, and from Feni	
		132/33kV end showing distance relay(phase-c), auto reclose relay relays Due to under construction buildings bamboo	20 MW load interrup
		near lower conductor	Chowmuhoni 132/33 kV end.
		ried lower conductor.	42 MW load interrup
			Feni 132/33 kV end.
	11:18	Sikalbaha Gas 225MW GT was svnc.	I dili 132/33 kV dila.
11:25	12:18	Sikaliona uas ZZSMW u1 was syric. Chauddagram-Feni 132 kV Ckt-2 Tripped from Feni 132/33kV end showing distance relay.	71 MW load interrup
11.23	12.10	Chauddagram-Feni 132 kV Ckt-2 1 ripped from Feni 132/33kV end snowing distance relay.	Feni 132/33 kV end.
			20 MW load interrup
			Chowmuhoni 132/33 kV end
			Cnowmunoni 132/33 kV end.
		L	
11:27	12:20	Chowmuhani-Feni 132 kV Ckt-1 Tripped from Chowmuhani 132/33kV end showing E/F Relay.	
	11:40	Bashkhali (SS Power) unit-2 was sync.	
11:40	12:17	Chowmuhani-Feni 132 kV Ckt-2 Forced S/D from Chowmuhani 132/33kV end Due to Remove Bamboo.	20 MW load interrup
		• · · · · · · · · · · · · · · · · · · ·	Chowmuhoni 132/33 kV end.
12:45		Siddhirganj GT-2 was shutdown.	
13:44		Siddirganj CCPP 335MW tripped	
17:43	18:20	Goalpara 132/33kV S/S T-5 LT Forced S/D Due to fuse change of 33 kV Bus PT.	
17:43	18:19	Goalpara 132/33kV S/S T-5 HT Forced S/D Due to fuse change of 33 kV Bus PT.	
17:45	18:17	Goalpara 132/33kV S/S T-6 LT Forced S/D Due to fuse change of 33 kV Bus PT.	
17:45	18:16	Goalpara 132/33kV S/S T-6 HT Forced S/D Due tofuse change of 33 kV Bus PT.	
	19:01	Bhola Natun Biddut BD LTD (GAS) GT11 was sync.	
19:24		SS Power (Unit-2) was shutdown.	
	20:11	Siddhirganj CCPP 335MW GT was sync.	
	21:22	Siddhirganj CCPP 335MW ST was sync.	
22:28	23:15	Sherpur 132/33kV S/S Transformer- 02 HT Forced S/D Due to Red Hot 33kV Bus.	18 MW load interrup.
22:28	23:16	Sherpur 132/33kV S/S Transformer- 02 LT Forced S/D Due to Red Hot 33kV Bus.	
23:26		Madanganj 132/33kV S/S Madanganj -Summit 102 MW 132 kv Ckt Forced S/D Due to Requested by Summit 102MW PP	
		Authority & NLDC.	
23:59		Aggreko-keraniganj 132kV Ckt-1 Scheduled S/D from Keranigonj 230/132/33kV end Due to Breaker open with NLDC	
		instruction.contact period end with govt and Aggreko.	
00:06		Hasnabad 132/33kV S/S Aggreko Aourahati Scheduled S/D Due to Instruction of NLDC due to LILO disconnect of Aggreko	
		100MW PP (Contract over)	
01:47		Sirajganj 132/33kV S/S T1-(415) LT Forced S/D Due to Red Hot has become visible at 33kV CB B-phase of 132/33kV	
	1	TR-01 at 33kV BUS side, informed to station in charge.	
03:04	1	Sikalbaha Gas 225MW ST tripped.	75 MW generation interrup.
03:26	1	Sirajgonj Gas 210MW Unit-1 tripped due to GBC trip.	130 MW generation interrup.
07:22	1	Haripur-Sonargaon 132kV Ckt-1 Tripped from Haripur 230/132kV end showing Distance Zone-1, ABN relays Due to rain.	
07:25	1	Daudkandi-Sonarqaon 132 kV Ckt-1 Tripped from Daudkandi 132/33kV end showing Distance trip relay relays Due to	
	1	Windy weather.	
	1	·····, ··	
	1		