POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT												
Till now the maximum go	eneration is · -		15648.0				21:0	00 Hrs on	19-Apr-23	Reporting Date :	5-Aug-23	
The Summary of Yesterd	ay's	4-Aug	-23 Generation &	Demand				Today's Actual Min Gen. &		Demand		
Day Peak Generation : Evening Peak Generation :			11626.0 MW 13395.0 MW	Hour : Hour :	12	2:00 1:00		Min. Gen. at Available Max Generation		7:00		11130 14855
E.P. Demand (at gen end) :			13395.0 MW	Hour :	2	1:00		Max Demand (Evening) :	:			14855
Maximum Generation :			13554.0 MW	Hour :		3:00		Reserve(Generation end)				355
Total Gen. (MKWH) :			285.30	System Loc RT THROUGH EAST-WEST IN	ad Factor : 87	7.71%		Load Shed :				0
Export from East grid to Wes	t grid :- Maximum		EXPORT / IMPOR	(I IHROUGH EASI-WESI IN	630 M	(W	at	19:30		Energy		
Import from West grid to Eas	t grid :- Maximum			=	M	/W	at	•		Energy		-
Actual :	Water Le	evel of Kaptai Lake at 6:00 A M on 80.57 Ft.(MSL),	5-Aug-23		Rule curve :	ar	0.28	Ft.(MSL)				
Gas Consumed :		Total =	1125.55 MMCFD.		0	il Consu	med (PD	DB):	HOD			
									HSD : FO :			
Cost of the Consumed Fuel (PDB+PVt):		Gas : Coal :	Tk160,820,777 Tk295,618,435			Oil	: Tk622,090,837		Total : Tk	,078,530,049	
				, ,				,,,,,,,			, , , , , , , , , , , , , , , , , , , ,	
		Load Sheddin	g & Other Information									
Area		Yesterday		Estimated Demand (S/S end)				Today Estimated Shedding (S/S end			ates of Shedding	
		MW		Estimated Demand (S/S end) MW				Estimated Shedding (S/S end	MW		ates of Shedding Estimated Demand)
Dhaka		0 0:0	0	4955					MIVV	0	0%	
Chittagong Area		0 0:0	0	1364						0	0%	
Khulna Area Rajshahi Area		0 0:00 0 0:00		1911 1662						0	0% 0%	
Cumilla Area		0 0:0	ת ח	1367						0	0%	
Mymensingh Area		0 0:0	Ď	1017						ō	0%	
Sylhet Area		0 0:0		570						0	0%	
Barisal Area		0 0:0		475						0	0%	
Rangpur Area Total		0 0:0)	929 14249						0	0%	
1041				14240								
		Information of the Generating Units under	shut down.									
		Planned Shut- Down			F	orced S	Shut- Dov	vn_				
					1)) Barapul	kuria ST:	Unit- 1,2				
					(2)) Ghoras	ial-3,/	mar.				
3) Shajibazar 371,100 MW 4) Bagathazar 371,100 MW												
					5)) Raozan	n unit-2					
					6)) Siddhire	ganj 210	MW .				
					7)) Shajiba	azar-9					
Outage	Restore	Additional Information of Ma	chines, lines, Interruption	/ Forced Load shed etc.								Remark
Time 08:04	Time 08:39	Halishahar 132/33kV S/S 403T/TR-1) LT Trippe	d showing Over Current rela	vs Due to Due to 33 kv Baraka ckt	t-01 fault				+	2.5	MW load interrup.	
08:04	08:39	Halishahar 132/33kV S/S 403T(TR-1) LT Trippe Halishahar 132/33kV S/S 413T(TR-2) LT Trippe	d showing Over Current rela	ys Due to Due to 33 kv Baraka ckl	t-01 fault							
09:04	11:05	Satkhira 132/33kV S/S Transformer-2 (T-2) LT S Satkhira 132/33kV S/S Transformer-2 (T-2) HT	Scheduled S/D Due to Red h	ot maintenance						25	MW load interrup.	
09:05 09:15	11:04	Satkhira 132/33kV S/S Transformer-2 (T-2) HT : Matarbari coal power Unit-1 was sync.	Scheduled S/D Due to Red I	ot maintenance								
09:37	17:47	Gopalganj 400/132kV S/S ATR-03 LT Schedule	d S/D Due to Fire fighting w	nrk								
09:38	17:42	Gopalgani 400/132kV S/S ATR-03 HT Schedule	ed S/D Due to Fire fighting w	ork								
10:01	12:35	Ishurdi 132/33kV S/S 132/33 kV T-2 LT Schedu	led S/D Due to station auxila	ri x-former maintenance work								
10:01	12:35	Ishurdi 132/33kV S/S 132/33 kV T-2 HT Schedu		ari x-former maintenance work								
	10:12 10:14	Agargaon 230/132kV S/S 230kV Transformer-1 Agargaon 230/132kV S/S 230kV Transformer-1	(705T1) HT is restored.									
10:19		Sylhet CCPP 225 MW ST was sync. Faridpur 132/33kV S/S Transformer-2 HT is rest	(
	10:37	Faridpur 132/33kV S/S Transformer-2 HT is resi	tored.						1			
12:00	10:38	Faridpur 132/33kV S/S Transformer-2 LT is rest Day peak generation: 11627 MW.	ored.									
12:00		Siddhirgani GT: Unit-1 was shutdown due to hy	draulic oil leakage							106	MW generation inte	writin
15:33	17:21	Bogura 132/33kV S/S Transformer-1 LT Schedu	iled S/D Due to 33kv nesco	vork							/IWV generation inte //W load interrup.	шир.
15:33	17:21	Bogura 132/33kV S/S Transformer-1 HT Schedi	uled S/D Due to 33kv nesco	work					1			
15:59	16:02	Shahjibazar 132/33kV S/S TR-02 LT Tripped sh	owing O/C, E/F relay 33 kv.	C phase Inst. relays Due to due to	PBS				1			
16:09	17:39	33kv Chunarughat feeder trip showing E/F Cumilla(S) 132/33kV S/S TR-2 LT Scheduled S	/D Due to PDP token S/D for	Work					1	20	MW load interrup.	
16:10	17:39	Cumilla(S) 132/33kV S/S TR-2 LT Scheduled S Cumilla(S) 132/33kV S/S TR-2 HT Scheduled S							1	20	···· roau miterrup.	
	17:42	Gopalgani 400/132kV S/S ATR-03 HT is restore	d.									
19:21		Bogura(New)-Bogura(Sherpur) 132 kV Ckt-2 Fo	rced S/D from Bogura 230/1	32kV end Due to Transformer Ove	erload.							
19:56		Siddhirganj GT-1 was sync.										
21:00 01:17		Evening Peak Gen. 13395 MW Bogura West 430/230 KV ATR-1 S/D							1			
01:29		Bogura West 430/230 KV ATR-1 Sync							1			
05:40	07:04	Sylhet 132/33kV S/S T1 LT Scheduled S/D Due	to Red hot Maintenance						1			
05:40 05:41	07:04 07:03	Sylhet 132/33kV S/S T1 LT Scheduled S/D Due Sylhet 132/33kV S/S T1 HT Scheduled S/D Due	to Red hot Maintenance	to CD /22 KV/ DSV Dbor - '					1			
05:41 06:10	07:03	Mymensingh 132/33kV S/S T1 HT Scheduled S/D Dui Mymensingh 132/33kV S/S Transformer-2 (414)	T) LT Scheduled S/D Due to	S/D due to Red bot maintenance	work				1			
		for 33kV Gafagaon Feeders 33kV Bus DS(R-Ph)	upper clamp						1			
06:10		Mymensingh 132/33kV S/S Transformer-2 (414)	 T) HT Scheduled S/D Due to 	S/D due to Red hot maintenance	work				1	85	MW load interrup.	
06:51		for 33kV Gafagaon Feeders 33kV Bus DS(R-Ph Tangail 132/33kV S/S Tr-4 LT Scheduled S/D D	i) upper clamp.						1	10	MW load interrup.	
06:51		Tangail 132/33kV S/S Tr-4 LT Scheduled S/D L	Due to 33ky T2 bus red hot						1	10	vivv idad interrup.	
06:51		Chapainawabganj-Rahanpur 132kV Ckt-1 Scheo	duled S/D from Chapai 132/3	3kV end Due to Project work								
06:57		Tangail 132/33kV S/S Tr-2 HT Scheduled S/D I	Due to 33ky T2 bus red hot						1	40	MW load interrup.	
06:57 07:00		Tangail 132/33kV S/S Tr-2 LT Scheduled S/D E Minimum generation 11130 MW	ue to 33kv T2 bus red hot						1			
07:00		willimum generation 11130 MVV							1			
		1										
'	Sub Divisional Engin						itive Engi		•		Superintendent Er	
	Network Operation Divis	sion			N-	letwork (Operation	n Division			Load Despatch (Circle