	POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DALLY REPORT												
ow the maximum generation is The Summary of Yesterday's	s:-		15648.0				21:	00 Hrs on	19-Apr-23	eporting Date :	19-Sep-23		
The Summary of Yesterday's Day Peak Generation :		18-Sep-	23 Generation & D 12998.0 MW	lemand Hour :		12:00		Today's Actual Min Gen. & Prol Min Gen. at	able Gen. & De	mand :00		10881	
Evening Peak Generation :			14465.0 MW	Hour :		19:30		Available Max Generation	:			15935	
E.P. Demand (at gen end) : Maximum Generation :			14650.0 MW 14465.0 MW	Hour : Hour :		19:30 19:30		Max Demand (Evening) : Reserve(Generation end)				14900 1035	
Total Gen. (MKWH) :			311.737	System Loa	d Factor	; 89.80%		Load Shed :				0	
from East grid to West grid :- Max	-		EXPORT / IMPOR	T THROUGH EAST-WEST INT	ERCONNECT		at	20:00		Energy			
from West grid to East grid :- Max	kimum				010	MW	at	-		Energy			
Actual :	Water Lev	el of Kaptai Lake at 6:00 A M on 108.19 Ft.(MSL),	19-Sep-23		Rule curve	. 10	02.91	Ft.(MSL)					
Actual :		106.19 FL(MBL),			Rule curve	. 1	JZ.91	FL(MOL)					
Gas Consumed :		Total =	1147.90 MMCFD.			Oil Consi	umed (PD	0B):					
									HSD : FO :				
(H 0 15 1000 0 0				TI 400 707 000									
of the Consumed Fuel (PDB+Pvt) : :			Gas : Coal :	Tk162,707,982 Tk580,698,874			Oil	: Tk589,617,453		Total : Tk1,33	3.024.309		
							-						
		Load Shedding & Of	her Information										
Area		Yesterday						Today					
		MW		Estimated Demand (S/S end) MW				Estimated Shedding (S/S end)	MW		s of Shedding stimated Demand)		
Dhaka		0:00		5149						0	0%		
Chittagong Area		0 0:00		1418						0	0%		
Khulna Area Rajshahi Area		0 0:00 0 0:00		1988 1729						0	0% 0%		
Cumilla Area		25 0:00		1422						0	0%		
Mymensingh Area Sylhet Area		122 0:00 30 0:00		1058 592						0	0% 0%		
Barisal Area		0 0:00		494						0	0%		
Rangpur Area		0 0:00		967						0	0%		
Total		177		14816						0			
		Information of the Generating Units under shu	t down.										
		Planned Shut- Down				Forced	Shut- Dov	vn					
		Fiamed Shue Down				1) Barapu	ukuria ST:	Unit- 1,2					
						2) Ghora	sal-3,7 azar 330 I						
							azar 330 f bari-71,10						
						5) Raoza	n unit-2						
						6) Siddhii	rganj 210	MW .					
0.000	B1	Additional Information of Machin	on lines Interruption / Forsed	Load shad ats								Remark	
Outage Time	Restore Time		ies, mes, menuption / roiced	Load siled etc.								Remark	
00.45	08:02	Sylhet 132/33kV S/S T4 LT is restored.	0.										
08:15 08:15	08:25 08:25	Sreemongol 132/33kV S/S 132/33kv T-3 LT Forced Sreemongol 132/33kV S/S 132/33kv T-3 HT Forced	S/D Due to 33kv Gas Refill Work S/D Due to 33kv Gas Refill Work	c. k									
08:22	10:14	Joydebpur 132/33kV S/S GT-3 HT Scheduled S/D E											
	08:23 08:25	Narshingdi 132/33kV S/S T-1 HT is restored. Narshingdi 132/33kV S/S T-1 LT is restored.											
09:20	17:34	Madaripur 132/33kV S/S T2-415T HT Scheduled S/	D Due to Red Hot of 33 kv feeder	r (Agoljhora)									
		source side D/S B-phase											
09:21	17:35	Madaripur 132/33kV S/S T2-415T LT Scheduled S/I B -phase 33KV Agailjhara Feeder Barishal PBS-2	D Due to Red Hot maintenance s	ource DS					17.0MW load	d interruption.			
09:31	11:03	Cumilla(S) 132/33kV S/S TR-4 LT Scheduled S/D E	ue to T-4 Bus Red hot (PDB Fee	eder)					10.0MW load	d interruption.			
09:31	11:03	Cumilla(S) 132/33kV S/S TR-4 HT Scheduled S/D E	Due to same										
09:53	14:42	Rampur 230/132/33 S/S Khulshi-1 Scheduled S/D E point at mono pole.											
09:54	13:40	Halishahar-Khulshi 132kV Ckt-1 Forced S/D from H	(hulshi 132/33kV end Due to Red	l hot									
10:05 10:12	15:50	Bashundhara-Tongi 132 kV Ckt-1 Scheduled S/D fm Meghnaghat Summit CCPP 305MW GT-1 was sync	om Tongi 230/132/33kV end Due	to Tree trimming.									
11:45		Bheramara(GK) 132/33kV S/S TR-2 LT Scheduled	S/D Due to 132/33kv Tr-2 Oil Cer	ntrifuging Work.									
11:46 12:00		Bheramara(GK) 132/33kV S/S TR-2 HT Scheduled Day peak generation 12998 MW.	S/D Due to 132/33kv Tr-2 Oil Cer	ntrifuging Work.									
12:54	23:02	Rampur 230/132/33 S/S Halishahar-1 Forced S/D											
	14:27	Sirajganj 132/33kV S/S Sherpur-1 is restored.											
14:35	14:28 14:45	Sherpur(Bogura)-Sirajgonj 132 kV Ckt-1 is restored Purbasadipur 132/33kV S/S T-3 Transformer (423T) I T Tripped showing O/C & E/E/	(50 & 50N) relays									
1		Due to Fokirpaera 33Kv Feeder LA Blust											
14:35	15:05	Purbasadipur 132/33kV S/S T-1 Transformer (403T Directional E/E relay tripped), relays Due to fakings	Purbasadipur 132/33kV S/S T-1 Transformer (403T) HT Tripped showing Lockout (For 33Kv side Directional E/F relay tripped) relays Due to fokirpara 33Kv Feeder LA Blust										
14:35	15:05	Purbasadipur 132/33kV S/S T-1 Transformer (403T) LT Tripped showing E/F (50 &6	i7) relays Due					1				
1 1		to Fokirpara 33kv side Feeder LA Blust.rain and thu	undaring in this area.						20.01.01.1	d indu an orbit			
14:40	17:22	Shyampur-Shyampur(New) 132kV Ckt-2 Tripped fro relay. relays Due to Tripped due to external materia	ils.						39.0MW load	d interruption.			
14:44	23:00	Halishahar-Khulshi 132kV Ckt-2 Forced S/D from H	Khulshi 132/33kV end Due to Red	l hot					1				
14:55	23:00	Rampur 230/132/33 S/S Khulshi-2 Scheduled S/D							1				
15:06	17:53	Madanganj 132/33kV S/S Madanganj-Fatullah 132K	V Ckt Forced S/D										
15:08	17:52	Fatullah-Madangani 132 kV Ckt-2 Forced S/D from	Fatullah 132/33kV end.										
15:11 16:30	00:46	Summit meghnaghat-2 589 MW PP GT was sync.	Current relays Due to Over Load										
16:35	17:05	Sylhet 132/33kV S/S T4 LT Tripped showing Over C Shyampur-Shyampur(New) 132kV Ckt-1 Tripped fro	m Shyampur 230/132kV end sho	wing Supervision					71.0MW load	d interruption.			
		relay relays Due to Above circuit tripped only from S Due to LA brust in Transformer -2 Bay of Shyampu	Shyampur (old) substation end.										
18:28		Rampal 1320 MW (BIFPCL) unit-1 was sync.	r (old) substation.										
	18:28	Rampal 400/230kV S/S Generator Transformer-1 (0	GT-1) LT is restored.										
19:30	18:28	Rampal 400/230kV S/S Generator Transformer-1 (Evening Peak Gen. 14466 MW	GT-1) HT is restored.										
21:19		Unique Meghnaghat Power 584 MW CCPP GT was											
21:36	23:45	Narshingdi 132/33kV S/S T-3 LT Scheduled S/D Du	ie to ≋-∞,						30.0MW load	d interruption.			
21:37	23:44	তৎকটি ইনকামিং গাইন ডি:গ মটপাটন মেইবেঁনেশ I Narshingdi 132/33kV S/S T-3 HT Scheduled S/D Du	ue to 10-∞,						1				
1		৬৬কেডি ইনকামিং লাইন ডিওস হটস্পটস মেইন্টেলেন্স							1				
22:03 22:03		Mirpur 132/33kV S/S T1 LT Forced S/D Due to 132/ Mirpur 132/33kV S/S T1 HT Forced S/D Due to 132	33KV T-1 Transformer CB Hydra /33KV/ T-1 Transformer CB Hydra	aulic pressure low.					1				
22:03		Mirpur 132/33kV S/S T1 LT Forced S/D Due to 132	V T-1 Transformer CB Hydraulic	c pressure low.					1				
22:37 22:37	23:55 23:55	Tangail 132/33kV S/S Tr-2 HT Forced S/D Due to F	ted hot at 33kv kachuadanga feed	der (BPDB)					130.0MW loa	ad interruption.			
22:37 07:00	∠3:55	Tangail 132/33kV S/S Tr-2 LT Forced S/D Due to R Minimum generation 10918 MW	eu not at 33kv kachuadanga feed	(0°00)					1				
07:05		Rangpur 132/33kV S/S T-2 (404T) LT Forced S/D E							90.0MW load	f interruption.			
07:05 07:07		Rangpur 132/33kV S/S T-1(414T) LT Forced S/D D Rangpur 132/33kV S/S T-1(414T) HT Forced S/D D	ue to 33kv Dharsana feeder bus I	DS red hot					1				
07:07		Rangpur 132/33kV S/S T-1(4141) HT Forced S/D L Rangpur 132/33kV S/S T-2 (404T) HT Forced S/D L							1				
		1							1				
									1				
									1				
	Sub Divisional Eng						tive Engi				Superintendent Engine Load Despatch Circle	er	
Network Operation Division					Network Operation Division						Load Despatch CIPCIE		