

AL LOAD DESPATCH CENTER
DAILY REPORT

30-Sep-23

Today's Actual Min Gen. & Probable Gen. & Demand

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR						
m East grid to West grid :- Maximum	690	MW	at	18:30		Energy
m West grid to East grid :- Maximum	-	MW	at	-		Energy

Gas Consumed :	Total =	1062.02 MMCFD.	Oil Consumed (PDB) :	1000
----------------	---------	----------------	----------------------	------

Gas :	Tk153,249,977		
Coal :	Tk685,853,535	Oil : Tk372,174,491	Total : Tk1,211,278,003

Load Shedding & Other Information

Information of the Generating Units under shut down.

Information of the Generating Units under shut down

Forced Shut-Down

- 1) Barapukuria ST: Unit- 1,2
- 2) Ghorasal-3,7
- 3) Shajibazar 330 MW
- 4) Baghabari-71,100 MW
- 5) Raozan unit-2
- 6) Siddhirganj 210 MW .

Time	Time	
------	------	--

08:41	08:05	Rangpur 132/33kV S/S T-1(414T) HT is restored.	
	08:05	Rangpur 132/33kV S/S T-2 (404T) HT is restored.	
	16:27	Tangail 132/33kV S/S Kaliakair-2 Project Work S/D.	90 MW load interrup.
	09:02	Keranigonj 230/132/33kV S/S Lalbagh-3 is restored.	
	09:06	Sylhet 132/33kV S/S T4 LT is restored.	
	09:42	Feni 132/33kV S/S T-1(405T) LT is restored.	
09:51	09:42	Feni 132/33kV S/S T-1(405T) HT is restored.	
	16:21	Siddhirganj 230/132kV S/S 335MMV EGCB 2 Scheduled S/D Due to ST Transformer schedule check for EGCB end.	
	10:06	Keranigonj 230/132/33kV S/S Earthing Trafo-1 HT is restored.	
	10:07	Keranigonj 230/132/33kV S/S Earthing Trafo-1 LT is restored.	
	10:37	Ashuganj 230/132/33kV S/S 132 kv Busbar-2 is restored.	
10:50	12:07	Baghabari PS --Ishurdi 132 KV ckt Trip [Baghabari PS END], SF-6 Gas Pressure Low. No Signal in Relay Panel.	
	10:57	Ashuganj 230/132/33kV S/S TR-OAT-12 LT is restored.	
	10:58	Ashuganj 230/132/33kV S/S TR-OAT-12 HT is restored.	
11:07	11:20	Feni-PHP 132kV Ckt-1 Tripped from Feni 132/33kV end showing Distance RelayPower swing B,C,Z2 relays.	
11:37	12:26	Sreepur 230/132/33kV S/S 132/33 kV T-1 LT Tripped showing Master Relay operate. relays.	
12:23	13:21	Madunaghat 132/33kV S/S TR-1(507T) LT Forced S/D Due to Emergency Red hot maintenance work by BPDB	42 MW load interrup.
	14:01	Sirajganj 132/33kV S/S T4-(445) LT is restored.	
	14:01	Sirajganj 132/33kV S/S T4-(445) HT is restored.	
	14:01	Sirajganj 132/33kV S/S T3-(435) HT is restored.	
	14:01	Sirajganj 132/33kV S/S T3-(435) LT is restored.	
15:25	21:20	Shahmirpur 132/33kV S/S 416T HT Forced S/D Due to Transformer Trip at 14:07 (Differential Relay trip(87/87N) signal and T2 Protection General Trip signal) due to 33 kv karnafally Tunnel feeder trip .	
16:02		Siddhirganj GT-2 was shutdown due to abnormal sound.	100 MW generation interrup.
16:39	17:07	Shkalbaha 230/132kV S/S Hathazari-02 Tripped showing Teleprotection relays Due to Zcom Tripping.	41 MW load interrup.
16:43	17:16	Madunaghat_I 400/230kV S/S ATR-01 LT Tripped showing RET670 relays.	
16:43	17:16	Madunaghat_I 400/230kV S/S ATR-01 HT Tripped showing RET670 relays.	
17:55		Sylhet 132/33kV S/S T4 LT Tripped showing Ins O/C. relays.	
18:08	18:22	Sreepur 230/132 kV grids S/S due to tripping of 33 kv Incomer-1 & 2.	48 MW load interrup.
20:13	00:04	Chapai 132/33kV S/S T-1 (405T) LT Forced S/D Due to T1 33 kv CB R phase red hot maintenance .	
20:13	00:04	Chapai 132/33kV S/S T-1 (405T) HT Forced S/D Due to T1 33 kv CB R phase red hot maintenance .	
	21:14	Hathazari-Kaptai 132kV Ckt-2 is restored.	
23:43	22:13	Mirpur-Uttara 3PH 132kV Ckt-1 is restored.	
	23:55	Thakurgaon 132/33kV S/S T-3(432T) HT Tripped.	13 MW load interrup.
	21:14	Hathazari-Kaptai 132kV Ckt-2 is restored.	
	22:13	Mirpur-Uttara 3PH 132kV Ckt-1 is restored.	
23:43	23:55	Thakurgaon 132/33kV S/S T-3(432T) HT Tripped showing N/A relays Due to 33kV Feeder fault under T-2 Transformer.	
23:43	00:10	Thakurgaon 132/33kV S/S T-2(412T) HT Tripped showing 33 kv O/C, E/F fault.Lockout relays Due to 33 kV Feeder fault.	
23:43	00:12	Thakurgaon 132/33kV S/S T-2(412T) LT Tripped showing Lockout relays Due to 33 kV Feeder fault.	
00:20	00:35	Bhulta-Haripur 132 kV Ckt-1 Tripped from Bhulta 132/33kV end showing MCGG(over current trip), MV/AI(backup protection trip), MVA(X(TCS-1 trip) relays Due to For KPPGL S/D, line load increased. So the line tripped for over load.	172 MW load interrup in Bhulta 132/33 kv end.
	01:38	Siddhirganj GT GT-2 was sync.	
0:57	6:38	Sirajganj GAS 410 MW Unit-4 ST was shutdown.	
06:40		Tangail 132/33kV S/S Kaliakair-2 Project Work S/D Due to project work.	
07:16		Fenchuganj -Sylhet 132kV Ckt-1 Project Work S/D from Sylhet 132/33kV end Due to For South Surma GIS Grid Line LILI Purpose.	
07:17		Fenchuganj-Sylhet (T at Bianibazar) 132kV Ckt-2 Project Work S/D from Fenchuganj 230/132/33kV end.	
07:29		Sirajganj 132/33kV S/S T4-(445) LT Project Work S/D.	
07:29		Sirajganj 132/33kV S/S T3-(435) LT Project Work S/D.	
07:30		Sirajganj 132/33kV S/S T3-(435) HT Project Work S/D.	3 MW load interrup.
7:30		Sirajganj 132/33kV S/S T4-(445) HT Project Work S/D.	9 MW load interrup.

**Superintendent Engineer
Load Despatch Circle**