POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT 21:00 Hrs on 19-Apr.23 Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at Available Max Generation Max Demand (Evening): Reserve(Generation end) Load Shed 5-Oct-23 now the maximum generation is:The Summary of Yesterday's Day Peak Generation: Evening Peak Generation: E.P. Demand (at gen end): Maximum Generation: Total Gen. (MKWH): 8825 16017 13200 2817 0 Total Gent. (www.co.) It from East grid to West grid :- Maximum It from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M on 107.84 FL(MSL) 444 MW MW 21:00 5-Oct-23 106.27 Ft.(MSL) Gas Consumed : Total = 1018.02 MMCFD. Oil Consumed (PDB) HSD : FO : Tk142,629,425 Tk548,543,407 of the Consumed Fuel (PDB+Pvt) : Oil : Tk299,170,254 Total : Tk990,343,086

| | Lo | ad Shedding & Other Informa | ation | | |
|-----------------|-----------|-----------------------------|----------------------------|------------------------------|-----------------------|
| Area | Yesterday | | | Today | |
| | | | Estimated Demand (S/S end) | Estimated Shedding (S/S end) | Rates of Shedding |
| | MW | | MW | MW | (On Estimated Demand) |
| Dhaka | 0 | 0:00 | 4437 | 0 | 0% |
| Chittagong Area | 0 | 0:00 | 1218 | 0 | 0% |
| Khulna Area | 0 | 0:00 | 1707 | 0 | 0% |
| Rajshahi Area | 0 | 0:00 | 1483 | 0 | 0% |
| Cumilla Area | 0 | 0:00 | 1220 | 0 | 0% |
| Mymensingh Area | 20 | 0:00 | 908 | 0 | 0% |
| Sylhet Area | 0 | 0:00 | 509 | 0 | 0% |
| Barisal Area | 0 | 0:00 | 424 | 0 | 0% |
| Rangpur Area | 0 | 0:00 | 829 | 0 | 0% |
| | | | | | |

829 **12735**

Rangpur Area Total

| | | Information of the Generating Units under shut down. | | |
|--------|---------|---|--|--------|
| | | Planned Shut- Down | Forced Shut-Down 1) Barras ST-Unit-1,2 2) Ghorasal-3,7 3) Shajilbazar 330 MW 4) Baghabari-71,100 MW 5) Raozan unit-2 6) Siddhirganj 210 MW . | |
| Outage | Restore | Additional Information of Machines, lines, Interruption / Forced Load shed etc. | · | Remark |

| Time | Restore | Additional Information of Machines, lines, Interruption / Forced Load shed etc. | |
|----------------------|--------------|--|----------------------------|
| - | Time | | |
| - - - | 8:08 | Purbasadipur 132/33kV S/S T-1 Transformer (403T) LT is restored. | |
| - - | 8:08 | Purbasadipur-Saidpur 132kV Ckt-1 is restored. | |
| - | 8:08 | Purbasadipur 132/33kV S/S T-3 Transformer (423T) LT is restored. | |
| - | 8:09 | Purbasadipur-Saidpur 132kV Ckt-2 is restored. | |
| | 8:14 | Purbasadipur-Thakurgaon-EPV 132kV Ckt-1 is restored. | |
| | 8:18 | Purbasadipur-Thakurgaon-EPV 132kV Ckt-2 is restored. | |
| _ | 8:20 | Purbasadipur 132/33kV S/S 33kV Bank-1 is restored. | |
| | 8:20 | Purbasadjour 132/33KV S/S 33KV Bank-2 is restored. | |
| 8:21 | 16:54 | Khagrachari-Rangamati 132kV Ckt-1 Scheduled S/D from Rangamati 132/33kV end Due to Annual maintenance. | |
| 8:49 | 10.54 | Nilegi admin-harigamen i 2247 V.Ki - ocieduled 275 non Rangaman 132/338V end bue to Annual mannenance. Sylhet south T1&T2 SD due to 33kv da alignment work. | |
| | | | |
| 9:10 | 16:16 | Tongi 230/132/33kV S/S Tongi-Uttara 3rd Phase Ckt Scheduled S/D Due to Annual maintenance (DLC). | |
| 9:19 | 17:53 | Jaldhaka 132/33kV S/S 416T LT Scheduled S/D Due to Annual maintenance work. | |
| 9:20 | 17:52 | Jaldhaka 132/33kV S/S 416T HT Scheduled S/D Due to Annual maintenance work. | |
| - | 9:55 | Hathazari 230/132/33kV S/S T-02 HT is restored. | |
| - | 9:56 | Hathazari 230/132/33kV S/S T-02 LT is restored. | |
| 10:13 | 10:51 | Rangpur-Saidpur 132kV Ckt-1 Forced S/D from Saidpur 132/33kV end Due to Red hot. | |
| _ | 11:54 | Svihet South T1&T2 was switched on | |
| 12:00 | - | Day peak generation is 11245 MW. | |
| 16:01 | 16:32 | Keranigonij 230/132/33kV S/S Hasnabad Tripped showing 21 Distance Zone 3 tripped. 86.1 trip relay operated. relays Due to | |
| 10.01 | 10.52 | 132 kV Hasnabad CKT 01 tripped. | |
| 16:14 | 16:28 | ISZ KV rissitaties UKT 01 stypes. Sirajganj 132/33KV SiS T3-(435) LT Forced S/D Due to energy meter phase sequence change work. | |
| | | Sirajganj 132/33/K 3/S 13-(435) ET Forced S/D Due to energy meter phase sequence change work. Sirajganj 132/33/K 3/S 13-(435) HT Forced S/D Due to Energy meter phase sequence change. | |
| 16:15 | 16:28 | on algum i roziovik vilo i ogradojim i roced oro bue to cirety treter prise sequence change. | 20 03 07/1 17 1 |
| 16:40 | 17:35 | Sonargaon 132/33kV S/S Tr-1 LT Forced S/D Due to 33 kv MIEZ feeder work. | 30.0MW load interrup. |
| 16:40 | 17:35 | Sonargaon 132/33kV S/S Tr-1 HT Forced S/D Due to 33 KV MIEZ feeder work. | 30.0MW load interrup. |
| 16:57 | 17:52 | Mongla 132/33kV S/S T-2 LT Tripped showing O/E (50/51) relays Due to 33 kv old port feeder fault. | 18.0MW load interrup. |
| 18:26 | 18:55 | Chandpur 132/33kV S/S 402T LT Tripped showing O/C & E/F relay relays Due to 33 kV Chandpur-2 Feeder O/C & E/F Signal, | 20.0MW load interrup. |
| | | A-Phase trip, earth fault signal shown but Chandpur-2 Feeder CB Not Operat. Due to Chandpur-2 feeder fault current flow | |
| | | Incomer-1 and incomer-1 CB Triped. | |
| 18:34 | _ | Khagrachari-Rangamati 132kV Ckt-1 Forced S/D from Rangamati 132/33kV end Due to Trip circuit unhealthy. | |
| | 18:56 | Shariatpur 132/33kV S/S T2-416T HT is restored. | |
| | 18:58 | Shariatpur 132/33kV S/S T2-416T LT is restored. | |
| 19:00 | 10.50 | Evening peak generation 12561 MW. | |
| 19.00 | 19:00 | Shariatpur 132/33kV S/S Auxiliary-02 (PGCB) HT is restored. | |
| | 19.00 | | |
| 0:30 | | BIPTC S/S Baharampur-4 Tripped showing Distance Relay 21.1 relays Due to None. | |
| - | 0:37 | Gopalganj 132/33kV S/S T1 HT is restored. | |
| - | 0:37 | Gopalganj 132/33kV S/S T1 LT is restored. | |
| 1:07 | - | Payra 1320 MW PP: Unit-2 was shutdown due to problem with de-superheater. | 660MW generation interrup. |
| 2:34 | - | Siddhirganj GT: Unit-1 tripped. | 120MW generation interrup. |
| 3:50 | 4:24 | Bogura 230/132kV S/S T-01 LT Tripped showing No Relay relays Due to Rain. | |
| 3:50 | 4:24 | Bogura 230/132kV S/S T-01 HT Tripped showing Lock Out Relay relays Due to Rain. | |
| 4:21 | - | Sirajganj Unit-4 was shutdown due to red hot maintenance at grid substation end. | 410MW generation interrup. |
| 4:45 | 5:00 | Jhenaidah-Kushtia 132kV Ckt-2 Tripped from Kushtia 132/33kV end showing Z1 relays Due to Earth fault, L-3 Due to heavy | |
| | | Rain fall with thundering and from Jhenaidah 132/33kV end showing under voltage relay relays Due to Inst. Over current. | |
| | 5:22 | Siddhirgani GT: Unit-1 was sync. | |
| 6:00 | J.22 | Min. Gen. 8825 MW | |
| 6:03 | - | Will. Oest. 6623 MVV Siraioani 132/33kV SiS T2-(425) HT Project Work S/D Due to PGNS (G2G) project has taken shutdown for T4 132kV BUS | |
| 6:03 | - | | |
| | | Loop disconnection work. | |
| 6:05 | - | Sirajganj 132/33kV S/S T3-(435) HT Project Work S/D Due to PGNS (G2G) project has taken shutdown for T4 132kV BUS | |
| | | Loop disconnection work. | |
| 6:07 | - | Sirajganj 132/33kV S/S Sherpur-1 Project Work S/D Due to PGNS (G2G) project has taken shutdown for T4 132kV BUS | |
| | | Loop disconnection work. | |
| | 7:59 | Baghabari-Sirajganj 132 kV Ckt-1 Project Work S/D from Sirajganj 132/33kV end Due to PGNS (G2G) project has taken | |
| 6:12 | | shutdown for T4 132kV BUS Loop disconnection work. | |
| 6:12 | 7:59 | Baghabari-Sirajganj 132 kV Ckt-1 Project Work S/D from Sirajganj 132/33kV end Due to PGNS (G2G) project has taken | |
| 6:12 | | shutdown for T4 132kV BUS Loop disconnection work. | |
| | | | |
| 6:12 | _ | Siraigani 132/33kV S/S Sherpur-2 Project Work S/D Due to PGNS (G2G) project has taken shutdown for T4 132kV BUS | |
| | - | Sirajganj 132/33kV S/S Sherpur-2 Project Work S/D Due to PGNS (G2G) project has taken shutdown for T4 132kV BUS | |
| 6:12 6:12 | - 7·55 | Loop disconnection work. | 65 0MW load interrup |
| 6:12 | 7:55 | Loop disconnection work. Sirajganj 132/33kV S/S Main Bus Project Work S/D Due to PGNS (G2G) project has taken shutdown for T4 132kV BUS Loop | 65.0MW load interrup. |
| 6:12 6:12 6:12 | | Loop disconnection work. Sirajami 132/33kV SIS Main Bus Project Work SID Due to PGNS (G2G) project has taken shutdown for T4 132kV BUS Loop disconnection work. | 65.0MW load interrup. |
| 6:12 6:12 | 7:55 7:59 | Loop disconnection work. Siriganij 1323/XV SSI Main Bus Project Work S/D Due to PGNS (G2G) project has taken shutdown for T4 132kV BUS Loop disconnection work. Baghabari-Siriganij 132 kV Ckt-1 Project Work S/D from Sirigipanij 132/Q3kV end Due to PGNS (G2G) project has taken shutdown | 65.0MW load interrup. |
| 6:12 6:12 6:12 | | Loop disconnection work. Sirajami 132/33kV SIS Main Bus Project Work SID Due to PGNS (G2G) project has taken shutdown for T4 132kV BUS Loop disconnection work. | 65.0MW load interrup. |