		POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date : 27-Oct-23							
Till now the maximum g	eneration is : -		15648.0		21:	00 Hrs on	19-Apr-23		
The Summary of Yesterd	lay's	26-Oct-2		Demand		Today's Actual Min	Gen. & Probable Gen. 8	& Demand	
Day Peak Generation : Evening Peak Generation :			11245.0 MW 12688.0 MW	Hour : Hour :	12:00 19:00	Min. Gen. at Available Max Gener	8:00		8976 14818
E.P. Demand (at gen end) :			12730.0 MW	Hour :	19:00	Max Demand (Evenir	na) :		11800
Maximum Generation :			12688.0 MW	Hour :	19:00	Reserve(Generation	end)		3018
Total Gen. (MKWH) :			261.333	System Load Factor	: 85.82%	Load Shed	1		0
Export from East grid to West	taria : Maximum		EXPORT / IMPO	RT THROUGH EAST-WEST INTERCONNEC	40 MW at	7:00	-	nerav	
Import from West grid to East	st grid :- Maximum			-	MW at	-		inergy	-
	Wate	r Level of Kaptai Lake at 6:00 A M on	27-Oct-23						
Actual :		103.57 Ft.(MSL),		Rule curv	e: 108.40	Ft.(MSL)			
Gas Consumed :		Total =	932.55 MMCFD.		Oil Consumed (PE	DB) :	HSD : FO :		
Cost of the Consumed Fuel	(PDB+Pvt) :		Gas : Coal :	Tk119,418,163 Tk606,785,831	Oil	. 7:010 070 700			
		Load Shedding 8	Other Information	16000,785,831	UI	: Tk316,072,798		otal : Tk1,042,276,792	
Area		Yesterday				Today			
A100		· · · · · · · · · · · · · · · · · · ·		Estimated Demand (S/S end)		Estimated Shedding	(S/S end)	Rates of Shedding	
		MW		MW			MW	(On Estimated Demand)	
Dhaka Chittagong Area		0 0:00 0 0:00		4534 1246			0	0% 0%	
Khulna Area		0 0:00		1246			0	0%	
Rajshahi Area		0:00		1517			0	0%	
Cumilla Area		0 0:00 25 0:00		1248 928			0	0%	
Mymensingh Area Svlhet Area		15 0:00		928 520			0	0% 0%	
Barisal Area		0 0:00		434			ő		
Rangpur Area		0:00		848			0	0%	
Total		40		13019			0		
		Information of the Generating Units under shu	down.						
		Planned Shut- Down			Forced Shut- Do				
		Planned Shut- Down			1) Barapukuria ST:				
					2) Ghorasal-3 7	01112-1,2			
		2) Stronssort, 2) 3) Shajibazar 330 MW							
					4) Baghabari-71,10	00 MW			
					5) Raozan unit-2				
					6) Siddhirganj 210	MW.			
Outage	Restore	Additional Information of Machin	nes, lines, Interruption / F	orced Load shed etc.					Remark
Time	Time								
08:15 08:15	17:17 14:51	Saidpur 132/33kV S/S TR-4 (414T) LT Scheduled S Palashbari 132/33kV S/S TR3-424T LT Scheduled S	D Due to Annual Maintena	1CE .					
08:32	14:52	Panchagarh 132/33kV S/S T-2(417T) LT Scheduled	S/D Due to Annual maintena	ince 2023/2024					
08:46	17:22	Chandraghona-Madunaghat 132 kV Ckt-2 S/D from	Madunaghat 132/33kV end	Due to for corrective maintenance					
08:48	15:24	Chauddagram-Cumilla(S) 132 kV Ckt-1 Scheduled S							
09:05		Gopalganj(N)-Madaripur 132kV Ckt-2 Project Work		2kV end Due to Madaripur ckt-02 SAS					
09:08	15:51	Commissioning and from Madaripur 132/33kV end E Ashuganj-Kishoreganj 132kV Ckt-2 Scheduled S/D f	lue to Project rom Kieboregani 132/33k\/	and Due to Annual Maintenance and from					
09.06	15.51	Ashuganj 230/132/33kV end Due to Annual mainten	ance work	end Due to Annual Maintenance and from					
09:14	12:59	Rangpur 132/33kV S/S T-1(414T) LT Scheduled S/E	Due to Annual Maintenand	ce					
09:17	16:22	Jamalpur-Mymensingh 132kV Ckt-2 S/D from Jama	Ipur 132/33kV end Due to A	Annual Maintenance.					
09:50	13:27	BIPTC S/S 10CF13 Forced S/D Due to Due to the tr							
09:55		Unique Meghnaghat Power 584 MW CCPP GT tripp	ed.						
11:40 12:55	15:22	Unique Meghnaghat Power 584 MW CCPP GT was Munshiganj 132/33kV S/S Sinha Peoples Energy Lir	sync. nited Project Work S/D Due	to Scada work By Communication					
12.00	15:22	Cumilla(N) 230/132/33kV S/S Sinna Peoples Energy Lir Cumilla(N) 230/132/33kV S/S 230KV T-02 LT is res	lored.	to could work by confliction					
13:17		Meghnaghat Unique Power CCPP 400/18kV ST GS	JT (Generation Step-Up Tra	ansformer) 400kV side was charged for the first	time.				
15:11		Siddhirganj CCPP 335 MW ST was sync.		-					
	15:45	Madunaghat-Sikalbaha 132kV Ckt-2 is restored.							
	16:27	Aminbazar-Mirpur 132kV Ckt-2 is restored.							
16:53	16:44 17:30	Amnura-Rajshahi 132kV Ckt-1 is restored. Halishahar 132/33kV S/S 423T(TR-3) LT Forced S/I	Due to Due to odh emerge	ancy maintenance					
10.00	17:30	Payra 400/132/33kV S/S 132/33 kV Transformer-03	HT is restored	andy manner failue.					
01:16		Meghnaghat Summit CCPP 305MW GT1 was sync.	at 01:16 hr and GT2 shut o	lown at 03:35hr					
06:27		Chowmuhani-Ramganj 132 kV Ckt-2 Project Work S	/D from Chowmuhani 132/	33kV end Due to Open Due to Scaffolding					
06:27		Chowmuhani-Ramganj 132 kV Ckt-1 Project Work S	/D from Chowmuhani end I	Due to Open Due to Scaffolding Remove work					
06:36		About 12MW interruption is occurring under Bhangi side tripping.	Ira 132KV sub-station from	U6:36 hrs due to T1&T2 transformer 33kV					
06:36	07:46	Bhangura 132/33kV S/S Tr-1(403T) LT Tripped shot	ving 86/C relays Due to 33	ky CT end bird flushing			15 MW power interru	ipt.	
06:36	07:46	Bhangura 132/33kV S/S Tr-2(413T) LT Tripped sho	ving 132/33 kv power transl	former-2 relays Due to Bird in 33 kv incommer			16 MW power interru	pt.	
07:08		Pabna 132/33kV S/S T-2 LT Forced S/D					20 MW power interru		
07:12		Kodda 132/33kV S/S Summit 149 MW PS Schedule	d S/D Due to Work for 132	kv CT change					
07:35	07:46	Rampal 1320 MW (BIFPCL) unit-2 was shutdown at Phone was 122/22/0/ S/S Tr 2/412T) LT is restored	U7:35 hrs due to preparation	on of PG test.					
	07:40	Bhangura 132/33kV S/S Tr-2(413T) LT is restored.							
	•						•		
	Sub Divisional Eng	ineer			Executive Eng	ineer		Superintendent Engi	ineer
	Network Operation Di	vision			Network Operatio			Load Despatch Cir	rcle