

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT										
Till now the maximum generation is :-				15648.0		21:00		Hrs on 19-Apr-23		
The Summary of Yesterday's				15-Nov-23		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :				10345.0 MW		Hour :		12:00		
Evening Peak Generation :				11892.0 MW		Hour :		18:00		
E.P. Demand (at gen end) :				11892.0 MW		Hour :		18:00		
Maximum Generation :				11892.0 MW		Hour :		18:00		
Total Gen. (MKWH) :				238.431		System Load Factor		83.54%		
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR										
Export from East grid to West grid :- Maximum				450 MW		at		7:00		
Import from West grid to East grid :- Maximum						MW		-		
Actual :				Water Level of Kaptai Lake at 6:00 A.M on 98.99		FL(MSL) ,		Rule curve : 107.50 FL(MSL)		
Gas Consumed :				Total = 839.12 MMCFD.		Oil Consumed (PDB) :				
						HSD : FO :				
Cost of the Consumed Fuel (PDB+Pvt) :				Gas : Tk114,499,637						
				Coal : Tk502,100,533		Oil : Tk246,240,056		Total : Tk862,840,227		
Load Shedding & Other Information										
Area		Yesterday		Estimated Demand (S/S end)		Today		Rates of Shedding		
		MW				Estimated Shedding (S/S end)		(On Estimated Demand)		
						MW				
Dhaka		0		0:00		4049		0		
Chittagong Area		0		0:00		1110		0		
Khulna Area		0		0:00		1553		0		
Rajshahi Area		0		0:00		1349		0		
Cumilla Area		0		0:00		1111		0		
Mymensingh Area		0		0:00		826		0		
Sylhet Area		0		0:00		463		0		
Barisal Area		0		0:00		386		0		
Rangpur Area		0		0:00		754		0		
Total		0				11600		0		
Information of the Generating Units under shut down.										
Planned Shut- Down						Forced Shut-Down				
						1) Barapukuria ST: Unit- 1,2 2) Ghorasal-3,7 3) Shajibazar 330 MW 4) Baghabari-71,100 MW 5) Razcan unit-2 6) Siddhirganj 210 MW .				
Outage		Restore		Additional Information of Machines, lines, Interruption / Forced Load shed etc.						Remark
Time		Time								
08:00		17:44		Shariatpur 132/33kV S/S T1-406T HT Scheduled S/D Due to Emergency Maintenance						
08:08		13:44		Jhenaidah 230/132kV S/S Jhenaidah2-Jashore Ckt-2 Scheduled S/D Due to Annual maintenance						
08:08		13:44		Jashore 132/33kV S/S JH-2(L1) Scheduled S/D Due to Annual Maintenance						
08:09				SS Power Unit-2 was synchronized.						
08:11		12:30		Juidah 132/33kV S/S 133/33 kV T-2 416T LT Scheduled S/D Due to Annual Maintenance.						
		08:12		Maniknagar-Siddhirganj 230kV Ckt-2 is restored.						
08:17		17:22		Rajshahi-Rajshahi(New) 132kV Ckt-1 Scheduled S/D from Rajshahi 132/33kV end Due to Annual Maintenance .						
08:20		16:58		Rangpur-Saidpur 132kV Ckt-2 Scheduled S/D from Rangpur end Due to Annual maintenance						
08:25				Faridpur 132/33kV S/S Transformer-3 LT Scheduled S/D Due to Annual Maintenance						
08:26		16:30		Ishwardi-Ruppur 132kV Ckt-1 Scheduled S/D from Ruppur 132/11kV end Due to Annual maintenances						
08:26		17:20		Rampal 400/230kV S/S ICT-1 LT Scheduled S/D Due to Preventive maintenance purpose.						
08:28		16:29		Ishwardi-Rooppur 132kV Ckt-2 Scheduled S/D from Ishardi 132/33kV end Due to A/M						
08:29		16:50		Sreemongol 132/33kV S/S 132/33kV T-2 LT Scheduled S/D Due to Annual maintenance						
08:30		16:50		Sreemongol 132/33kV S/S 132/33kV T-3 HT Scheduled S/D Due to Annual maintenance						
08:30		16:09		Faridpur 132/33kV S/S Transformer-3 HT Scheduled S/D Due to Annual Maintenance						
08:33		15:37		Chandraghona-Rangamati 132 kV Ckt-1 S/D from Chandraghona 132/33kV end Due to Dead line checking						
08:34		15:12		Tangail 132/33kV S/S Tr-2 HT Scheduled S/D Due to Annual Maintenance.						
08:39		17:11		Rajshahi 230/132/33kV S/S 132 kV Main BUS-01 Scheduled S/D Due to A/M						
08:42		17:52		Purbasaidpur 132/33kV S/S T-4 Transformer LT Scheduled S/D Due to Annual Maintenance						
08:45		19:06		Ashuganj-Sreepur 230 kV Ckt-2 Scheduled S/D from Ashuganj end Due to As per instruction of NLDC						
08:48		19:10		Bhulta-Haripur 230 kV Ckt-1 Scheduled S/D from Haripur 230/132kV end Due to Work on other side Due to A/M.						
08:55				Aminbazar 400/230/132kV S/S 230 kv Bus 01 Scheduled S/D Duetto Bus Conductor change work						
09:01		13:35		Fatuallah-Shyampur(New) 132 kV Ckt-2 Scheduled S/D from Fatullah 132/33kV end Due to Annual winter maintenance.						
09:04		16:35		Dohazari-Sikalbaha 132 kV Ckt-2 Scheduled S/D from Dohazari end Due to Annual Deadline checking.						
09:08		15:57		Ashuganj-Cumilla(N) 230 kV Ckt-2 Scheduled S/D from Cumilla(N) 230/132/33kV end Due to Annual Maintenance						
09:13		19:06		Sreepur 230/132/33kV S/S Sreepur-Ashuganj Ckt-2 Scheduled S/D Due to Annual Maintenance						
09:15		20:46		Gopalganj 400/132kV S/S ATR-02 LT Project Work S/D Due to SAS Commissioning						
09:20		09:59		Rangpur-Rangpur Confidence(100MW) 132kV Ckt-1 Forced S/D from Rangpur end Due to Gas filling of confidence side						
09:20		15:10		Ashuganj-Brahmanbaria 132kV Ckt-1 S/D from Brahmanbaria end Due to Annual maintenance.						
09:21				Khulna (C) S/S TR-1 425T LT Scheduled S/D Due to Annual maintenance.						
09:25		16:45		BIPTC S/S 10CF14 Scheduled S/D Due to Annual Maintenance						
09:49		18:41		Aminbazar 400/230/132kV S/S 230/132kV Tr-01 LT Scheduled S/D Due to Annual Maintenance						
		13:08		Barishal 230/132kV S/S T-5 HT is restored.						
13:15		17:04		Barishal 230/132kV S/S T-4 LT Scheduled S/D Due to Annual Maintenance						
		13:57		Keraniganj 230/132/33kV S/S Hasnabad is restored.						
		16:06		Niamatpur 132/33kV S/S 417T HT is restored.						
		17:01		Baghabari-Sirajganj 132 kV Ckt-1 is restored.						
		17:22		Sherpur(Bogura)-Sirajgonj 132 kV Ckt-2 is restored.						
		17:24		Sirajganj 132/33kV S/S Sherpur-2 is restored.						
		17:28		Mirpur 132/33kV S/S T1 HT is restored.						
		17:45		Shariatpur 132/33kV S/S T1-406T LT is restored.						
		23:23		Joydebpur-Kodda B 132 kV Ckt-1 is restored.						
		23:26		Joydebpur-Kodda B 132 kV Ckt-2 is restored.						
23:35				Bhola Natun Biddut BD LTD (GAS) GT-2 was shutdown due to hot gas path inspection.						110 MW Generation interrup.
00:58				BIPTC S/S 20DF24 Tripped showing 21R relays Due to 20DF24 shunt reactor tripped by impedance 21R						
05:25				Bashkhali SS Power Unit-1 was shut down due to bearing vibration problem.						
06:55				Niamatpur 132/33kV S/S 417T HT Scheduled S/D Due to Annual Maintenance work.						
07:03				Baghabari-Sirajganj 132 kV Ckt-1 Project Work S/D from Sirajganj 132/33kV end Due to BCRECL has taken S/D for tower erection						
07:08				Sherpur(Bogura)-Sirajgonj 132 kV Ckt-2 Project Work S/D from Bog-Sherpur 132/33kV end.						
		07:10		Hasnabad 132/33kV S/S Keraniganj-2 (Pre- Aourahati) is restored.						
07:34				Aggreko-keraniganj 132kV Ckt-1 Scheduled S/D from Keraniganj 230/132/33kV end Due to Annual maintenance work						
07:41				Hasnabad 132/33kV S/S Keraniganj-2 (Pre- Aourahati) S/D Due to From Keraniganj ending CB OPEN at 07:34 hrs and from our hasnabad Ending E/S Close at 07:41						
07:41				Barishal 230/132kV S/S T-5 HT Scheduled S/D Due to Annual maintenance						
07:45				Bogura-Sirajganj 230 kV Ckt-1 Scheduled S/D from Bogura end Due to Annual maintenance work						
07:55				Niamatpur 132/33kV S/S 417T LT Scheduled S/D Due to Annual Maintenance work.						
Sub Divisional Engineer Network Operation Division				Executive Engineer Network Operation Division				Superintendent Engineer Load Despatch Circle		