				POWER GRID COMPANY OF	BANGLADE	SH LTD.				
				NATIONAL LOAD DESP	PATCH CENT					
Till now the maximum ge	eneration is : -		15648.0			2	1:00 Hrs o	n 19-Apr-2	Reporting Date :	4-Jan-24
The Summary of Yesterd	ay's	3-Jan-2					Today's Actual	Min Gen. & Prob	able Gen. & Demand	1
Day Peak Generation : Evening Peak Generation :			9287.0 MW 10131.0 MW	Hour : Hour :	12:0 18:0		Min. Gen. at Available Max Ge	neration :	5:00	648° 11819
E.P. Demand (at gen end) : Maximum Generation :			10131.0 MW 10131.0 MW	Hour : Hour :	18:0 18:0		Max Demand (Ev Reserve(Generat			10200 1619
Total Gen. (MKWH)			205.711	System Load Facto	or : 84.6		Load Shed	ion enu)		(
Export from East grid to Wes	t grid :- Maximum		EXPORT / IMPO	RT THROUGH EAST-WEST INTERCOM	NNECTOR 292 MW	at	18:30		Energy	
Import from West grid to Eas	t grid :- Maximum	of Kaptai Lake at 6:00 A M on	4-Jan-24	-	MW	at	-		Energy	
Actual:	Tratal Earline	92.77 Ft.(MSL) ,	4 0011 24	Rule	curve :	102.43	Ft.(MSL)			
Gas Consumed :		Total =	719.82 MMCFD.		Oil C	Consumed (F	PDB):			
								HSD : FO :		
Cost of the Consumed Fuel (PDB+Pvt) ·		Gas :	Tk91,137,222						
:			Coal :	Tk492,187,206		Oil	: Tk184,247,137		Total : Tk	767,571,565
		Load Shedding &	Other Information							
Area		Yesterday					Today			
		MW		Estimated Demand (S/S end) MW			Estimated Shedd	ing (S/S end) MW	F	Rates of Shedding In Estimated Demand)
Dhaka		0 0:00		3467				MIVV	0	0%
Chittagong Area Khulna Area		0 0:00 0 0:00		946 1323					0	0% 0%
Rajshahi Area Cumilla Area		0 0:00		1148 946					0	0% 0%
Mymensingh Area		0 0:00 0 0:00		702					0	0%
Sylhet Area Barisal Area		0 0:00 0 0:00		395 328					0	0% 0%
Rangpur Area		0 0:00		642					0	0%
Total		0		9898					0	
		Information of the Generating Units under	shut down.							
		Planned Shut- Down			Ford	ed Shut-D	own			
					2) G	arapukuria S' horasal-3,7	1: Unit- 1,2			
	3) Shajibazari 330 MW 4) Baghabari-71,100 MW									
					5) R	aozan unit-2				
					6) Si	iddhirganj 21	0 MW .			
Outage	Restore	Additional Information of Ma	chines, lines, Interruption	/ Forced Load shed etc.						Remark
Time 8:08	Time 17:08	Jashore-Noapara 132kV Ckt-2 Scheduled S/D fr	rom Jashore 132/33kV end Γ	Que to Annual Maintenance From Noapara	End and					
		from Noapara 132/33kV end Due to Due to Anni	ual Maintenance.	·	End dilo					
8:20 8:20	17:31 19:00	Naogaon 132/33kV S/S T-3 LT Project Work S/I Bhulta-Rampura 230 kV Ckt-4 Scheduled S/D fr			to CT					
8:21	17:11	(2133 R-ph) change, and from Bhulta 400/230k\ Naogaon 132/33kV S/S T-3 HT Project Work S/	/ end Due to Shutdown take	n by Rampura SS.						
8:29	15:07	Bogura-Mahasthangar (New)) 132 kV Ckt-1 Sch	eduled S/D from Bogura 132							
8:38	17:17	and from Mahasthangarh 132/33kV end Due to a Baghabari-Sirajganj 230 kV Ckt-2 Scheduled S/l	Annual Maintenance. D from Siraigoni 230 end Du	e to Annual Maintenance, and from						
8:45	45.05	Baghabari 230/132kV end Due to A/M.								
8:50	15:05 17:46	Halishahar-Julda 132kV Ckt-1 Scheduled S/D fr Gopalganj (O) - Gopalgan (N) Ckt-1 Scheduled	om Juidan 132/33kV end Du S/D from Gopalganj 132/33k	ie to Annual Maintenance (Line). :V end Due to E/M.						
8:50 9:01	17:33 17:21	Gopalganj- Gopalganj(N) 132kV Ckt-2 Schedule Jaldhaka-Saidpur 132kV Ckt-2 Scheduled S/D f	d S/D from Gopalganj 132/3	3kV end Due to E/M.						
		Jaldhaka 132/33kV end Due to For Annual Main	tenance.							
9:04 9:05	17:20 21:05	Fenchuganj 230/132/33kV S/S 230 KV Bus-1 S New Tongi S/S T2(413T) LT Project Work S/D I								
9:13	17:22	Kallyanpur-Lalbag 132kV Ckt-2 Scheduled S/D t	from Kallyanpur 132/33kV er	nd Due to Dead line check.						
9:13 9:14	16:17 16:16	Nawabganj 132/33kV S/S TR-2 LT Scheduled S Nawabganj 132/33kV S/S TR-2 HT Scheduled S	S/D Due to Annual Maintenar	nce.						
9:14 9:18	15:37 16:24	Rampura-Ullon-2 132kV Ckt-2 Scheduled S/D fr			own, work at U	Illon end.				
9:19	16:32	Hathazari-Kaptai 132kV Ckt-1 Scheduled S/D from Hathazari 230/132/33kV end Due to Annual Maintenance. Madanganj 132/33kV S/S Madanganj -DPDC Char sayedpur 132k Ckt-2 Scheduled S/D Due to Control Cable repair work Going								
9:24 9:33	21:22 15:42	Matuail-Siddhirganj 132kV Ckt-1 Scheduled S/D Ashuganj-Shahjibazar 132kV Ckt-1 Scheduled S	rrom Siddhirganj 132/33kV S/D from Ashuganj 230/132/3	end ⊔ue to Annual Maintenance Work. 33kV end. and from Shahjibazar 132/33kV €	end					
9:34	13:57	Due to Cross broken at 178 no H pole. Pre mesi Bhaluka 132/33kV S/S Transformer- 01 HT Sch	rement for repairing.	faintananca						
9:34	13:59	Bhaluka 132/33kV S/S Transformer- 01 LT Sch	eduled S/D Due to Annual M							
10:00 10:01	14:51 16:10	Aminbazar 400/230/132kV S/S 132 kv Bus 02 S Ashuganj-Bhulta 400 kV Ckt-2 Scheduled S/D fi		Due to Due to Annual Maintenance Works						
10:34	19:32	Mirpur-Uttara 132kV Ckt-1 Scheduled S/D from	Mirpur 132/33kV end Due to		ent Maintenan	ce Work.				
10:35 10:41	14:36 14:37	Shikalbaha 230/132kV S/S Hathazari - 01 Project Hathazari 230/132/33kV S/S Shikolbaha-01 Project		t work.						
12:00	3:13	Day Peak Generation: 9287 MW Rampal 400/230kV S/S Bus Reactor Forced S/D								
12:07 12:07	3:13	Rampal 400/230kV S/S Bus Reactor Forced S/I	Due to Due To low voltage.							
-	12:07 12:56	BSRM 230/33kV S/S 230/33 kV Transformer-1 BSRM 230/33kV S/S 230/33 kV Transformer-1								
13:00	13:24	Siddhirganj 132/33kV S/S 120MW EGCB GT1	Tripped showing LBB INITIA	TION,86 relays Due to External fault						
13:00	-	(At the same time dutch bangla line goes trip). Siddhirganj-Siddhirganj (Orion)132kV Ckt-1 Trip	ped from Siddhirganj 132/33	BkV end showing E/F, O/C relays Due to Po	ot head LA Fau	ult.				
13:00 13:01	-	Siddhirganj- Dutch Bangla Line tripped due to th Sonargaon 132/33kV S/S B: 10.0MW load intern	e bursting of "Yellow" phase							
14:15	-	Siddhirganj-Siddhirganj (Orion)132kV Ckt-1 For	ced S/D from Siddhirganj 13.							
15:39 15:45	16:01 18:15	Siddhirganj 132/33kV S/S 120MW EGCB GT1 Hasnabad 132/33kV S/S 132/33kV 404 T-1 LT	Tripped showing LBB initiation	on relays Due to Trip. ain bus isolator box replacement						
15:45	18:15	Hasnabad 132/33kV S/S 132/33kV 404 T-1 HT	Forced S/D Due to 132 kv m	nain bus isolator box replacement.	MODE " :					
16:28	17:06 16:44	Jashore-Noapara 132kV Ckt-2 Tripped from Jas Chowmuhani-Feni 132 kV Ckt-2 is restored.		, , , , ,	MCB Failed.					
17:22	17:52 17:28	Hasnabad 230/132kV S/S AUTO TR-1 LT Tripp	ed showing No relay operate	ed relays.						
-	17:28 17:45	Dohazari-Sikalbaha 132 kV Ckt-1 is restored. Meghnaghat-Shyampur 230kV Ckt-1 is restored								
18:00 18:35	-	Evening peak generation is 10131MW Ashuganj 450 MW CCPP(North) Syncronized w								
19:40	21:18	Maniknagar-Matuail 132kV Ckt-1 Forced S/D fro	m Maniknagar 132/33kV en	d Due to Sky wire is torn at Matuail to Siddhi	nirgonj end.					
5:00 6:14	-	Minimum generation: 6481 MW. Dohazari-Sikalbaha 132 kV Ckt-2 Project Work	S/D from Shikalbaba 230/13	2kV end.						
7:41	-	Gopalganj (O) - Gopalgan (N) Ckt-1 Scheduled								
j J		1						1		

Executive Engineer Network Operation Division

Superintendent Engineer Load Despatch Circle

Sub Divisional Engin