

POWER GRID COMPANY OF BANGLADESH LTD.									
NATIONAL LOAD DESPATCH CENTER									
DAILY REPORT									
				21:00	Hrs on 19-Apr		Reporting Date : 10-Feb-24		
Till now the maximum generation is :-				15548.0					
The Summary of Yesterday's				9-Feb-24	Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	9108.0 MW	Hour :	12:00	Min. Gen. at		5.00	6804		
Evening Peak Generation :	9282.0 MW	Hour :	19:00	Available Max Generation			12455		
E.P. Demand (at gen end) :	9345.0 MW	Hour :	19:00	Max Demand (Evening)			10800		
Maximum Generation :	9670.0 MW	Hour :	13:00	Reserve(Generation end)			1655		
Total Gen. (MkWh) :	202.311	System Load Factor	87.17%	Load Shed			0		
Export from East grid to West grid :- Maximum				EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR		670 MW	at 7:00		Energy
Import from West grid to East grid :- Maximum						MW			Energy
Actual :				Water Level of Kapila Lake at 6:00 A.M on	10-Feb-24	Rule curve :		95.74	Fl (MSL)
Gas Consumed :				Total =	789.19 MMCFD.	Oil Consumed (POB) :		HSD	
								FO :	
Cost of the Consumed Fuel (POB+Pvt) :				Gas :	Tk303,748,880	Oil :		Tk50,953,846	Total : Tk821,884,915
				Coal :	Tk467,182,188				
Load Shedding & Other Information									
Area	Yesterday	Estimated Demand (S/S end)		Today	Estimated Shedding (S/S end)		Rates of Shedding (On Estimated Demand)		
	MW		MW			MW			
Dhaka	0	0.00	3694			0		0%	
Chittagong Area	0	0.00	1010			0		0%	
Khulshi Area	0	0.00	1413			0		0%	
Rajshahi Area	0	0.00	1226			0		0%	
Cumilla Area	0	0.00	1010			0		0%	
Myrmensingh Area	60	0.00	750			0		0%	
Sylhet Area	0	0.00	421			0		0%	
Barisal Area	0	0.00	350			0		0%	
Rangpur Area	0	0.00	665			0		0%	
Total	60	0.00	10660			0		0%	
Information of the Generating Units under shut down.									
Planned Shut-Down				Forced Shut-Down					
				1) Barapukuria ST- Unit-1,2 2) Ghormael-3,5, 3) Shahbazpur 330 MW 4) Baghabari-71,100 MW 5) Raicon unit-2 6) Siddhirganj 210 MW 7) Ashuganj East					
Outage	Region	Additional Information of Machines, lines, interruption / Forced Load shed etc.							Remark
Time	Time								
08:01	15:26	Kushlia 132/33kV S/S T2 LT Scheduled S/D Due to AM							40.0MW load interrup.
08:02	15:31	Kushlia 132/33kV S/S T2 HT Scheduled S/D Due to AM							40.0MW load interrup.
08:02	15:30	Kushlia 132/33kV S/S T-1 LT Scheduled S/D Due to AM							40.0MW load interrup.
08:03	15:35	Kushlia 132/33kV S/S T-1 LT Scheduled S/D Due to AM							40.0MW load interrup.
08:05	21:23	Feni 132/33kV S/S Bus-1 Scheduled S/D Due to Chondogram CKT01_02 Reconducting work.							12.0MW load interrup.
08:05	16:46	Manikganj 132/33kV S/S 132/33 kV Transformer GT-4 (5075 MVA) HT Project Work S/D Due to Project work.							12.0MW load interrup.
08:05	16:47	Manikganj 132/33kV S/S 132/33 kV Transformer GT-4 (5075 MVA) LT Project Work S/D Due to Project work.							12.0MW load interrup.
08:05	16:47	Manikganj 132/33kV S/S 132/33 kV Transformer GT-3 (5075 MVA) HT Project Work S/D Due to Project work.							12.0MW load interrup.
08:05	16:48	Manikganj 132/33kV S/S 132/33 kV Transformer GT-3 (5075 MVA) LT Project Work S/D Due to Project work.							12.0MW load interrup.
08:05	16:48	Manikganj 132/33kV S/S 132/33 kV Transformer GT-2(3550 MVA) HT Project Work S/D Due to Project work.							12.0MW load interrup.
08:05	16:25	Kaptipur - Manikganj 132kV Ck-2 Project Work S/D from Manikganj 132/33kV end Due to Project work.							Manikganj 132/33kV end 12.0MW load interrup.
08:05	16:26	Kaptipur - Manikganj 132kV Ck-1 Project Work S/D from Manikganj 132/33kV end Due to Project work.							Manikganj 132/33kV end 12.0MW load interrup.
08:05	16:49	Manikganj 132/33kV S/S 132/33 kV Transformer GT-2(3550 MVA) LT Project Work S/D Due to Project work.							Manikganj 132/33kV end 12.0MW load interrup.
08:17	14:59	Jhenaidah-Kushlia 132kV Ck-1 Scheduled S/D from Kushlia 132/33kV end Due to AM and from Jhenaidah 132/33kV end Due to AM							40.0MW load interrup.
08:17	15:00	Is Kushlia 132kV Bus shutdown.							Kushlia 132/33kV end 40.0MW load interrup.
08:17	14:59	Jhenaidah-Kushlia 132kV Ck-2 Scheduled S/D from Kushlia 132/33kV end Due to AM and from Jhenaidah 132/33kV end Due to AM							40.0MW load interrup.
08:18	14:58	Bheramara PIS-Kushia 132 kV Ck-1 Scheduled S/D from Kushlia 132/33kV end Due to AM and from Bheramara 230/132kV end Due to Annual Maintenance							Kushlia 132/33kV end 40.0MW load interrup.
08:18	14:59	Bheramara PIS-Kushia 132 kV Ck-2 Scheduled S/D from Kushlia 132/33kV end Due to AM and from Bheramara 230/132kV end Due to Annual Maintenance							Kushlia 132/33kV end 40.0MW load interrup.
08:30	16:11	Shikabaha 230/132kV S/S ATR 02 LT Scheduled S/D							Bheramara 230/132 kV end 38.0MW load interrup.
08:32	16:10	Shikabaha 230/132kV S/S ATR 02 HT Scheduled S/D							Bheramara 230/132 kV end 38.0MW load interrup.
08:33	08:33	Sirajganj 132/33kV S/S Main Bus is restored.							Bheramara 230/132 kV end 38.0MW load interrup.
08:40	17:36	Manknagar-Siddhirganj 230kV Ck-2 Scheduled S/D from Siddhirganj 230/132kV end Due to Dead Line Checking.							
08:52	08:52	Sherpur(Bogura)-Sirajganj 132 kV Ck-1 is restored.							
09:03	17:18	Ghorasal- Ishwardi 230 kV Ck-2 Scheduled S/D from Ghorasal 230kV end Due to T cleaning the 230 kV line disk and from Ishwardi 230/132kV end.							
09:05	14:10	Bhutta 132/33kV S/S GT1 HT Scheduled S/D Due to Annual Maintenance							40.0MW load interrup.
09:22	16:11	Amnura 132/33kV S/S T-2 (410T) HT Scheduled S/D Due to Cooling fan maintenance							
09:22	16:13	Amnura 132/33kV S/S T-2 (410T) LT Scheduled S/D Due to Cooling fan maintenance							
09:34	10:09	Mirzapur 132/33kV S/S Transformer-01(E05) HT Tripped showing Non dir over current stage -1 & 2 87T relay general trip&1 relay trip OPTD&2 relay trip OPTD relays Due to PSS three feeder fault.							43.0MW load interrup.
09:34	10:14	Mirzapur 132/33kV S/S Transformer-01(E05) LT Tripped showing Non dir over current stage -1 & 2 87T relay general trip&1 relay trip OPTD&2 relay trip OPTD relays Due to PSS three feeder fault.							43.0MW load interrup.
09:34	10:29	Mirzapur 132/33kV S/S Transformer-02(E07) LT Tripped showing 87T relay general trip&1 relay trip OPTD&2 relay trip OPTD relays Due to PSS three feeder trip at a time							43.0MW load interrup.
09:35	09:35	Jaypurhal-Naogon 132kV Ck-1 is restored.							
10:41	14:44	Bakulia-Sikabaha 132 kV Ck-2 Scheduled S/D from Shikabaha 230/132kV end.							
11:12	12:22	Kamargrhor-Kemanganj 138kV Ck Scheduled S/D from Kemanganj 230/132kV end Due to Dead line check.							
11:22	12:20	Uthlagra 132/33kV S/S Power Transformer -1 LT Forced S/D Due to 132 kv T1 Transformer BKR gas leakage maintenance.							
11:22	12:19	Bogura west 400/230 kV ATR-3 S/D							
11:22	12:19	Uthlagra 132/33kV S/S Power Transformer -1 HT Forced S/D Due to SF6 GAS leakage maintenance.							
11:32	11:39	Bogura West 400 KV Bus-2 S/D							
12:00	12:40	Farpur 230/132kV S/S 132kV Reserve Bus Sec-1 Scheduled S/D Due to 1132 KV Rahim Sill Reserve Bus Isolator finger changing work.							
12:40		Day Peak Gen. 9109 MW							
		S/S Power Synchronized							
		Sirajganj 132/33kV S/S T1-(410T) LT is restored.							
		Sirajganj 132/33kV S/S T1-(410T) HT is restored.							
		Bakulia-Sikabaha 132 kV Ck-2 is restored.							
		Bogura 230/132kV S/S 230kV Main 1 is restored.							
13:30	15:14	Farpur 132/33kV S/S 132 kV 50MW Power Station ck-1 Tripped showing Distance, Zone-1 (6.089 km), ABC N relays Due to Unknown							
		Aminabaz-Arpor(Chal) 230kV Ck-1 is restored.							
18:37	18:35	Bogura West 400 KV Bus-2 Syn.							
		Bogura west 400/230 KV ATR-3 Syn.							
19:00	18:52	Ishwardi 132/33kV S/S 132 kV Baghabari Line is restored.							
		Evening peak generation: 9282 MW.							
19:20	19:28	Faridpur 132/33kV S/S 132 kV 50MW Power Station ck-1 Tripped showing Distance, Zone-1 (6.689 km), ABC N relays.							
19:29		Faridpur 132/33kV S/S 132 kV 50MW Power Station ck-1 Tripped showing Distance, Zone-1 (6.660 km), ABC N relays.							
	21:35	Feni 132/33kV S/S T2(410T) LT is restored.							
	21:35	Feni 132/33kV S/S T2(410T) HT is restored.							
	22:10	Feni 132/33kV S/S Feni-Lanka HFO PS is restored.							
	22:12	Chaudhagram-Feni 132 kV Ck-2 is restored.							
	22:12	Chaudhagram-Feni 132 kV Ck-1 is restored.							
		Siddhirganj 335 MW CCRP Synchronized with remarks:- GT							
22:19		Siddhirganj CCRP 335 MW GT was sync.							
01:17		Meghnaghat 450 MW CCRP (MPL) Shutdown with remarks:- GT1							
01:28		Siddhirganj 335 MW CCRP Synchronized with remarks:- ST							
01:28		Siddhirganj CCRP 335 MW ST was sync.							
01:38		Meghnaghat 450 MW CCRP (MPL) Shutdown with remarks:- ST							
01:46		Meghnaghat 450 MW CCRP (MPL) Shutdown with remarks:- GT2							
01:46		Meghnaghat CCRP 450 MW was shutdown.							
05:00		Minimum generation is 6604 MW							
06:36		Manikganj 132/33kV S/S 132/33 kV Transformer GT-2(3550 MVA) HT Project Work S/D Due to Project work.							
06:37		Manikganj 132/33kV S/S 132/33 kV Transformer GT-2(3550 MVA) LT Project Work S/D Due to Project work.							
06:37		Manikganj 132/33kV S/S 132/33 kV Transformer GT-3 (5075 MVA) HT Project Work S/D Due to Project work.							
06:38		Manikganj 132/33kV S/S 132/33 kV Transformer GT-3 (5075 MVA) LT Project Work S/D Due to Project work.							
06:38		Manikganj 132/33kV S/S 132/33 kV Transformer GT-4 (5075 MVA) HT Project Work S/D Due to Project work.							
06:48		Gopalganj 132/33kV S/S Gopalganj 100 MW PS Forced S/D							
06:48		Gopalganj-Methumail 132kV Ck-1 Forced S/D from Gopalganj 132/33kV end.							
06:48		Kaptipur - Manikganj 132kV Ck-2 Project Work S/D from Manikganj 132/33kV end Due to Project work.							
06:48		Kaptipur - Manikganj 132kV Ck-1 Project Work S/D from Manikganj 132/33kV end Due to Project work.							
06:48		Gopalganj 132/33kV S/S Gallamani-1 Forced S/D Due to Main bus ret hot maintenance							
06:48		Gopalganj 132/33kV S/S Gallamani-2 Forced S/D							
07:00		Gopalganj (Ch) - Gopalganj (N) Ck-1 Scheduled S/D from Gopalganj 400/132kV end. and from Gopalganj 132/33kV end.							
07:00		Gopalganj- Gopalganj(N) Ck-2 Scheduled S/D from Gopalganj 400/132kV end. and from Gopalganj 132/33kV end.							
07:03		Gopalganj 132/33kV S/S T1 Forced S/D							
07:04		Gopalganj 132/33kV S/S LT Forced S/D							
07:05		Kaptipur - Manikganj 132kV Ck-1 Scheduled S/D from Kaptipur 132/33kV end Due to Shutdown taken by Manikganj grid							20.0MW load interrup.
07:05		Gopalganj 132/33kV S/S T2 LT Forced S/D							20.0MW load interrup.
07:06		Kaptipur - Manikganj 132kV Ck-2 Scheduled S/D from Kaptipur 132/33kV end Due to Shutdown Taken by Manikganj grid							25.0MW load interrup.
07:06		Gopalganj 132/33kV S/S T2 Forced S/D							25.0MW load interrup.
07:22		Bogura 230/132kV S/S 132kV Main 1 Scheduled S/D Due to PROJECT WORK							
		BPTC S/S 220kV-42 Tripped showing relay 286 & 186 operated relays Due to summary (backpack protection opt.)							
07:14		Rampur 230/132/33 S/S Khulshi-2 Scheduled S/D Due to Bus shutdown at khulshi Grid							
07:14		Rampur 230/132/33 S/S Khulshi-1 Scheduled S/D Due to Bus shutdown at khulshi Grid							
07:22		Khulshi 132/33kV S/S Main Bus Scheduled S/D Due to Annual maintenance....							
07:26		AKSM-Khulshi 132kV Ck-1 Project Work S/D from AKS 132/33kV end Due to Comand to Nide							30.0MW load
07:33		BSRM-Cumilla(N) 230 kV Ck-1 Project Work S/D from BSRM 230/33kV end Due to Shutdown taken by ESPNER project.							
07:36		Baghabari-Siraganj 230 kV Ck-1 Project Work S/D from Baghabari 230/132kV end Due to DRNPP-403W/Roopur Dhaka Phase-2 Stringing Work							
07:39		Baghabari-Siraganj 230 kV Ck-2 Project Work S/D from Baghabari 230/132kV end Due to DRNPP-403W/Roopur Dhaka Phase-2 Stringing Work							
Sub Divisional Engineer Network Operation Division				Executive Engineer Network Operation Division				Superintendent Engineer Load Dispatch Circle	