P					POWER GRID COMPANY OF BAR	NGLADESH LTD.					
					NATIONAL LOAD DESPATO DAILY REPORT	CH CENTER					
Till now the maximum		21-Mar-24		5648.0		21	00 Hrs on Today's Actual Min Gen. & I	19-Apr-23	porting Date :	22-Mar-24	
The Summary of Yester Day Peak Generation Evening Peak Generation	rday's :	21-Mar-24	10124.0 1		Hour:	12:00 18:00	Min. Gen. at Available Max Generation		00		7249 13365
E.P. Demand (at gen end) Maximum Generation			10246.0 M	/W	Hour : Hour :	18:00 13:00	Max Demand (Evening) : Reserve(Generation end)				10700 2665
Total Gen. (MKWH)	<u> </u>		232.981		System Load Factor THROUGH EAST-WEST INTERCONNE	: 93.95%	Load Shed :				0
Export from East grid to W Import from West grid to E	est grid :- Maximum ast grid :- Maximum			-		840 MW at MW at	21:00		Energy Energy		_
Actual :	Water Level	of Kaptai Lake at 6:00 A M on 80.97 Ft.(MSL),	2	2-Mar-24	Rule cur		Ft.(MSL)				
Gas Consumed :		Total =	847.82	MMCFD.		Oil Consumed (P					
								HSD : FO :			
Cost of the Consumed Fue	el (PDB+Pvt) :		Gas :		Tk352,496,687						
:			Coal :		Tk517,104,573	Oil	: Tk227,629,258		Total : Tk1,097	,230,518	
Area		Load Shedding & Other	er Informati	<u>on</u>			Today				
Atta		MW			Estimated Demand (S/S end)		Estimated Shedding (S/S end	l) MW		of Shedding mated Demand)	
Dhaka Chittagong Area		0 0:00 0 0:00			4567 1255				0	0% 0%	
Khulna Area Rajshahi Area		0 0:00 0 0:00			1758 1528				0	0% 0%	
Cumilla Area Mymensingh Area		0 0:00 0 0:00			1257 935				0	0%	
Sylhet Area Barisal Area		0 0:00 0 0:00			524 437				0	0% 0%	
Rangpur Area Total		0 0:00			854 13114				0	0%	
		Information of the Generating Units under shut of	down.								
-		Planned Shut- Down				Forced Shut-Do	wn				
						1) Barapukuria ST 2) Ghorasal-3,5,7	: Unit- 1,2				
						3) Shajibazar 330 4) Baghabari-71.1	MW 00 MW				
						5) Raozan unit-2 6) Siddhirganj 210	MW				
						7) Ashuganj North					
Outage	Restore	Additional Information of Machine	s, lines, Inte	rruption / Force	ed Load shed etc.						Remark
Time 08:13	Time 16:25	Mirpur-Uttara 3PH 132kV Ckt-1 Scheduled S/D from	n Mirpur 132	33kV end Due to	B phase CT replacement work on						
	08:25	Mirpur-Uttara Sector-18 Ckt Niamatpur 132/33kV S/S Transformer-2 (417T) LT is	restored.								
08:47 08:58	11:47 11:57	Keraniganj-Nawabganj 132kV Ckt-2 Scheduled S/D f Keraniganj-Nawabganj 132kV Ckt-2 Scheduled S/D f	rom Nawabo	janj 132/33kV er onj 230/132/33k	d Due to Instructed by NLDC V end Due to Maintenence work at						
09:08	12:51	Keraniganj end. Sunamgani 132/33kV S/S Chhatak-Sunamgoni CKT-	-2 Scheduler	i S/D							
09:11	09:29	Bhaluka 132/33kV S/S Transformer- 01 LT Tripped s	howing Alsto	m relays Due to	33kv gaffargaon feeder trip for C.T.			50.0MW load	interruption.		
09:11	09:29	Bhaluka 132/33kV S/S Transformer- 02 LT Tripped s	howing Alsto	m relays Due to	33kv gaffargaon feeder trip for C.T.						
09:19 09:19	12:59 12:59	Sylhet 132/33kV S/S T4 LT Scheduled S/D Due to Te Sylhet 132/33kV S/S T4 HT Scheduled S/D Due to Te									
09:38	16:19 09:38	Madanganj 132/33kV S/S Madanganj -Haripur 132 kt Faridpur 132/33kV S/S 33 KV Bus is restored.	v Ckt-2 Foro	ed S/D Due to Re	ed hot maintenance						
09:39 12:00	16:18	Haripur 20/13/2/V SS Madanganj-2 Scheduled SID Due to Work of Madanganj Substation. Day peak Gen. = 10/12/4 MW.									
12:37	12:10	Chapai 132/33kV S/S T-1 (405T) HT is restored. Siddhirganj 335 MW CCPP Tripped with remarks:- S	т								
14:13	13:27	Joypurhat-Naogaon 132kV Ckt-1 is restored. Haripur 230/132kV S/S Auto TR-1 HT Scheduled S/E		Centifusina Worl							
14:13 15:52	22:45	Haripur 230/132kV S/S Auto TR-1 LT Scheduled S/D Matuail-Siddhirganj 132kV Ckt-1 Tripped from Siddh	Due to Oil (Centifusing Work				72.0MW load	interruption.		
		Due to Conductor loop break off in pot head B- phase relays Due to Tripping at Siddhirgonj end	and from N	latuail 132/33kV	end showing No Relay at Matuail end						
15:53 15:53	16:36 16:36	Siddhirganj 132/33kV S/S 120MW EGCB GT2 Trippo Siddhirganj 132/33kV S/S 120MW EGCB GT1 Trippo	ed showing l	.BB initiation rela	ays Due to Matuail line trip ays Due to Matuail line trip						
16:10 16:24		Siddhirganj 335 MW CCPP Syncronized with remark Siddhirganj 335 MW CCPP Syncronized with remark	s:- manual u	pdate (GT/False	i .						
16:55 16:55	17:20	Matarbari 2*600 MW (CPGCL) Syncronized with rem Purhasadinur 132/33kV S/S T-1 Transformer (403T)	arks:- manu HT Tripped	showing No Rela	av relavs			40.0MW load	interruption.		
16:55 16:55	17:21 17:29	Purbasadipur 132/33kV S/S T-1 Transformer (403T) Purbasadipur 132/33kV S/S T-2 Transformer (413T)	LT Tripped :	showing MCGG.	ALSTOM relays Due to 33KV Balubari Fault			21.0MW load			
16:55	17:30	Feeder Fault Purbasadipur 132/33kV S/S T-2 Transformer (413T)		-	•						
	17:12	BALUBARI FEEDER FAULT Maniknagar-Siddhirganj 230kV Ckt-2 is restored.		J	, ,						
18:00 18:45		Evening Peak Gen. 10248 MW Bashundhara-Tongi 132 kV Ckt-2 Tripped from Tong	i 230/132/33	kV end showing	Distance relay.Z-1.B-Phase relays						
	19:24	Due to Heavy Storm Kalurghat 132/33kV S/S TRFO-02(516T) LT is restor		_							
19:35	22:17	Haripur 230/132kV S/S Ullon (Maniknagar-2) Tripped thundaring.	d showing Di	stance Zone-1 Y	phase Neutral. relays Due to Rain and						
19:50		Haripur-Sonargaon 132kV Ckt-2 Tripped from Harip Rain and Thundaring. and from Sonargaon 132/33kV	ur 230/132k end showin	V end showing E a General trip. Z	Distance Zone -1, AN. relays Due to one -1. R-phase fault, carrier						
19:50	22:42	record, A/R operated, relays Due to Line trip Matuail-Siddhirganj 132kV Ckt-1 Forced S/D from Si									
19:51	20:04	pot head B- phase. Sonargaon 132/33kV S/S Tr-1 LT Forced S/D Due to						55.0MW load	interruption.		
19:58 22:14	19:58	Haripur-Sonargaon 132kV Ckt-2 Scheduled S/D from Bhola 225 MW CCPP Syncronized with remarks:- G	m Sonargaoi	132/33kV end I	Due to Line checking purpose.						
22:14 06:19		Bhola 225 MW CCPP Shutdown with remarks:- GT-2 Bhandaria 132/33kV S/S Transformer-2 LT Project W	2		Work			10.0MW load	interruption.		
06:20 06:21		Bhandaria 132/33kV S/S Transformer-2 HT Project W Bhandaria 132/33kV S/S Main Bus Bar Project Work	Vork S/D Du	to G2G project	work						
06:21	1	Barishal-Bhandaria 132 kV Ckt-1 Project Work S/D fr Barishal 132/33kV end Due to Bhandaria Substation	om Bhandar Bus Mainten	ia 132/33kV end ance work	Due to G2G Project Work and from						
06:23 06:23	1	Jamalpur 132/33kV S/S T-3 LT Scheduled S/D Due t Jamalpur 132/33kV S/S T-3 HT Scheduled S/D Due t	to 33 KV cap	acitor bank 3 dis acitor bank 3 dis	connector switch maintenance work			8.0MW load i	nterruption.		
06:24 06:26		Bagerhat-Bhandaria 132 kV Ckt-1 Project Work S/D f Feni 132/33kV S/S T-2(415T) LT Scheduled S/D Due	from Bagerh	at 132/33kV end	Due to Ordered by ALDC, Khulna.			6.0MW load i	nterruption.		
06:26 06:30		Feni 132/33kV S/S T-2(415T) HT Scheduled S/D Du Dohazari 132/33kV S/S Power Transformer -T-1 HT I	e to For 33K	V Isolator Mainte	nance			26.0MW load			
06:30 06:36		Dohazari 132/33kV S/S Power Transformer -T-1 LT F Jashore 132/33kV S/S T-2 LT Project Work S/D Due	Project Work	S/D Due to G2G	capacity upgradation work			35.0MW load			
06:37 06:37		Jashore 132/33kV S/S T-2 HT Project Work S/D Due Jashore 132/33kV S/S T-2 HT Project Work S/D Due Jashore 132/33kV S/S T-1 LT Project Work S/D Due	to 33 kv bus	ber upgradation							
06:37 07:00		Jashore 132/33kV S/S T-1 ET Project Work S/D Due Minimum Generation = 7,251MW	to 33kv bus	ber upgadation							
07:51 07:58		SS Power Shutdown with remarks:- Unit-2 Madaripur 132/33kV S/S T3-426T LT Tripped showir	na O/C relev					4.0MW load i	nterruption		
07:58	I	Madaripur 132/33kV S/S T3-426T HT Tripped showii	ng O/C relay	s Due to None					rapaon.		

Executive Engineer Network Operation Division Superintendent Engineer Load Despatch Circle

Sub Divisional Engineer Network Operation Division