

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2024				Day : Friday				Date : 22.03.24				
Probable Maximum Demand : 10700 MW				Probable Maximum Generation : 13365 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 81.09 ft				Today = 80.97 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.03.24 (Yesterday)		22.03.24 (Today)		21.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/ Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	140	150			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	31	25	20	25	83	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	350	420	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	365	364	360	360			
10	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	300	250	335	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	150	151	150	150	184	Gas Shortage	
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	15	15			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	8	8			
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	32	27	39	39			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	25	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	32	32	32			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	17			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	35	17	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	82	16	149			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	15	15	45	195			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	17	77	35	100			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	0	17			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	14	0	17			
28	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	0	17	0	54			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	20	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17			
31	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
32	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	0	17			
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	51	34	98	98			
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	15	25			
35	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage	
	Meghnaghat 589 MW CCGP(Summit)	Gas				0	0	0	0		Test run	
Dhaka Zone Total				5828	5634	1583	1772	1851	2442	1356	740	
36	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	20	8	25			
40	Teknaf 20MW PP (SolarsTech)	Solar (IPP)	1x20	20	20	0	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	20			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
44	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	216	216	213	215			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	16	0	32			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	34	34	34			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	66	32	66			
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	15	20	30			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	7	25	0	25			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	0	17			
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
53	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	86	11	12	12			
54	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	25	0	25	25			
55	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	17	17	140			
57	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	280	280	280	280			
58	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	568	695	810	810			
	Cox's Bazar Wind PP	(Wind) (IPP)				14	0	40	40		Test run	
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				20	0	25	0		Test run	
Chattogram Zone Total				4404	4344	1432	1517	1650	1874	380	330	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	40	39	46	46			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	198	191	225	225			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	280	295	270	300			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Gas Shortage	
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	287	320	300	320			
64	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	0	0	187	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	0	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	6	6	8			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	38	47	47	47			
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		Test run	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	51	34	200			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	9	10			
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	25	34	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	5	17	19	17			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	30	34	114			
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	28	45	55			
76	Bhainbari 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	0	34	0	94			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	10	53	20	55			
**	Impoprt (Tirupura)	India		160	160	110	124	128	141			
Cumilla Zone Total				2937	2929	1158	1377	1267	1785	547	0	
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	72	73	90	100	129	Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	115	115	49	97	60	98				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	19	0	18			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0			
84	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
Mymensingh Zone Total				600	592	168	195	202	222	129	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.03.24 (Yesterday)		22.03.24 (Today)		21.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)				
85	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0	0	70	Under maint.			
86	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	38	38	38	38	0	52	GT-4 Under maint.			
87	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	0	0				
88	Kushiana 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	130	120	163	163	0	0				
89	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	0	0				
90	Shahjibazar GTPP Unit-8 & 9	Gas (PDB)	2x35	70	66	40	40	65	65	0	0				
91	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	0	330	Under maint.			
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	0	0	Contact Expired			
93	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	212	210	205	210	0	0				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	18	20	20	0	0				
95	Sylhet 10 MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10	0	0				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	13	17	16	17	0	0				
97	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	280	300	300	0	0				
98	Bibiana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	320	330	400	400	0	0				
99	Bibiana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	360	370	370	370	0	0				
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	0	0	Test run			
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	0	0				
Sylhet Zone Total						2472	2427	1409	1423	1587	1593	0	452		
102	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0	0	0				
103	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	0	Gas Shortage			
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	6	0	50	0	0				
105	Gopalnani 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	9	0	70	0	0				
106	Khulna 225 MW CCGP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0	0	0				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	17	17	0	0				
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0	0	0				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	72	0	100	0	0	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	32	0	0				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	0	0				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	356	363	370	370	0	0				
113	Khulna 330 MW CCGP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	919	923	937	792	0	0				
Khulna Zone Total						3241	3237	1347	1301	1424	1331	410	0		
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110	0	0				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	6	7	7	0	0				
116	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	80	80	130	130	0	114	ST under maint.			
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	700	700	1200	1200	0	0				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	54	0	0				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	150	150	0	0				
120	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	180	220	220	0	0				
Barishal Zone Total						2265	2265	1104	1106	1817	1871	0	114		
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	0	Gas Shortage			
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	0	Under maint.			
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	25	40	0	0				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	24	0	0				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	44	50	90	0	0				
125	Katakhalii 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	14	40	50	0	0				
126	Katakhalii 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	42	42	0	0				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	16	38	0	0				
128	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	140	140	140	150	70	0	Gas Shortage			
129	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	0	Gas Shortage			
130	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	0	Gas Shortage			
131	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	349	250	414	414	164	0	Gas Shortage			
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	2	2	5	8	0	0				
133	Natore 52 MW PP (Rajkanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8	0	0				
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	0	35	0	0				
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	0	35	0	0				
136	Armura 50 MW PP (Sinha)	HFO (NENP)	7x7.9	50	50	0	0	28	28	0	0				
137	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0	0	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1012	826	1000	1000	745	100				
Rajshahi Zone Total						3453	3431	1505	1311	1774	1962	745	100		
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	0	Coal Shortage			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	0	Under Overhauling			
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	0	Coal Shortage			
140	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0	0	0				
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	38	6	40	0	0				
142	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0	0	0				
143	Majpara, Tatulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0	0	0				
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	36	0	75	0	0				
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	39	0	30	0	0	0				
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	204	0	130	0	0	0				
Rangpur Zone Total						1030	950	418	244	344	285	189	85		
Sub-total: Plants in operation						26230	25809	10124.0	10246	11916	13365	3756	1821		
(B) Plants under long term maintenance/ contract expired															
147	Katpottii 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0	0	0	0	Contract Expired		
148	Hariapur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0	0	0	0	Contract Expired		
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0	0	0	0	Contract Expired		
150	Bosila 108MW PP(CLCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0	0	0	0	Contract Expired		
Sub-total: Plants under long term maintenance/ contract expired						614	0	0	0	0	0	0	0		
Gross Total						26844	25809	10124	10246	11916	13365	3756	1821		
(C) Actual data of 21.03.24 (Yesterday) Thursday :															
01.	Max. Demand at eve. peak (Generation end)	:	10246	MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	9998	MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	10333	MW, at =	13:00 hrs	Dhaka	3931	3931	0	Mymensingh	946	946	0		
04.	Minimum Generation (Generation end)	:	8058	MW, at =	6:00 hrs	Chattogram	1006	1006	0	Sylhet	363	363	0		
05.	Day-peak Generation (Generation end)	:	10124	MW, at =	12:00 hrs	Khulna	1019	1019	0	Rajshahi	297	297	0		
06.	Evening-peak Generation (Generation end)	:	10246	MW, at =	18:00 hrs	Rajshahi	953	953	0	Rangpur	578	578	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs	Cumilla	905	905	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7249	MW, at =	5:00 hrs	Total							9998	9998	0
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost :							(a) Gas = 352496687 Taka	(c) Coal = 517104573 Taka	
a)	Gas/LF limitation	:	3367	MW		(b) Oil = 227629258 Taka							Total = 1097230518 Taka		
c)	Coal supply Limitation	:	189	MW		14. Maximum Temperature in Dhaka was :							26.8°C		
b)	Low water level in Kaptai lake	:	200	MW		15. Export through East-West interconnections :									
c)	Plants under shut down/ maintenance	:	1821	MW		At evening peak-hour							10124	MW, at	18:00 hrs
10.	Total Energy (Generation + India Import)	:	232.98	MKWh		Maximum							840	MW, at	21:00 hrs
	By Gas = 115.354 MKWh					By Oil = 12.679 MKWh									
	By Coal = 77.229 MKWh					By Hydro = 0.720 MKWh									
	By Solar = 2.472 MKWh														
11.	Total Gas Supplied	:	847.82	MMCFD		Energy							0	MKWh	
(D) Forecast of 22.03.24 (Today) Friday :															
01.	Maximum Demand	:	10700	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	13365	MW	(Generation end)	05.	Total Generation	:	241.26	MKWh					
03.	Reserve / Shortage	:	266												