

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2024					Day : Thursday				Date : 28.03.24					
Probable Maximum Demand : 13300 MW					Probable Maximum Generation : 13585 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 80.38 ft				Today = 80.26 ft				Rule Curve = 88.84 ft.	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.03.24 (Yesterday)		28.03.24 (Today)		27.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :					
					Day	Evening	Day	Evening	Gas/Coal/oil/ Water Limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date	
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	210	140	130	130	100	Gas Shortage			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110	80	Gas Shortage			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	5	5	5	5	103	Gas Shortage			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	420	450	450					
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling			
9	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	400	337	342	350	350					
10	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage			
11	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	300	335	335	335					
12	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	140	147	150	150	188	Gas Shortage			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	0	30					
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	41	25	8	83					
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x4.73	80	80	39	39	39	39					
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33					
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17					
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	70	17	105					
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	115	32	149					
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17					
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	60	45	195					
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	35	54	17	54					
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	52	54	54					
28	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	0	54	0	17					
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	35	0					
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	0	0	17					
31	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0					
32	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	0	0					
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	10	0	15	25					
35	Unique Meghnaghat 584MW CCPP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage			
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0		Test run			
Dhaka Zone Total				5828	5634	1910	2124	1866	2432	1370	740			
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Inadequate Water Level			
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.			
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0					
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	7	25	8	25					
40	Teknaf 20MW PP (SolarsTech)	Solar (IPP)	1x20	20	20	19	0	20	0					
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	19					
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	15	17	17					
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.			
44	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	210	213	210	211					
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	16	16	16					
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	34	34	34					
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	33	65	41	75					
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	32	10	20					
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	69	0	69					
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	0	17					
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
53	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	12	12	12	12					
54	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	25	12	25	25					
55	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	125	54	125					
57	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	284	275	270	285					
58	Matarani 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	864	936	800	930					
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	40	40		Test run			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				75	0	25	0		Test run			
Chattogram Zone Total				4404	4344	1751	1934	1679	2006	380	330			
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	28	37	30	40					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	217	207	220	225					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	295	330	315	330					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Gas Shortage			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	393	354	340	340					
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	36	8	36	159	Gas Shortage			
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	5	6	8					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	23	46	30	46					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		Test run			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34					
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	0	8	8					
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	0	25	25					
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	52	25	52					
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	0	18	18					
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	98	17	98	98					
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	26	38	60					
76	Bhainob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	13	17	17					
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	0	51	0	72					
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	30	11	30	30					
**	Impoprt (Tripura)	India		160	160	134	68	128	141					
Cumilla Zone Total				2937	2929	1421	1338	1421	1631	519	0			
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	145	180	101	150					
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	64	49	100					
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	32	56	100					
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	50	0	50	0					
84	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	0	6	0	6					
Mymensingh Zone Total				600	592	304	282	258	356	0	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.03.24 (Yesterday)		28.03.24 (Today)		27.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date			
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)					
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	Under maint.				
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	40	40	40		50	GT-4 Under maint.				
87	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	0	25	25	25							
88	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163							
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0							
90	Shahibazar GTPP Unit-8 & 9	Gas (PDB)	2x35	70	66	56	40	65	65							
91	Shahibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.				
92	Shahibazar 86MW PP (Shahibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0			Contact Expired				
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	135	132	135	135							
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	18	18	18							
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0							
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24							
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	300	300	300							
98	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	377	395	360	360							
99	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	345	355	340	340							
100	Shahibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run				
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	25	25	25							
Sylhet Zone Total				2472	2427	1391	1517	1495	1495	0	450					
102	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage				
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	39	0	50							
105	Gopalnani 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	4	74	0	70							
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	220	230	0	0	0	0							
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17							
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0							
109	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	97	0	100	0	0							
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0							
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0							
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	373	378	370	370							
113	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0							
**	Bheramara (HVDC)	India		1000	1000	913	770	940	940							
Khulna Zone Total				3241	3237	1387	1278	1427	1447	410	0					
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	64	110	110							
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	5	10	7	10							
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	132	132	130	135			62	ST under maint.			
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1080	930	1200	1200							
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	54							
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	150	150	150							
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220							
Barishal Zone Total				2265	2265	1637	1506	1817	1879	0	62					
a)	Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage				
b)	Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.				
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	25	40							
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	24							
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	44	50	90							
125	Katakhalii 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	50							
126	Katakhalii 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	42	0	42	42							
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	16	38							
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	214	173	180	210							
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage				
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage				
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	344	348	414	414	66		Gas Shortage				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	2	5	8							
133	Natore 52 MW PP (Rajbanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8							
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	0	35							
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	0	0	35							
136	Amnura 50 MW PP (Sinha)	HFO (NENP)	7x7.9	50	28	14	0	28	28							
137	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0							
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	920	1026	1000	1000							
Rajshahi Zone Total				3453	3431	1574	1639	1814	2022	577	100					
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage				
b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling				
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal Shortage				
140	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	42	6	42							
142	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
143	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0							
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	35	75							
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	36	0	30	0							
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	198	0	130	0							
Rangpur Zone Total				1030	950	446	317	409	317	159	85					
Sub-total: Plants in operation				26230	25809	11821.0	11935	12186	13585	3415	1767					
(B) Plants under long term maintenance/ contract expired																
147	Katottii 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				Contract Expired			
148	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0				Contract Expired			
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				Contract Expired			
150	Bosilia 108MW PP(CLCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Contract Expired			
Sub-Total: Plants under long term maintenance/ contract expired				614	0	0	0	0	0	0	0					
Gross Total				26844	25809	11821	11935	12186	13585	3415	1767					
(C) Actual data of 27.03.24 (Yesterday) Wednesday :																
01.	Max. Demand at eve. peak (Generation end)	:	11935	MW	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	11633	MW	at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	12152	MW	at =	14:00 hrs	Dhaka	4324	4324	0	Mymensingh	991	991	0		
04.	Minimum Generation (Generation end)	:	9037	MW	at =	6:00 hrs	Chattogram	1309	1309	0	Sylhet	452	452	0		
05.	Day-peak Generation (Generation end)	:	11821	MW	at =	12:00 hrs	Khulna	1509	1509	0	Rajshahi	392	392	0		
06.	Evening-peak Generation (Generation end)	:	11935	MW	at =	21:00 hrs	Rajshahi	1279	1279	0	Rangpur	647	647	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW	at =	21:00 hrs	Cumilla	730	730	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9405	MW	at =	5:00 hrs	Total							11633	11633	0
09.	Generation shortfall at evening peak due to :	:					13.	Fuel cost :	(a) Gas = 388140076 Taka				(c) Coal = 619267387 Taka			
a)	Gas/LF limitation	:	3056	MW		(b) Oil = 440837401 Taka				Total = 1448244864 Taka						
c)	Plants under shut down/ maintenance	:	1767	MW		Total							11633	11633	0	
b)	Coal supply Limitation	:	159	MW			14.	Maximum Temperature in Dhaka was : 33.2°C								
c)	Low water level in Kaptai lake	:	200	MW			15.	Export through East-West interconnections :								
10.	Total Energy (Generation + India Import)	:	271.89	MKWh			At evening peak-hour : 11821 MW, at 21:00 hrs									
	By Gas = 126.156 MKWh				By Oil =	24.160 MKWh	Maximum : 470 MW, at 19:30 hrs									
	By Coal = 93.255 MKWh				By Hydro =	0.726 MKWh	Energy : 0 MKWh									
	By Solar = 3.429 MKWh															
11.	Total Gas Supplied	:	957.26	MMCFD												
(D) Forecast of 28.03.24 (Today) Thursday :																
01.	Maximum Demand	:	13300	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	:	13585	MW	(Generation end)	05.	Total Generation : 297.58 MKWh									
03.	Reserve / Shortage	:	285	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 30.3°C									

* Captive Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation