

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month March, 2024				Day : Saturday				Date : 30.03.24				
Probable Maximum Demand : 12500 MW				Probable Maximum Generation : 14102 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 80.14 ft				Today = 80.02 ft				
				Rule Curve = 88.84 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.03.24 (Yesterday)		30.03.24 (Today)		29.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/ Water Limitation (MW)	Machines shut down (MW)		Description/ Remarks
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130	110	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	5	5	5	5	103	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	340	420	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	342	335	330	330			
10	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	200	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	300	330	0	330			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	147	150	150	150	185	Gas Shortage	
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	30			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	50	8	83			
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	31	39	39	39			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	115	32	149			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	195	45	195			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	17	53	17	54			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	52	54	54			
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	54	0	54			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	22	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	17			
31	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
32	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	17	15	25			
35	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage	
	Meghnaghat 589 MW CCGP(Summit)	Gas				0	0	0	0		Test run	
<b>Dhaka Zone Total</b>				<b>5828</b>	<b>5634</b>	<b>1690</b>	<b>2369</b>	<b>1786</b>	<b>2504</b>	<b>1297</b>	<b>740</b>	
36	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	1	0	5	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	5	25	8	25			
40	Teknaf 20MW PP (SolarsTech)	Solar (IPP)	1x20	20	20	17	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	19			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	10	17	17	17			
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
44	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	212	210	210	211			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	32	16	32			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	34	34	34			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	25	59	41	75			
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	42	15	20			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	25	0	69			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	17			
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
53	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
54	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	35	46	36	46			
55	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	25	143	54	140			
57	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	440	490	0	490			
58	Matarani 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	764	790	800	930			
	Cox's Bazar Wind PP	(Wind) (IPP)				7	13	40	40		Test run	
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				50	0	25	0		Test run	
<b>Chattogram Zone Total</b>				<b>4404</b>	<b>4344</b>	<b>1759</b>	<b>2047</b>	<b>1425</b>	<b>2263</b>	<b>380</b>	<b>330</b>	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	40	39	40	40			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	198	212	220	225			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	290	320	330	330			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Gas Shortage	
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	292	285	340	340			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	36	187	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	8			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	44	45	30	46			
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		Test run	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	6	8	8			
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	36	25	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	17	18	18			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	80	98	98	114			
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	58	38	60			
76	Bhainab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	0	76	0	76			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	53	30	30	30			
**	Impoprt (Tirpura)	India		160	160	116	132	128	141			
<b>Cumilla Zone Total</b>				<b>2937</b>	<b>2929</b>	<b>1315</b>	<b>1478</b>	<b>1446</b>	<b>1651</b>	<b>547</b>	<b>0</b>	
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	59	133	101	150			
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	100	49	100			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	65	56	100			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	31	0	50	0			
84	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
<b>Mymensingh Zone Total</b>				<b>600</b>	<b>592</b>	<b>198</b>	<b>304</b>	<b>258</b>	<b>356</b>	<b>0</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.03.24 (Yesterday)		30.03.24 (Today)		29.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)			
85	Fenchugonj CCGPP Phase-1	Gas (PDB)	2x32+1x33	97	70	28	41	43	43		29	Under maint.	
86	Fenchugonj CCGPP Phase-2	Gas (PDB)	2x35+1x35	104	90	29	29	40	40		61	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	11	25	25	25				
88	Kushiara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
90	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	58	65	65				
91	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0			Contact Expired	
93	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	132	132	135	135				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	18	18	18				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
97	Bibiayana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	315	300	300				
98	Bibiayana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	385	400	380	380				
99	Bibiayana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	387	385	340	340				
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
101	Fenchugonj 44MW (Energypirima)	Gas (NENP)	12*3.3+5*2	50	50	10	25	25	25				
<b>Sylhet Zone Total</b>					<b>2472</b>	<b>2427</b>	<b>1512</b>	<b>1615</b>	<b>1558</b>	<b>1558</b>	<b>0</b>	<b>420</b>	
102	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage	
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	30	0	40				
105	Gopalnani 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	30	0	70				
106	Khulna 225 MW CCGP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	22	17	18				
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	68	0	100	0	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	373	377	380	380				
113	Khulna 330 MW CCGP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	916	774	935	935				
<b>Khulna Zone Total</b>					<b>3241</b>	<b>3237</b>	<b>1357</b>	<b>1233</b>	<b>1432</b>	<b>1443</b>	<b>410</b>	<b>0</b>	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	6	8	7	10				
116	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	133	133	130	135		61	ST under maint.	
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	860	1244	1200	1200				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	54				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	250	250	250				
120	Bhola 220MW CCGP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
<b>Barishal Zone Total</b>					<b>2265</b>	<b>2265</b>	<b>1419</b>	<b>1920</b>	<b>1934</b>	<b>1979</b>	<b>0</b>	<b>61</b>	
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
121	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	25	40				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	20	0	25				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	50	90				
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	48	40	50				
126	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	16	42	42				
127	Santalaha 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	16	38				
128	Siraigonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	214	180	180	210				
129	Siraigonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
130	Siraigonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
131	Siraigonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	300	414	414	414				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	5	8				
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	16	8	16				
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35				
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	0	0	35				
136	Armura 50 MW PP (Sinha)	HFO (NENP)	7x7.9	50	50	0	0	28	28				
137	Siraigonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1012	1005	1000	1000				
<b>Rajshahi Zone Total</b>					<b>3453</b>	<b>3431</b>	<b>1574</b>	<b>1913</b>	<b>1814</b>	<b>2031</b>	<b>511</b>	<b>100</b>	
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
138	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200		74	Coal Shortage	
140	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	35	6	42				
142	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	35	75				
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0				
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	144	0	130	0				
<b>Rangpur Zone Total</b>					<b>1030</b>	<b>950</b>	<b>390</b>	<b>310</b>	<b>409</b>	<b>317</b>	<b>159</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>					<b>26230</b>	<b>25809</b>	<b>11214.0</b>	<b>13189</b>	<b>12062</b>	<b>14102</b>	<b>3304</b>	<b>1736</b>	
<b>(B) Plants under long term maintenance/ contract expired</b>													
147	Katottli 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
148	Hariapur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
<b>Sub-total: Plants under long term maintenance/ contract expired</b>					<b>614</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>					<b>26844</b>	<b>25809</b>	<b>11214</b>	<b>13189</b>	<b>12062</b>	<b>14102</b>	<b>3304</b>	<b>1736</b>	
<b>(C) Actual data of 29.03.24 (Yesterday) Friday :</b>													
01.	Max. Demand at eve. peak (Generation end)	:	13250 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	12717 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed	Zone	Demand MW	Supply MW	Load Shed		
03.	Highest Generation (Generation end)	:	13189 MW, at = 21:00 hrs	Dhaka	4384	4384	0	Mymensingh	1177	1119	58		
04.	Minimum Generation (Generation end)	:	9493 MW, at = 6:00 hrs	Chattogram	1318	1318	0	Sylhet	515	515	0		
05.	Day-peak Generation (Generation end)	:	11214 MW, at = 12:00 hrs	Khulna	1656	1656	0	Rajshahi	421	421	0		
06.	Evening-peak Generation (Generation end)	:	13189 MW, at = 21:00 hrs	Rajshahi	1320	1320	0	Rangpur	728	728	0		
07.	Evening Peak Load-shed (Sub-station end)	:	58 MW, at = 21:00 hrs	Cumilla	1198	1198	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10116 MW, at = 5:00 hrs	Total	12717	12659	58						
09.	Generation shortfall at evening peak due to :	:		13.	Fuel cost :	(a) Gas = 393307996 Taka	(c) Coal = 633887370 Taka						
a)	Gas/LF limitation	:	2945 MW		(b) Oil = 456729420 Taka	Total = 1483924785 Taka							
c)	Coal supply Limitation	:	159 MW	14.	Maximum Temperature in Dhaka was :	32.7°C							
b)	Low water level in Kaptai lake	:	200 MW	15.	Export through East-West interconnections :								
c)	Plants under shut down/ maintenance	:	1736 MW	At evening peak-hour	:	11214 MW, at 21:00 hrs							
10.	Total Energy (Generation + India Import)	:	274.51 MKWh	Maximum	:	650 MW, at 20:00 hrs							
	By Gas = 126.882 MKWh		By Oil = 25.036 MKWh	Energy	:	0 MKWh							
	By Coal = 94.911 MKWh		By Hydro = 0.711 MKWh										
	By Solar = 2.698 MKWh												
11.	Total Gas Supplied	:	952.33 MMCFD										
<b>(D) Forecast of 30.03.24 (Today) Saturday :</b>													
01.	Maximum Demand	:	12500 MW (Generation end)	04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	14102 MW (Generation end)	05.	Total Generation	:	260.17 MKWh						
03.	Reserve / Shortage	:	1602 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	:	32.7°C						

\* Captive Power \*\* Imported Power  
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation