

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month April, 2024				Day : Wednesday				Date : 03.04.24				
Probable Maximum Demand : 15300 MW				Probable Maximum Generation : 14344 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 79.56 ft				Today = 79.43 ft				
				Rule Curve = 87.60 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.04.24 (Yesterday)		03.04.24 (Today)		02.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/ Water Limitation MW	Machines shut down (MW)		Description/ Remarks
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	170	170	170	170			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	5	5	5	5	103	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	225	225			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	367	372	370	400			
10	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	325	333	335	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	148	146	330	330	189	Gas Shortage	
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	40	15	40			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	41	8	50			
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	39	32	40	40			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	145	32	149			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	245	47	242			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	17	132	60	135			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	34			
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	90	35	90			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	35	0	35			
31	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
32	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	13	13	15	15			
35	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage	
	Meghnaghat 589 MW CCGP(Summit)	Gas				50	150	150	150		Test run	
<b>Dhaka Zone Total</b>				<b>5828</b>	<b>5634</b>	<b>2068</b>	<b>2864</b>	<b>2150</b>	<b>2898</b>	<b>1191</b>	<b>740</b>	
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	60	30	30	170	Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	3	0	5	0	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	3	25	8	25			
40	Teknaf 20MW PP (SolarsTech)	Solar (IPP)	1x20	20	20	18	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	20	6	26			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	34	17	17			
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
44	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	211	211	210	211			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	16	16	16			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	0	0	0			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	32	51	51	51			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	48	65	70	80			
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	7	7			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	32	10	20			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	13	8	25			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	17			
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	24	15	17			
53	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
54	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	30	48	36	46			
55	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	31	144	54	150			
57	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	490	490	490	490			
58	Matarani 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	448	779	750	780			
	Cox's Bazar Wind PP	(Wind) (IPP)				37	21	40	40		Test run	
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				34	0	25	0		Test run	
<b>Chattogram Zone Total</b>				<b>4404</b>	<b>4344</b>	<b>1513</b>	<b>2084</b>	<b>1897</b>	<b>2077</b>	<b>350</b>	<b>330</b>	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	24	21	25	30			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	210	214	220	220			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	320	270	300	315			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Gas Shortage	
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	365	360	350	350			
64	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	8	8	195	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	32	44	40	45			
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		Test run	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	145	34	151			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	6	6	6	6			
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	15	15	25	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	52	25	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	19	20	20			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	98	17	100			
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	48	17	55			
76	Bhainob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	36	17	17			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	72	72	72	72			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	11	10	20	20			
**	Impoprt (Tripura)	India		160	160	124	136	128	141			
<b>Cumilla Zone Total</b>				<b>2937</b>	<b>2929</b>	<b>1352</b>	<b>1603</b>	<b>1381</b>	<b>1692</b>	<b>555</b>	<b>0</b>	
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	33	114	70	120	88	Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	99	49	100			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	103	56	100			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
84	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
<b>Mymensingh Zone Total</b>				<b>600</b>	<b>592</b>	<b>193</b>	<b>322</b>	<b>227</b>	<b>326</b>	<b>88</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.04.24 (Yesterday)		03.04.24 (Today)		02.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)			
85	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	Under maint.	
86	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	30	30		62	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	52	53	53	53				
88	Kushiara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	112	110	110	110				
89	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
90	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	57	60	60				
91	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0			Contact Expired	
93	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	132	135	135	140				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	18	20	20				
95	Sylhet 10 MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0		10	Gas Shortage	
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	25	16	25				
97	Bibiayana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	305	320	320				
98	Bibiayana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	404	367	400	400				
99	Bibiayana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	350	350	340	340				
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	43	47	45	45				
<b>Sylhet Zone Total</b>					<b>2472</b>	<b>2427</b>	<b>1560</b>	<b>1538</b>	<b>1572</b>	<b>1586</b>	<b>10</b>	<b>419</b>	
102	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCGP	Gas (NWPGLCL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage	
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	40	15	50				
105	Gopalnani 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	61	50	60				
106	Khulna 225 MW CCGP	HSD/ Gas (NWPGLCL)	1 x 150+1x75	230	230	0	0	0	0				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	18	17	17	18				
108	Madhumati 100 MW PP	HFO (NWPGLCL)	6x18.415	105	105	0	0	0	0				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	90	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	390	392	380	380				
113	Khulna 330 MW CCGP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	150	150	150				
**	Bheramara (HVDC)	India		1000	1000	747	490	940	650				
<b>Khulna Zone Total</b>					<b>3241</b>	<b>3237</b>	<b>1255</b>	<b>1150</b>	<b>1652</b>	<b>1308</b>	<b>410</b>	<b>0</b>	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	100	80	64	80				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	0	0	7	10				
116	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130		64	ST under maint.	
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1210	1200	1200				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	307	307	307	307				
120	Bhola 220MW CCGP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
<b>Barishal Zone Total</b>					<b>2265</b>	<b>2265</b>	<b>2018</b>	<b>1964</b>	<b>1945</b>	<b>2097</b>	<b>0</b>	<b>64</b>	
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	24	32	25	40				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	16	0	30				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	50	90				
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	32	40	50				
126	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	8	25	16	16				
127	Santalaha 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	16	35				
128	Siraigonj 225MW CCGP Unit-1	Gas (NWPGLCL)	1x150+1x75	210	210	170	160	190	200				
129	Siraigonj 225MW CCGP Unit-2	Gas (NWPGLCL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
130	Siraigonj 225MW CCGP Unit-3	Gas (NWPGLCL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
131	Siraigonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	348	310	330	330				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	10	10	5	8				
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8				
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	18	35	0	55				
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	1	35	0	55				
136	Armura 50 MW PP (Sinha)	HFO (NENP)	7x7.9	50	28	28	28	28	28				
137	Siraigonj 6.55 MW Solar	Solar (NWPGLCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1017	1010	1000	1000				
<b>Rajshahi Zone Total</b>					<b>3453</b>	<b>3431</b>	<b>1653</b>	<b>1813</b>	<b>1714</b>	<b>1945</b>	<b>511</b>	<b>100</b>	
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250		24	Coal Shortage	
140	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	33	6	6	50				
142	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	0	113	35	115	115				
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	37	0	30	0				
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	208	0	130	0				
<b>Rangpur Zone Total</b>					<b>1030</b>	<b>950</b>	<b>535</b>	<b>369</b>	<b>459</b>	<b>415</b>	<b>109</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>					<b>26230</b>	<b>25809</b>	<b>12147.0</b>	<b>13707</b>	<b>12997</b>	<b>14344</b>	<b>3224</b>	<b>1738</b>	

<b>(B) Plants under long term maintenance/ contract expired</b>													
147	Katottli 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
148	Hariapur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
<b>Sub-total: Plants under long term maintenance/ contract expired</b>					<b>614</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>					<b>26844</b>	<b>25809</b>	<b>12147</b>	<b>13707</b>	<b>12997</b>	<b>14344</b>	<b>3224</b>	<b>1738</b>	

  

<b>(C) Actual data of 02.04.24 (Yesterday) Tuesday :</b>												
01.	Max. Demand at eve. peak (Generation end)	: 15000 MW, at = 21:00 hrs	12.	<b>Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :</b>								
02.	Max. Demand at eve. peak (Sub-station end)	: 14378 MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	: 14008 MW, at = 22:00 hrs		Dhaka	5296	5096	200	Mymensingh	1247	1057	190	
04.	Minimum Generation (Generation end)	: 11162 MW, at = 8:00 hrs		Chattogram	1339	1199	140	Sylhet	486	411	75	
05.	Day-peak Generation (Generation end)	: 12147 MW, at = 12:00 hrs		Khulna	1807	1632	175	Barishal	463	463	0	
06.	Evening-peak Generation (Generation end)	: 13707 MW, at = 21:00 hrs		Rajshahi	1554	1384	170	Rangpur	851	766	85	
07.	Evening Peak Load-shed (Sub-station end)	: 1235 MW, at = 21:00 hrs		Cumilla	1335	1135	200					
08.	Minimum Generation Forecast up to 8:00 hrs.	: 11640 MW, at = 5:00 hrs						<b>Total</b>	<b>14378</b>	<b>13143</b>	<b>1235</b>	
09.	Generation shortfall at evening peak due to :							(a) Gas = 402462133 Taka	(c) Coal = 706421789 Taka		Taka	
a)	Gas/LF limitation	: 2945 MW		13.	Fuel cost :			(b) Oil = 665492279 Taka	Total = 1774376201 Taka		Taka	
c)	Coal supply Limitation	: 109 MW										
b)	Low water level in Kaptai lake	: 170 MW										
c)	Plants under shut down/ maintenance	: 1738 MW		14.	Maximum Temperature in Dhaka was :							
10.	Total Energy (Generation + India Import)	: 296.73 MKWh		15.	Export through East-West interconnections :							
	By Gas = 130.619 MKWh	By Oil = 36.405 MKWh			At evening peak-hour	: 12147 MW, at 21:00 hrs						
	By Coal = 104.954 MKWh	By Hydro = 0.834 MKWh			Maximum	: 584 MW, at 21:00 hrs						
	By Solar = 3.536 MKWh				Energy	: 0 MKWh						
11.	Total Gas Supplied	: 1011.50 MMCFD										

  

<b>(D) Forecast of 03.04.24 (Today) Wednesday :</b>												
01.	Maximum Demand	: 15300 MW (Generation end)	04.	Maximum Load-shed	: 905 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 14344 MW (Generation end)	05.	Total Generation	: 324.10 MKWh							
03.	Reserve / Shortage	: -956 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	: 36.5°C							

\* Captive Power \*\* Imported Power  
#Remarks: Highest Generation 1564