

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2024				Day : Thursday				Date : 04.04.24				
Probable Maximum Demand : 15000 MW				Probable Maximum Generation : 14782 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 79.43 ft				Today = 79.31 ft				
				Rule Curve = 87.40 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.04.24 (Yesterday)		04.04.24 (Today)		03.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/ Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	170	170	170	170			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	5	5	5	5	103	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	400	386	380	400			
10	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	318	330	335	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	315	318	330	330			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	41	40	15	40			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	16	8	50			
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	32	39	40	40			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	32	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	18	18	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	148	32	149			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	245	97	242			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	79	149	60	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	14	55	0	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	34			
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	126	35	126			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	35			
31	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
32	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	13	13	15	15			
35	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage	
	Meghnaghat 589 MW CCGP(Summit)	Gas				130	130	150	150		Test run	
Dhaka Zone Total				5828	5634	2243	2851	2210	2988	1002	740	
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	6	25	8	25			
40	Teknaf 20MW PP (SolarsTech)	Solar (IPP)	1x20	20	20	19	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	20	6	26			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	20	34	17	34			
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
44	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	213	211	210	211			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	16	16	16			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	0	0	0			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	51	51			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	55	74	82	80			
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	7	7			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	25	10	20			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	6	26	8	25			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	17			
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	34	17	17			
53	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
54	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	36	36	36	46			
55	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	45	126	54	150			
57	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	489	490	490	490			
58	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	775	752	750	780			
	Cox's Bazar Wind PP	(Wind) (IPP)				13	0	40	40		Test run	
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				63	0	25	0		Test run	
Chattogram Zone Total				4404	4344	1919	2001	1911	2094	380	330	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	22	23	25	30			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	210	201	220	220			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	300	295	300	315			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Gas Shortage	
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	285	285	350	350			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	43	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	6	6	6			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	25	28	40	45			
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	110	110		Test run	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	150	34	151			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	6	6			
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	15	15	25	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	34	25	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	7	20	20			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	114	17	114			
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	57	17	55			
76	Bhairoh 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	72	95	72	95			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	40	40	50	50			
**	Impoprt (Tirupura)	India		160	160	124	126	152	160			
Cumilla Zone Total				2937	2929	1333	1552	1545	1888	547	0	
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	35	109	70	120	93	Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	89	49	100			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	107	56	110			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0			
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	12	10	10			
Mymensingh Zone Total				600	592	190	317	237	340	93	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.04.24 (Yesterday)		04.04.24 (Today)		03.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)			
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	40	43	43		30	Under maint.	
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	28	30	30		62	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	53	53	53	53				
88	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	110	110	110				
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
90	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	25	30	30	30				
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0			Contact Expired	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	20	97	135	140				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	18	20	20				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0		10	Gas Shortage	
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	25				
97	Bibiayana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	315	320	320				
98	Bibiayana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	401	389	400	400				
99	Bibiayana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	370	362	360	370				
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	50	0	0	0			Test run	
101	Fenchugonj 44MW (Energypima)	Gas (NENP)	12*3.3+5*2	50	50	47	47	47	47				
Sylhet Zone Total					2472	2427	1483	1505	1564	1588	10	422	
102	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWPGLCL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage	
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	22	34	15	50				
105	Gopalnani 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	32	59	50	60				
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGLCL)	1 x 150+1x75	230	230	0	0	0	0				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	18				
108	Madhumati 100 MW PP	HFO (NWPGLCL)	6x18.415	105	105	0	0	0	0				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	93	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	380	386	385	385				
113	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	50	120	150	150				
**	Bheramara (HVDC)	India		1000	1000	921	634	940	650				
Khulna Zone Total					3241	3237	1515	1250	1657	1313	410	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	110	64	110				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	9	10	7	10				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130		64	ST under maint.	
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	950	1244	1244	1244				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	17				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	250	307	307	307				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2265	2265	1608	2038	1989	2038	0	64	
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	14	32	32	40				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	18	0	30				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	96	50	96				
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	50	40	50				
126	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	34	34	34	34				
127	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	38	30	35				
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGLCL)	1x150+1x75	210	210	164	166	190	200				
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGLCL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGLCL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	289	333	380	380		81	Gas Shortage	
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	10	5	10				
133	Natore 52 MW PP (Rajkanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	95	0	95				
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	70	0	70				
136	Armura 50 MW PP (Sinha)	HFO (NENP)	7x7.9	50	28	35	35	35	35				
137	Sirajgonj 6.55 MW Solar	Solar (NWPGLCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1008	1021	1000	1000				
Rajshahi Zone Total					3453	3431	1623	2006	1810	2083	592	100	
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250		24	Coal Shortage	
140	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2*3	113	113	6	85	6	85				
142	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	112	35	115				
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	35	0	30	0				
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	203	0	130	0				
Rangpur Zone Total					1030	950	501	447	459	450	109	85	
Sub-total: Plants in operation					26230	25809	12415.0	13967	13382	14782	3143	1741	
(B) Plants under long term maintenance/ contract expired													
147	Katoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
148	Hariapur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-total: Plants under long term maintenance/ contract expired					614	0	0	0	0	0	0	0	
Gross Total					26844	25809	12415	13967	13382	14782	3143	1741	
(C) Actual data of 03.04.24 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	: 15250 MW, at = 21:00 hrs		12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 14598 MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 14091 MW, at = 22:00 hrs		Dhaka	5457	5232	225	Mymensingh	1255	1075	180		
04.	Minimum Generation (Generation end)	: 11640 MW, at = 7:00 hrs		Chattogram	1399	1229	170	Sylhet	533	473	60		
05.	Day-peak Generation (Generation end)	: 12415 MW, at = 12:00 hrs		Khulna	1717	1587	130	Barishal	455	425	30		
06.	Evening-peak Generation (Generation end)	: 13967 MW, at = 21:00 hrs		Rajshahi	1550	1410	140	Rangpur	876	766	110		
07.	Evening Peak Load-shed (Sub-station end)	: 1225 MW, at = 21:00 hrs		Cumilla	1356	1176	180						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 11689 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :	:						Total	14598	13373	1225		
a)	Gas/LF limitation	: 2834 MW		13.	Fuel cost :	(a) Gas = 401932185 Taka		(c) Coal = 712962239 Taka		Taka			
d)	Coal supply Limitation	: 109 MW				(b) Oil = 738480033 Taka		Total = 1853374456 Taka		Taka			
b)	Low water level in Kaptai lake	: 200 MW											
c)	Plants under shut down/ maintenance	: 1741 MW		14.	Maximum Temperature in Dhaka was : 36.0°C								
10.	Total Energy (Generation + India Import)	: 306.30 MKWh		15.	Export through East-West interconnections :								
	By Gas = 131.673 MKWh	By Oil = 40.259 MKWh		At evening peak-hour		: 12415 MW, at 21:00 hrs							
	By Coal = 106.269 MKWh	By Hydro = 0.713 MKWh		Maximum		: 830 MW, at 19:30 hrs							
	By Solar = 3.555 MKWh			Energy		: 0 MKWh							
11.	Total Gas Supplied	: 988.84 MMCFD											
(D) Forecast of 04.04.24 (Today) Thursday :													
01.	Maximum Demand	: 15000 MW (Generation end)		04.	Maximum Load-shed : 286 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 14782 MW (Generation end)		05.	Total Generation : 326.06 MKWh								
03.	Reserve / Shortage	: -218 MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 30.3°C								

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation