

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date: 5-Apr-24

Page-2

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | | Peak Hour Generation | | Enervor Generated | Remarks |
|------------------------------|--|----------------|--------------------|----------------------------|-------------|----------------------|---------|------------------------|---------|
| | | | | MW | MW | MW | KWH | | |
| | | | | Unit No. X Capacity | | | | | |
| 1 | Ghorasal Repowered CCGP-Unit-3 (GT) | PDB | 1280 | 280 | 0 | 0 | 0 | Under maint. | |
| 2 | Ghorasal Repowered CCGP Unit-4 | PDB | 1210 | 180 | 170 | 408938 | 0 | | |
| 3 | Ghorasal TPP Unit-5 | PDB | 1210 | 190 | 170 | 415800 | 0 | | |
| 4 | Ghorasal 365 MW CCGP Unit-7 | QRPB | 1243*1122 | 365 | 0 | 0 | 0 | Air Compressor problem | |
| 5 | Ghorasal 78.5 MW PP(MAX) | QRPB | 240 | 0 | 0 | 0 | 0 | Contract Expired | |
| 6 | Ghorasal 108 MW PP (Regent) | IPP | 343*35 | 5 | 108 | 5 | 133318 | Gas shortage | |
| 7 | Haripur GTTP | SBU, PDB | 232 | 20 | 0 | 0 | 0 | Under maint. | |
| 8 | Haripur 412 MW CCGP | EGCB | 1273*1139 | 400 | 365 | 8776800 | 0 | Machine problem | |
| 9 | Haripur 360 MW CCGP(HPL) | IPP | 1235*1125 | 0 | 0 | 0 | 0 | Contract Expired | |
| 10 | Meghnaghat 450 MW CCGP(MPL) | IPP | 2150*1150 | 450 | 225 | 5100500 | 0 | GT-2 under maint | |
| 11 | Meghnaghat 100 MW CCGP | NENP | 1210 | 0 | 0 | 0 | 0 | Contract Expired | |
| 12 | Meghnaghat CCGP(Summit) | IPP | 2110*1110 | 335 | 309 | 7355316 | 0 | Gas shortage | |
| 13 | Madanganj 102 PP(Summit) | NENP | 617 | 102 | 0 | 0 | 0 | Contract Expired | |
| 14 | Madanganj-55 MW PP(Summit) | IPP | 3*17.08+111.3 | 55 | 40 | 302929 | 0 | Fuel shortage | |
| 15 | Keraniganj 100 MW PP (Powerpac) | NENP | 813.45 | 75 | 13 | 270000 | 0 | Fuel shortage | |
| 16 | Narshingdi 22 MW PP (Doreen) | SIPP, REB | 82.90 | 22 | 0 | 0 | 0 | Contract Expired | |
| 17 | 210 MW Siddhirganj PP | PDB | 1210 | 115 | 0 | 0 | 0 | Under maint. | |
| 18 | Siddhirganj 2120 MW GTTP | EGCB | 2105 | 210 | 0 | 0 | 0 | Gas shortage | |
| 19 | Siddhirganj 109 PP(Dutch Bangla) | NENP | 128.9 | 100 | 0 | 0 | 0 | Contract Expired | |
| 20 | Siddhirganj 335 MW CCGP | EGCB | 1217+118 | 335 | 328 | 7860985 | 0 | Fuel shortage | |
| 21 | Gasapur 102 MW PP (Digital Power) | IPP | 128.924 | 91 | 102 | 91 | 1465200 | Fuel shortage | |
| 22 | Katpatti 52 MW PP (Sinha) | IPP | 77.9 | 0 | 0 | 0 | 0 | Fuel shortage | |
| 23 | Kamalaghat 54 MW PP(Banco Energy) | IPP | 318 | 54 | 17 | 90720 | 0 | Fuel shortage | |
| 24 | Kodda 150 MW PP | BPDB-RPCL | 9*17.06 | 149 | 145 | 1170240 | 0 | | |
| 25 | Manikganj 55 MW PP (Northern) | IPP | 319.3 | 55 | 55 | 270636 | 0 | | |
| 26 | Nabaganj 55 MW PP (Southern power) | IPP | 319.3 | 55 | 35 | 185492 | 0 | Fuel shortage | |
| 27 | Bosila 108 MW PP(PLC) | IPP | 128.775+113.5 | 0 | 0 | 0 | 0 | | |
| 28 | Summit Power (Madhabdi+Ashulia) | SIPP, REB | 3*3.67+4*8.73 | 80 | 37 | 857400 | 0 | Engine problem | |
| 29 | Maona 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 33 | 777240 | 0 | | |
| 30 | Rugganj 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 21 | 471100 | 0 | Engine problem | |
| 31 | Gasapur 52 MW PP | RPCL | 819.9 | 25 | 25 | 517920 | 0 | Fuel shortage | |
| 32 | Tongi 80 MW GTTP | PDB | 1105 | 105 | 0 | 0 | 0 | Gas shortage | |
| 33 | Kodda 300 MW PP Unit-2 (Summit) | IPP | 1817.076 | 300 | 195 | 1889345 | 0 | Fuel shortage | |
| 34 | Bramhangon 100 MW PP (Aggreko) | IPP | 114.0959 | 0 | 0 | 0 | 0 | Contract Expired | |
| 35 | Aurash 100MW PP (Aggreko) | IPP | 0.8523+0.9591 | 0 | 0 | 0 | 0 | Contract Expired | |
| 36 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 818.4524 | 149 | 132 | 1400886 | 0 | Fuel shortage | |
| 37 | Gasapur 100 MW PP | RPCL | 617.5 | 105 | 105 | 1536000 | 0 | | |
| 38 | Meghnaghat 104 MW PP (OPCL) | IPP | 18.56 | 104 | 52 | 992640 | 0 | Fuel shortage | |
| 39 | Manikganj 162MW PP(MPGL) | IPP | 9*18 | 162 | 90 | 565920 | 0 | Fuel shortage | |
| 40 | Spectra Solar Plant Ltd | IPP | 35 | 35 | 0 | 178303 | 0 | Fuel shortage | |
| 41 | Kanchan Purbasol Power Generation Ltd. | IPP | 182.3 | 55 | 0 | 383520 | 0 | Fuel shortage | |
| 42 | Meghnaghat Uniques power | IPP | 586 | 584 | 0 | 0 | 0 | On test. | |
| 43 | Summit Meghnaghat-2 589 MW(Gas) | IPP | 589 | 0 | 130 | 3113182 | 0 | On test. | |
| Dhaka area Total | | | | 5634 | 2788 | 53910832 | | | |
| 39 | Chattogram TPP-1 | PDB | 1210 | 180 | 0 | 0 | 0 | Gas shortage | |
| 40 | Chattogram TPP-2 | PDB | 1210 | 180 | 0 | 0 | 0 | Gas shortage | |
| 41 | Razzan 25 MW PP | RPCL | 318.9 | 25 | 25 | 212416 | 0 | | |
| 42 | Teknaf 20MW PP (SolarTech) | IPP | 20 | 20 | 0 | 118125 | 0 | | |
| 43 | Patenga 50MW PP (Baraka) | IPP | 8*6.98 | 50 | 6 | 104640 | 0 | Fuel shortage | |
| 44 | Kapla Hydro Unit-1,2,3,4,5 | PDB | 2*40+3*50 | 230 | 60 | 861460 | 0 | Low water level | |
| 45 | Sikalbaha 225MW | PDB | 1150+175 | 225 | 215 | 4952098 | 0 | | |
| 46 | Sikalbaha Peaking | PDB | 1150 | 0 | 0 | 0 | 0 | Under maint. | |
| 47 | Sikalbaha 105 MW PP (Baraka Sikalbah) | IPP | 6*17.5 | 105 | 17 | 499309 | 0 | Fuel shortage | |
| 48 | Hathazari 100 MW peaking PP | PDB | 11*8.9 | 98 | 74 | 1270176 | 0 | Engine problem | |
| 49 | Dohazari-Kalaish 100 MW Peaking | PDB | 6*17 | 102 | 51 | 1078536 | 0 | Engine problem | |
| 50 | Judah 100 MW Unit-1 (Acorn) | NENP | 813.45 | 100 | 36 | 1041720 | 0 | Fuel shortage | |
| 51 | Judah 100 MW Unit-3 (Acorn) | IPP | 813.5 | 100 | 0 | 0 | 0 | Fuel shortage | |
| 52 | Barabunda 22 MW PP (Regent) | SIPP, PDB | 82.90 | 22 | 5 | 110544 | 0 | Engine problem | |
| 53 | Malancha, Cig, EPZ (United) | IPP | 5*8.73+3*9.34 | 0 | 24 | 654720 | 0 | | |
| 54 | Chattogram 108 MW PP (ECPV) | IPP | 167 | 108 | 12 | 101760 | 0 | Fuel shortage | |
| 55 | Kapla 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 27242 | 0 | | |
| 56 | Anwara 300 MW PP (United) | IPP | 1717+24 | 300 | 16 | 386400 | 0 | Fuel shortage | |
| 57 | Jodis Power | IPP | 3*18.55+13.6 | 54 | 17 | 123396 | 0 | Fuel shortage | |
| 58 | Karnaphuli Power Ltd. | IPP | 18.4156+6.5 | 110 | 34 | 500980 | 0 | Fuel shortage | |
| 59 | Judah unit-2 (Acorn) | IPP | 813.6 | 100 | 11 | 282240 | 0 | Fuel shortage | |
| 60 | Anlima Energy Ltd. | IPP | 6*21.2 | 116 | 34 | 386400 | 0 | Fuel shortage | |
| 61 | Minshara 150 MW | BPDB-RPCL | 18.59 | 163 | 144 | 903272 | 0 | Fuel shortage | |
| 62 | SS Power | SS Power | 2612 | 1224 | 480 | 11770968 | 0 | Coal shortage | |
| 63 | Cox's Bazar Wind | IPP | 65 | 0 | 0 | 84960 | 0 | On test. | |
| 64 | Matarbari 2*600 MW (CPGCL) | CPGCL | 0 | 575 | 565 | 13563636 | 0 | | |
| 65 | Minshara 150 MW (Gas) | BPDB-RPCL | 18.59 | 0 | 0 | 0 | 0 | On test. | |
| 66 | Sonagazi 75 MW Solar Plant | EGCB | 75 | 0 | 0 | 271818 | 0 | | |
| Chattogram area Total | | | | 4344 | 1836 | 39306556 | | | |
| 67 | Ashuganj TPP Unit-3 | APSCl | 1150 | 0 | 0 | 0 | 0 | Contract Expired | |
| 68 | Ashuganj TPP Unit-4 | APSCl | 1150 | 0 | 0 | 0 | 0 | Contract Expired | |
| 69 | Ashuganj TPP Unit-5 | APSCl | 1150 | 0 | 0 | 0 | 0 | Contract Expired | |
| 70 | Ashuganj 225 MW CCGP | APSCl | 1142+175 | 221 | 191 | 5209000 | 0 | FGMO | |
| 71 | Ashuganj 450 MW CCGP(North) | APSCl | 1360 | 360 | 300 | 2415100 | 0 | Gas shortage | |
| 72 | Ashuganj 450 MW CCGP(South) | APSCl | 1360 | 360 | 305 | 7289000 | 0 | FGMO | |
| 73 | Ashuganj 420 MW CCGP(East) | APSCl | 2841+116*1 | 400 | 290 | 7157000 | 0 | Gas shortage | |
| 74 | Ashuganj 50 MW PP | APSCl | 14*3.968 | 45 | 21 | 503568 | 0 | Gas shortage | |
| 75 | Ashuganj 55 MW PP (Precision) | QRPP | 0 | 55 | 46 | 685440 | 0 | Gas shortage | |
| 76 | Ashuganj 195 MW PP (APSCl-United) | IPP | 20*9.73+116 | 195 | 8 | 83636 | 0 | Gas shortage | |
| 77 | Ashuganj 151 MW PP (Midland) | IPP | 619.34 | 51 | 5 | 1161668 | 0 | | |
| 78 | Ashuganj 150 MW PP (Midland) | IPP | 23*7.15 | 150 | 6 | 150545 | 0 | Fuel shortage | |
| 79 | Titas 50 MW Peaking PP | PDB | 6*8.92 | 52 | 35 | 828656 | 0 | Engine problem | |
| 80 | Chandpur 150 MW CCGP | PDB | 1106+157 | 163 | 0 | 0 | 0 | Under maint. | |
| 81 | Chandpur 200 MW (Desh Energy) | IPP | 1218.4 | 200 | 155 | 1524960 | 0 | Fuel shortage | |
| 82 | Feni 11 MW PP (Doreen) | SIPP, REB | 4.90 | 11 | 126 | 180380 | 0 | Engine problem | |
| 83 | Impqonj (Tripura) | Imported power | 0 | 160 | 126 | 2898240 | 0 | | |
| 84 | Jangalia 33 MW PP (Summit) | SIPP, PDB | 4*8.73 | 33 | 0 | 303700 | 0 | Engine problem | |
| 85 | Jangalia 52 MW PP (Lakdanavi) | IPP | 6*8.92 | 52 | 51 | 858638 | 0 | | |
| 86 | Cumilla 25 MW PP (Summit) | SIPP, REB | 3*3.67+2*6.97 | 25 | 20 | 374050 | 0 | Engine problem | |
| 87 | Daudkandi 200 MW PP (B.Trac) | IPP | 1541.4 | 0 | 0 | 0 | 0 | | |
| 88 | Feni Lanka Power | IPP | 7*18.415+19.78 | 114 | 114 | 1450080 | 0 | | |
| 89 | Chowmuhani 113 MW | IPP | 12*9.78+2*3.1 | 113 | 48 | 615720 | 0 | Fuel shortage | |
| 90 | Bhairab 54.5 MW | IPP | 3*18.2 | 54 | 17 | 441720 | 0 | Engine problem | |
| 91 | Chandpur 115 (Doreen) | IPP | 4*18.5+2*22.5 | 115 | 95 | 874560 | 0 | Fuel shortage | |
| Cumilla Area Total | | | | 2929 | 1687 | 35015841 | | | |
| 92 | RPCL 210MW CCGP | IPP | 4*35+170 | 202 | 105 | 1514880 | 0 | Gas shortage | |
| 93 | Jamalpur 95 MW PP(Powerpac) | IPP | 0 | 0 | 0 | 0 | 0 | Under maint. | |
| 94 | Sarishabari 3 MW Solar Plant | IPP | 13 | 3 | 0 | 13400 | 0 | | |
| 95 | Mymensingh 200 MW PP (United) | IPP | 9*78*21 | 200 | 116 | 1228800 | 0 | Fuel shortage | |
| 96 | Jamalpur 115 MW PP (United) | IPP | 9*78*12 | 115 | 88 | 1068000 | 0 | Fuel shortage | |
| 97 | Sutakchi 50 MW Solar PP | IPP | 50 | 50 | 0 | 284250 | 0 | | |
| 98 | Tangali Pali Power Gen 22 MW | IPP | 4*6.7 | 22 | 24 | 332160 | 0 | Fuel shortage | |
| Mymensingh Area Total | | | | 582 | 333 | 4421490 | | | |
| 99 | Fenchugani CCGP Phase-1 | PDB | 2*32+133 | 70 | 40 | 955000 | 0 | Machine problem | |
| 100 | Fenchugani CCGP Phase-2 | PDB | 2*35+135 | 90 | 30 | 684320 | 0 | Machine problem | |
| 101 | Kushaura 163 MW CCGP (KP) | IPP | 1109+154 | 163 | 110 | 2521636 | 0 | ST under maint. | |
| 102 | Shahbazar 330 MW CCGP | PDB | 3110 | 330 | 0 | 0 | 0 | Under maint. | |
| 103 | Fenchugani 51 MW PP (Barakatullah) | RPP | 19*2.90 | 51 | 53 | 1232400 | 0 | | |
| 104 | Fenchugani 44 MW (Energyprima) | NENP | 12*3.3+5.2 | 50 | 44 | 1063368 | 0 | Engine problem | |
| 105 | Hobiganj 11 MW PP Confidence-E | SIPP, REB | 4*2.90 | 11 | 0 | 0 | 0 | Gas shortage | |
| 106 | Shahbazar GTTP Unit-8 & 9 | PDB | 2*35 | 66 | 26 | 580800 | 0 | Unit-8 Under Maint. | |
| 107 | Shahbazar 86 MW PP (Shahbazar) | RPP | 32*2.90 | 86 | 0 | 0 | 0 | Contract Expired | |
| 108 | Shahbazar 100 MW GTTP | PDB | 1100 | 100 | 100 | 897218 | 0 | | |
| 109 | Sylhet 225 MW CCGP | PDB | 1142+189 | 231 | 132 | 3228760 | 0 | ST under maint. | |
| 110 | Sylhet 20 MW GTTP | PDB | 120 | 20 | 18 | 434000 | 0 | | |
| 111 | Sylhet 50 MW PP (EPL) | NENP | 27*2 | 0 | 0 | 0 | 0 | Contract Expired | |
| 112 | Shajhanulla 25 MW PP | SIPP, REB | 3*9.34 | 25 | 17 | 403872 | 0 | Engine problem | |
| 113 | Bibiana-II 341 MW CCGP (Summit) | IPP | 1222+1119 | 341 | 295 | 7256000 | 0 | FGMO | |
| 114 | Bibiana-III 400 MW CCGP | PDB | 2851+1341 | 400 | 400 | 8733000 | 0 | FGMO | |
| 115 | Sylhet 10MW PP (Desh) | RPP | 6*1.95 | 10 | 0 | 0 | 0 | Contract Expired | |
| 116 | Bibiana South 400 MW | PDB | 400 MW | 363 | 360 | 843400 | 0 | FGMO | |
| Sylhet Area Total | | | | 2427 | 1624 | 36483774 | | | |
| 117 | Bheramara GTTP Unit-3 | PDB | 120 | 16 | 0 | 0 | 0 | Reserve | |
| 118 | Bheramara (HVDC) | Imported power | 2500 | 1000 | 633 | 19611636 | 0 | | |
| 119 | Khulna 115 PP MW (KPCL-2) | NENP | 717 | 115 | 0 | 0 | 0 | Contract Expired | |
| 120 | Fariapur 50 MW Peaking PP | PDB | 6*6.99 | 54 | 40 | 555840 | 0 | Engine problem | |
| 121 | Khulna 225 MW CCGP | NWP/CPCL | | | | | | | |