

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2024		Day : Saturday				Date : 06.04.24						
Probable Maximum Demand :		15500 MW		Probable Maximum Generation :		15048 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 79.08 ft		Today = 78.96 ft		Rule Curve = 87.00 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.04.24 (Yesterday)		06.04.24 (Today)		Gen. shortfall for : Gas/Coal/oil/Water Limitation (MW)	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	170	170	170	170			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPL	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	5	5	5	5	103	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	0		
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Under maint	
8	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Harijpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	400	360	365	381	400	210	Gas Shortage	
10	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	0		
11	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	327	328	335	335			
12	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	318	309	330	330			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	15	40			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	91	50	91			
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power.(Madhabdi+Ashula)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	40	37	40	40			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	21	21	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	105	17	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	145	32	145			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	195	97	242			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	54	132	60	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	16	52	50	51			
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	90	35	126			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	17	35			
31	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
32	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	13	13	15	15			
35	Unique Meghnaghat 584MW CCPP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage	
	Meghnaghat 589 MW CCPP(Summit)	Gas				130	130	130	130		Test run	
Dhaka Zone Total				5828	5634	2101	2788	2283	3002	1002	965	
36	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	60	30	60	170	Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25			
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	6	6	6			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	34			
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
44	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	213	215	211	211			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	16	16	16			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	0	0	0			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	51	51			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	34	74	42	82			
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	7	7			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			27	24	15	25			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12			
51	Sikalbaha 54 MW PP(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	19			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34			
53	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	12	11	12	12			
54	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	48	36	48	48			
55	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	34	17	17			
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	45	144	54	150			
57	Chattogram 2*621MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	490	490	490	490			
58	Metarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	552	565	551	551			
	Cox's Bazar Wind PP	(Wind) (IPP)				6	0	40	40			Test run
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				31	0	25	0			Test run
Chattogram Zone Total				4404	4344	1631	1836	1682	1890	350	330	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	20	21	25	25			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	211	191	220	220			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	325	305	300	300			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	6	300	300	300	60	Gas Shortage	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	360	290	280	280			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	8	0	8	187	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	28	35	36	42			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	155	34	151			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	6	6			
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	15	0	15	15			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	51	25	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	114	17	114			
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	27	48	17	55			
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	27			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	0	95	72	95			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	44	46	44	44			
**	Impport (Tiptura)	India		160	160	128	126	152	160			
Cumilla Zone Total				2937	2929	1359	1887	1637	1971	247	0	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	105	70	120	97	Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	88	49	100			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	116	56	110			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	35	0	50	0			
84	Tangali 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	24	10	24			
Mymensingh Zone Total				600	592	192	333	237	354	97	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.04.24 (Yesterday)		06.04.24 (Today)		05.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	40	40	43	43		30	Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	50	53	53	53				
88	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	110	110	110				
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
90	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	25	25	30	30				
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0			Contract Expired	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	133	132	135	140				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	20	20				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0	10		Gas Shortage	
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	17	17	16	25				
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	295	320	320				
98	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	390	400	400	400				
99	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	360	360	360	370				
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	100	0	0			Test run	
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	47	44	47	47				
Sylhet Zone Total				2472	2427	1537	1624	1564	1588	10	420		
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
104	Fardipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	17	40	22	50				
105	Gopelganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	30	53	50	60				
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
107	Russha 105 MW PP (Oron russha)	HFO (IPP)	6x18.445	105	105	72	71	70	70				
108	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
109	Mongla Oron 100 MW Solar PP	Solar (IPP)		100	100	71	0	100	0				
110	Khulna 115 MW PP (RPL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
111	Nosara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
112	Maitree Super Thermal 1320 MW PP (J-1)	Coal (BIFPCL)	1x617	617	617	382	382	385	385				
113	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	50	150	0	150				
**	Bheramara (HVDC) India			1000	1000	918	633	936	647				
Khulna Zone Total				3241	3237	1540	1329	1563	1362	410	0		
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	48	80	48	80				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	0	9	7	10				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130		64	ST under maint.	
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1110	1244	900	1244				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	17				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	230	307	200	307				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total				2265	2265	1738	2007	1522	2008	0	64		
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	27	32	35	40				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	26	0	30				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	95	50	96				
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	10	47	40	50				
126	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	25	34	34	34				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	22	28	30	30				
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	179	174	190	200				
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	350	414	380	380				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	10	11	5	10				
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	75	0	95				
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	28	70	35	70				
136	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	35	35	35	35				
137	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1216	1189	1400	1400				
Raishahi Zone Total				3453	3431	1906	2238	2248	2478	511	100		
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250	24		Coal Shortage	
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	71	6	70				
142	Saidour 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara, Tabulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
144	Thakurgaon 119MW PP (Energybase)	HFO (IPP)	6*20	118	118	0	75	35	75				
145	Lalmochhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	11	0	30	0				
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	108	0	130	0				
Rangpur Zone Total				1030	950	381	396	459	395	109	85		
Sub-total: Plants in operation				26230	25809	12385.0	14438	13195	15048	2736	1964		

(B) Plants under long term maintenance/ contract expired												
147	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired
148	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired
150	Bossila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired
Sub-Total: Plants under long term maintenance/ contract expired				814	0	0	0	0	0	0	0	
Gross Total				26844	25809	12385	14438	13195	15048	2736	1964	

(C) Actual data of 05.04.24 (Yesterday) Friday :												
01.	Max. Demand at eve. peak (Generation end)	: 15300 MW, at = 21:00 hrs		12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 14606 MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	: 14438 MW, at = 21:00 hrs		Dhaka	4986	4936	50	Mymensingh	1256	1106	150	
04.	Minimum Generation (Generation end)	: 11832 MW, at = 8:00 hrs		Chattogram	1432	1302	130	Sylhet	450	450	0	
05.	Day-peak Generation (Generation end)	: 12385 MW, at = 12:00 hrs		Khulna	1875	1690	185	Barishal	477	477	0	
06.	Evening-peak Generation (Generation end)	: 14438 MW, at = 21:00 hrs		Rajshahi	1743	1580	163	Rangpur	930	830	100	
07.	Evening Peak Load-shed (Sub-station end)	: 823 MW, at = 21:00 hrs		Cumilla	1457	1412	45					
08.	Minimum Generation Forecast up to 8:00 hrs.	: 11791 MW, at = 5:00 hrs						Total	14606	13783	823	
09.	Generation shortfall at evening peak due to :											
	a) Gas/LF limitation	: 2457 MW		13.	Fuel cost :	(a) Gas = 407070050 Taka		(c) Coal = 721871969 Taka				
	d) Coal supply Limitation	: 109 MW				(b) Oil = 765290420 Taka		Total = 1894232439 Taka				
	b) Low water level in Kaptai lake	: 170 MW		14.	Maximum Temperature in Dhaka was :	34°C						
	c) Plants under shut down/ maintenance	: 1964 MW		15.	Export through East-West interconnections :							
10.	Total Energy (Generation + India Import)	: 308.69 MCKWh			At evening peak-hour	: 12385 MW, at 21:00 hrs						
	By Gas = 133.894 MCKWh	By Oil = 41.873 MCKWh			Maximum	: 780 MW, at 8:00 hrs						
	By Coal = 107.124 MCKWh	By Hydro = 0.861 MCKWh			Energy	: 0 MCKWh						
	By Solar = 2.347 MCKWh			11.	Total Gas Supplied	: 1074.66 MCMCFD						

(D) Forecast of 06.04.24 (Today) Saturday :												
01.	Maximum Demand	: 15500 MW (Generation end)		04.	Maximum Load-shed	: 349 MW At evening peak (Sub-station end)						
02.	Maximum Generation	: 15048 MW (Generation end)		05.	Total Generation	: 331.40 MCKWh						
03.												