

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2024				Day : Monday				Date : 08.04.24				
Probable Maximum Demand : 14300 MW				Probable Maximum Generation : 15568 MW				Rule Curve = 86.60 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 78.72 ft				Today = 78.48 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.04.24 (Yesterday)		08.04.24 (Today)		07.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/ Water Limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	190	190	190	190			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	5	5	5	5	103		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	450	450		225	Under maint.
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	330	411	380	410			
10	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	280	329	335	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	267	318	330	330			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	15	40			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	91	50	91			
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	39	39	39	39			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	26	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	149	32	145			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	197	97	242			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	17	114	60	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	50	51	53	53			
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	54	0	54			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0			
31	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
32	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	13	13	15	15			
35	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584		Gas Shortage
	Meghnaghat 589 MW CCGP(Summit)	Gas				150	150	150	150			Test run
Dhaka Zone Total				5828	5634	1952	2832	2497	3191	1002	965	
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Inadequate Water Level
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	180	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25			
40	Teknaf 20MW PP (SolarsTech)	Solar (IPP)	1x20	20	20	13	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	6			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
44	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	211	211	211	211			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	16	16	16			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	0	0	0			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	51	51			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	40	25	40			
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	7	7			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			8	25	15	25			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	13	12	12			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	36			
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
53	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	11	11	12	12			
54	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	48	58	48	70			
55	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	145	54	150			
57	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	489	269	490	490			
58	Matarani 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	725	660	730	730			
	Cox's Bazar Wind PP	(Wind) (IPP)				0	1	40	40			Test run
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				30	0	25	0			Test run
Chattogram Zone Total				4404	4344	1744	1634	1856	2002	380	330	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	20	25	25			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	219	200	220	220			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	270	240	300	300			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	280	280	330	330			
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	270	230	280	280			
64	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	8	195			Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	6	6	6			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	33	37	33	33			
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	152	34	151			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	9	6	6			
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	30	30	30			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	51	25	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	17	20	20			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	70	34	98			
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	58	17	58			
76	Bhainob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	35			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	0	96	32	95			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	0	32	44	44	23		Gas Shortage
**	Impoprt (Tripura)	India		160	160	116	84	152	160			
Cumilla Zone Total				2937	2929	1359	1680	1656	2002	218	163	
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	65	113	113	113	89		Gas Shortage
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	98	49	107			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	56	108	56	136			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	21	0	50	0			
84	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	12	18	18	18			
Mymensingh Zone Total				600	592	203	337	288	374	89	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.04.24 (Yesterday)		08.04.24 (Today)		07.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)			
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	42	43	43		28	Under maint.	
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	29	30	30		61	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	47	53	53	53				
88	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	110	112				
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
90	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	25	25	27	27				
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0			Contact Expired	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	71	201	201	201				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	20	20				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0		10	Gas Shortage	
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	25	24	16	25				
97	Bibiayana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	265	295	320	320				
98	Bibiayana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	319	395	400	400				
99	Bibiayana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	310	326	330	330				
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	99	100	100	100			Test run	
101	Fenchugonj 44MW (Energypirima)	Gas (NENP)	12*3.5+2	50	50	47	47	47	47				
Sylhet Zone Total					2472	2427	1407	1667	1697	1708	10	419	
102	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage	
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	16	42	16	42				
105	Gopalnani 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	22	48	30	50				
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	225	230	0	0	0	0				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	53	70	90				
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	9	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	387	387	385	387				
113	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	917	779	940	796				
Khulna Zone Total					3241	3237	1386	1309	1541	1365	410	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	110	48	110				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	8	10	7	10				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	130	130	130		64	ST under maint.	
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	920	620	1244	1244				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	17	17				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	182	307	150	307				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220				
Barishal Zone Total					2265	2265	1386	1432	1816	2038	0	64	
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	35	34	35	35				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	24	0	30				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	42	96	50	96				
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	40	50				
126	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	34	34	34	34				
127	Santalaha 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	20	30	30				
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	200	214	200	210				
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	289	283	380	400				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	8	5	10				
133	Natore 52 MW PP (Rajkanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	18	55	35	95				
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	18	50	18	90				
136	Armura 50 MW PP (Sinha)	HFO (NENP)	7x7.9	50	28	35	35	35	35				
137	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1417	1415	1400	1400				
Rajshahi Zone Total					3453	3431	2107	2313	2276	2523	511	100	
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	230	220	220		44	Coal Shortage	
140	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	63	6	70				
142	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	4	0	0	8	0				
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	35	75				
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	20	0	30	0				
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	107	0	130	0				
Rangpur Zone Total					1030	950	337	368	429	365	129	85	
Sub-total: Plants in operation					26230	25809	11881.0	13572	14056	15568	2749	2126	
(B) Plants under long term maintenance/ contract expired													
147	Katotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
148	Hariapur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					614	0	0	0	0	0	0	0	
Gross Total					26844	25809	11881	13572	14056	15568	2749	2126	
(C) Actual data of 07.04.24 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	: 13850 MW, at = 21:00 hrs		12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 13200 MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed	Zone	Demand MW	Supply MW	Load Shed		
03.	Highest Generation (Generation end)	: 13572 MW, at = 21:00 hrs		Dhaka	4702	4702	0	Mymensingh	1188	1073	115		
04.	Minimum Generation (Generation end)	: 11881 MW, at = 9:00 hrs		Chattogram	1244	1244	0	Sylhet	467	467	0		
05.	Day-peak Generation (Generation end)	: 11881 MW, at = 9:00 hrs		Khulna	1584	1584	0	Rajshahi	305	305	0		
06.	Evening-peak Generation (Generation end)	: 13572 MW, at = 21:00 hrs		Rajshahi	1615	1565	50	Rangpur	928	828	100		
07.	Evening Peak Load-shed (Sub-station end)	: 265 MW, at = 21:00 hrs		Cumilla	1168	1168	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10717 MW, at = 5:00 hrs						Total	13200	12935	265		
09.	Generation shortfall at evening peak due to :												
a)	Gas/LF limitation	: 2420 MW		13.	Fuel cost :	(a) Gas = 410082937 Taka			(c) Coal = 680140604 Taka				
d)	Coal supply Limitation	: 129 MW				(b) Oil = 662307030 Taka			Total = 1752305071 Taka				
b)	Low water level in Kaptai lake	: 200 MW											
c)	Plants under shut down/ maintenance	: 2126 MW		14.	Maximum Temperature in Dhaka was : 30.7°C								
10.	Total Energy (Generation + India Import)	: 299.39 MKWh		15.	Export through East-West interconnections :								
	By Gas = 135.312 MKWh	By Oil = 36.162 MKWh		At evening peak-hour		: 11881 MW, at 21:00 hrs							
	By Coal = 101.305 MKWh	By Hydro = 0.721 MKWh		Maximum		: 750 MW, at 18:30 hrs							
	By Solar = 1.998 MKWh			Energy		: 0 MKWh							
11.	Total Gas Supplied	: 1045.61 MMCFD											
(D) Forecast of 08.04.24 (Today) Monday :													
01.	Maximum Demand	: 14300 MW (Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 15568 MW (Generation end)		05.	Total Generation : 315.45 MKWh								
03.	Reserve / Shortage	: 1268 MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 30.7°C								

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation