

**Bangladesh Power Development Board  
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 954667, 9551095

Month April, 2024				Day : Sunday				Date : 14.04.24			
Probable Maximum Demand : 12800 MW				Probable Maximum Generation : 15514 MW				Rule Curve = 85.40 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 77.59 ft				Today = 77.47 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.04.24 (Yesterday)		14.04.24 (Today)		13.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	170	220	180	220		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	76	12	76	32	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450		
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	307	337	330	330		
10	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	192	162	140	200		
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	315	321	335	335		
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	307	320	330	330		
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	40	40		
14	Gaganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	50	92	92		
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0		
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x6.73	80	80	19	24	27	30		
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	16	16	33	33		
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	8	8	33	33		
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	8	25		
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	17	17	100		
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	82	48	145		
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17		
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	300	300		
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	80	80	100		
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	35		
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55		
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	53	53		
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	0	54		
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	35	0		
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0		
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	15	15		
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	80	75	230	350	509	Gas Shortage
	Meghnaghat 589 MW CCGP(Summit)	Gas				300	590	550	550		Test run
<b>Dhaka Zone Total</b>				<b>5526</b>	<b>5332</b>	<b>2402</b>	<b>3139</b>	<b>3518</b>	<b>4148</b>	<b>646</b>	<b>740</b>
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	118	120	120	62	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	6	0	5	0		
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25		
37	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	8	6	6		
39	Sikalbaha 105 MW PP (Baraka Sikalabaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17		
40	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	208	212	211	211		
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	48	16	32		
43	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	0	0	0		
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	51	51	51		
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	63	42	64		
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	5	5		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			42	42	40	40		
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	13	12	12		
48	Sikalbaha 54 MW PP (Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	17		
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	17	17	17		
50	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	10	12	12		
51	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	25	80	80		
52	Chattogram 116 MW PP (Arlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	17	17	17		
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	70	54	145		
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	408	47	524	524		
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	525	650	700	700		
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	8	8	40	40		
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				69	0	25	0		
<b>Chattogram Zone Total</b>				<b>4464</b>	<b>4404</b>	<b>1505</b>	<b>1493</b>	<b>2052</b>	<b>2165</b>	<b>262</b>	<b>330</b>
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	31	32	36	36		
58	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	194	217	220	220		
59	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	270	240	270	300		
60	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	315	280	280	300		
61	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	240	230	330	330		
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	108	55	55	55		
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	19	51	51	51		
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	5	6	6		
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	14	33	33		
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	155	50	155		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10		
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	30	30		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	52	25	52		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	17	20	20		
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	70	17	114		
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	26	57	38	58		
74	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	36	36	36		
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	10	38	44	52		
**	Impoport (Tripura)	India		160	160	84	100	152	160		
<b>Cumilla Zone Total</b>				<b>2937</b>	<b>2929</b>	<b>1453</b>	<b>1701</b>	<b>1720</b>	<b>2035</b>	<b>0</b>	<b>163</b>
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	166	111	35	48		
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	68	99	50	100		
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	107	56	105		
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0		
82	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	12	22	24	24		
<b>Mymensingh Zone Total</b>				<b>600</b>	<b>592</b>	<b>353</b>	<b>339</b>	<b>217</b>	<b>277</b>	<b>0</b>	<b>0</b>

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.04.24 (Yesterday)		14.04.24 (Today)		13.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	39	43	41	41		27	Under maint.	
84	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	29	30	30		61	GT-4 Under maint.	
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	53	53				
86	Kushiana 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	110	110				
87	Hohiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	60	60	60				
89	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
90	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	201	207	210	210				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	15	17	20	20				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	23	24	25	25				
93	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0				
94	Bibiana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
95	Bibiana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	0	0	150	400				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	46	44	47	47				
<b>Sylhet Zone Total</b>					<b>2376</b>	<b>2331</b>	<b>570</b>	<b>589</b>	<b>746</b>	<b>996</b>	<b>0</b>	<b>418</b>	
98	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
100	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	16	42				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	30	50				
102	Khulna 225 MW CCGP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	70	90				
104	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
105	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	92	0	100	0				
106	Mafree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	0	0	0	0				
107	Khulna 330 MW CCGP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	927	787	803	948				
<b>Khulna Zone Total</b>					<b>3703</b>	<b>3699</b>	<b>1019</b>	<b>787</b>	<b>1019</b>	<b>1130</b>	<b>410</b>	<b>0</b>	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	48	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	0	0	7	10				
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	63	130	130	130		64	ST under maint.	
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	610	1244	1244	1244				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	17				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	307	150	150				
114	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
<b>Barishal Zone Total</b>					<b>2265</b>	<b>2235</b>	<b>1043</b>	<b>1901</b>	<b>1816</b>	<b>1881</b>	<b>0</b>	<b>64</b>	
115	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	55	50	60	60				
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	30				
118	Chapai nawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	96	50	96				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	16	40	50				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	34	34				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	30	30				
122	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	195	178	200	210	32		Gas Shortage	
123	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
124	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
125	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	376	380	400	38		Gas Shortage	
126	Ullapera 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	8	8				
127	Natore 52 MW PP (Rajkanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	75	35	70				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	111	35	70				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	35	35				
131	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkanda Ltd	(Import)	2x748	1496	1496	929	1408	1400	1400				
<b>Rajshahi Zone Total</b>					<b>3453</b>	<b>3431</b>	<b>1605</b>	<b>2353</b>	<b>2321</b>	<b>2551</b>	<b>510</b>	<b>100</b>	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal Shortage	
134	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	56	40	56				
136	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara. Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	95	35	75				
139	Lalmonirhat 30 MW Solar (Intracon)	Solar (IPP)	1*30	30	30	30	0	30	0				
140	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	177	0	130	0				
<b>Rangpur Zone Total</b>					<b>1030</b>	<b>950</b>	<b>449</b>	<b>351</b>	<b>443</b>	<b>331</b>	<b>159</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>					<b>26354</b>	<b>25903</b>	<b>10399.0</b>	<b>12653</b>	<b>13852</b>	<b>15514</b>	<b>1987</b>	<b>1900</b>	
<b>(B) Plants under long term maintenance/ contract expired</b>													
141	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Hariapur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 106MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>700</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>					<b>27054</b>	<b>25903</b>	<b>10399</b>	<b>12653</b>	<b>13852</b>	<b>15514</b>	<b>1987</b>	<b>1900</b>	
<b>(C) Actual data of 13.04.24 (Yesterday) Saturday :</b>													
01.	Max. Demand at eve. peak (Generation end)	:	12700	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12060	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12653	MW, at =	21:00 hrs	Dhaka	3161	3161	0	Mymensingh	1172	1137	35
04.	Minimum Generation (Generation end)	:	9604	MW, at =	6:00 hrs	Chattogram	1297	1297	0	Sylhet	541	541	0
05.	Day-peak Generation (Generation end)	:	10399	MW, at =	12:00 hrs	Khulna	1617	1617	0	Barishal	449	449	0
06.	Evening-peak Generation (Generation end)	:	12653	MW, at =	21:00 hrs	Rajshahi	1526	1526	0	Rangpur	926	926	0
07.	Evening Peak Load-shed (Sub-station end)	:	45	MW, at =	21:00 hrs	Cumilla	1370	1360	10				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10002	MW, at =	5:00 hrs					Total	12060	12015	45
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 414408300 Taka	(c) Coal = 513689499 Taka				
	a) Gas/LF limitation	:	1628	MW			(b) Oil = 365472923 Taka	Total = 1293570722 Taka					
	d) Coal supply Limitation	:	159	MW									
	b) Low water level in Kaplai lake	:	200	MW									
	c) Plants under shut down/ maintenance	:	1900	MW									
10.	Total Energy (Generation + India Import)	:	263.59	MKWh		14.	Maximum Temperature in Dhaka was :	37.6°C					
	By Gas = 139.717 MKWh			By Oil = 19.969 MKWh		15.	Export through East-West interconnections :						
	By Coal = 77.102 MKWh			By Hydro = 0.724 MKWh			At evening peak-hour :	10399	MW, at	21:00 hrs			
	By Solar = 3.410 MKWh						Maximum :	128	MW, at	8:00 hrs			
11.	Total Gas Supplied	:	1098.43	MMCFD			Energy :	0	MKWh				
<b>(D) Forecast of 14.04.24 (Today) Sunday :</b>													
01.	Maximum Demand	:	12800	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15514	MW	(Generation end)	05.	Total Generation	:	266.65	MKWh			
03.	Reserve / Shortage	:	2714	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :		36.9°C				

\* Captive Power \*\* Imported Power  
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation