## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT 21:00 Hrs on 19-Apr-23 Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at Available Max Ceneration Max Demand (Evening): Reserve(Generation end) Load Shed R Reporting Date : 16-Apr-24 15-Apr-24 Generation & Demand 12011.0 MW 14093.0 MW 14093.0 MW 14093.0 MW Till now the maximum generation is:The Summary of Yesterday's Day Peak Generation Evening Peak Generation E.P. Demand (at gen end) Maximum Generation Total Gen. (MKWH) 15-Apr-24 Generation & Demand 14093.0 MW 21:00 14093.0 MW 21:00 14093.0 MW 21:00 14093.0 MW 21:00 296.494 System Load Factor 87.65% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 250 MW at 16-Apr-24 11589 15890 15000 890 0 16-Apr-24 Rule curve : 85.00 Ft.( MSL ) Total = Gas Consumed : 1262.89 MMCFD. Oil Consumed (PDB): HSD : FO : Cost of the Consumed Fuel (PDB+Pvt) : Gas : Tk451,600,510 Coal : Tk548,447,665 Oil : Tk473,955,678 Total : Tk1,474,003,853

Load Shedding & Other Information						
Area	Yesterday		Today			
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding	
	MW		MW	MW	(On Estimated Demand)	
Dhaka	0	0:00	4308	0	-23%	
Chittagong Area	88	0:00	1182	0	-21%	
Khulna Area	7	0:00	1655	0	-21%	
Rajshahi Area	0	0:00	1438	0	-20%	
Cumilla Area	0	0:00	1184	0	-21%	
Mymensingh Area	65	0:00	880	0	-20%	
Sylhet Area	0	0:00	494	0	-21%	
Barisal Area	0	0:00	411	0	0%	
Rangpur Area	85	0:00	804	0	-20%	
Total	245		12357	0		

Total		245	12357	0
		Information of the Generating Units under shut down.		
		Planned Shut- Down	Forced Shut- Down	
			1) Barapukuria ST: Unit- 1	1,2
			2) Ghorasal-3,7	
			3) Shajibazar 330 MW	
			4) Baghabari-71,100 MW	v
			5) Raozan unit-2	
			6) Siddhirganj 210 MW .	
			7) Bibiyana-2	
			' '	
Outage	Restore	Additional Information of Machines, lin	nes, Interruption / Forced Load shed etc.	Remark
Time	Time			·

7ime 08:02	Time 13:41	Khulna(S) 230/132kV S/S TR-2 HT Tripped showing BBP Trip, BFP Trip. relays.	107.0 MW load interruption.
08:02	13:54	Gallamari- Khulna (S) 132kV Ckt-2 Tripped from Khulna(S) 230/132kV end showing BBP Trip, BFP Trip, relays.	10.0 MW load interruption.
08:02	13:53	Gallamari- Khulna (S) 132kV Ckt-1 Tripped from Khulna(S) 230/132kV end showing BBP Trip, BFP Trip, relays.	
08:02	10:13	Khulna(C )-Khulna (S) 132kV Ckt-2 Tripped from Khulna(S) 230/132kV end showing BBP Trip, BFP Trip. relays.	127.0 MW load interruption.
08:02	10:10	Khulna(C)-Khulna (S) 132kV Ckt-1 Tripped from Khulna(S) 230/132kV end showing BBP Trip, BFP Trip. relays.	
08:02	10:14	Khulna (S)-Satkhira 132kV Ckt-2 Tripped from Khulna(S) 230/132kV end showing BBP Trip, BFP Trip, relays.	56.0 MW load interruption.
08:02	13:29	Khulna(S) 230/132kV S/S Capacitor Bank 1 & 2 Tripped showing BBP Trip, BFP Trip. relays.	
08:02	10:00	Khulna(S) 230/132kV S/S TR-1 LT Tripped showing BBP Trip, BFP Trip. relays.	107.0 MW load interruption.
08:02	10:06	Khulna(S) 230/132kV S/S TR-3 LT Tripped showing BBP Trip, BFP Trip. relays.	
08:02	10:05	Khulna(S) 230/132kV S/S TR-3 HT Tripped showing BBP Trip, BFP Trip. relays.	
08:02	13:52	Khulna(S) 230/132kV S/S TR-2 LT Tripped showing BBP Trip, BFP Trip. relays.	
08:02	10:02	Khulna (S)-Satkhira 132kV Ckt-1 Tripped from Khulna(S) 230/132kV end showing BBP Trip, BFP Trip, relays.	
09:51	11:50	Jashore 132/33kV S/S JH-1(L2) Tripped showing Relay- z1, Trip-ABC, PH-AB, Dist-13.7 km relays.	90.0 MW load interruption.
09:51	12:39	Jashore 132/33kV S/S Cap. Bank-1 Tripped showing Lock out relay 86 relays.	
09:51	12:39	Jashore 132/33kV S/S Cap. Bank-2 Tripped showing Lock out 86 relays.	
09:53		Benapole 132/33kV S/S Transformer-2(416T) LT Tripped showing REF630 relays Due to U/F trip	44.0 MW load interruption.
09:55		Meghnaghat 400/230kV S/S 230kV spare bay shyampur-1 was sd	
10:26	11:47	Madunaghal-TKCL 132kV Ckt-1 Forced S/D from Madunaghat 132/33kV end Due to NLDC BIPTC SiS 20DF13 is restored.	
12:00		Day peak generation is 12011MW	
12:23	17:59	Bheramara 230/132kV S/S GTG (NW) Tripped showing 86A, 86B relays Due to Problem of Protection panel	
12:23		of GTG (NW) Xfr. Bheramara 410 MW CCPP Tripped	
14:05		Meghnaghat-Reliance 400kV Ckt-1 was shutdown.	
18:45		Bheramara 410 MW CCPP Syncronized with remarks:- GT	
19:52 19:52 21:00		Feni-PHP 132kV Ckt-1 Scheduled S/D from Feni 132/33kV end Due to According to NLDC order Barolinal-Feni 132 kV Ckt-2 Scheduled S/D from Feni 132/33kV end Due to According to NLDC order. Day Peak Cen. 14094 MW	
21:08		Biblyana-III 400 MW CCPP Syncronized with remarks:- GT	
21:33		Bheramara 410 MW CCPP Syncronized with remarks:- ST	
23:14		Bheramara 410 MW CCPP Syncronized with remarks:- GT	
05:48	05:54	Meghnaphat-Shyampur 230kV Ckt-1 Scheduled S/D from Meghnaghat 230/132kV end Due to Corrective maintenance work	
06:05 06:11		Kachua 132/33kV S/S TR-2 LT Scheduled S/D  Amihbazar-Keraniganj 23kV Ckt-2 Scheduled S/D from Keranigonj 230/13/2/33kV end Due to beacuse of Shampur-Mengahaid Circuit Stüden due to this reason Aminbazar1 &2 circuit going to Shutdown according to NLDC	
06:11		Aminbazar-Keranjagna Jouth Cottom due to the reason raminazar in the critical going to critical and the control of the control	
06:13		Meghnaghat-Shyampur 230kV Ckt-1 Scheduled S/D from Meghnaghat 230/132kV end Due to Corrective maintenance work done	
06:14		Kachua 132/33kV S/S TR-2 HT Scheduled S/D	
06:32		Baghabari 71 MW GTPP Shutdown with remarks:- Due to gas pressure low.	
07:00		minimum generation 11589 MW	
07:01		Narail 132/33kV S/S Capacitor Bank Bay Scheduled S/D Due to Due to Red hot Maintenance.	
	Sub Divisional Engine	 er Executive Engineer	Superintendent Engineer