

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2024				Day : Friday				Date : 03.05.24				
Probable Maximum Demand : 16000 MW				Probable Maximum Generation : 17276 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.73 ft				Today = 73.62 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.05.24 (Yesterday)		03.05.24 (Today)		02.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	69	78	75	75	30		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	403	403	400	400			
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	315	295	335	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	301	278	310	310			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	40			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	49	82	48	90			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	34	22	35	36			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	11	16	16	16			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	35	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	147	32	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	2	0	17	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	15	275	210	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	93	129	52	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	41	35	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	16	50	17	53			
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	90	162	90	162			
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	25	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	0	15			
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	450	450	400	500	500			
	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	0	0	24	67	60	80			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	25	65	25	100			
	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	0	0	19	91	25	100			
	Meghnaghat 589 MW CCGP(Summit)	Gas				400	350	360	450			Test run
Dhaka Zone Total				5526	5332	3209	3855	3483	4326	420	845	
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	114	117	115	115			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25			
37	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	6			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	34	17	34			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	211	212	211	211			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	16	16	16	16			
43	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	36	61	36	60			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	51	35	51			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	48	40	64			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	7	7	5	5			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			12	22	15	30			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	19	80	20	90			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	22	54	17	54			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34			
50	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	34	60	40	70			
51	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	0	0	0	0			
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	35	72	35	52			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	61	54	163			
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	272	265	270	270			
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	391	776	360	800			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	43	37	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				46	0	33	0			
Chattogram Zone Total				4464	4404	1450	2081	1445	2220	200	330	
57	Ashugani 50 MW PP	Gas (APSCL)	14x3.968	53	45	31	37	34	34			
58	Ashugani 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	206	213	0	0			
59	Ashugani 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	290	280	300	335			
60	Ashugani 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	335	305	345	345			
61	Ashugani 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	345	300	280	330			
62	Ashugani 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	90	90	187		Gas Shortage
63	Ashugani 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
64	Ashugani 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	5	6	6			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	34	36	41			
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	162	90	100	120			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	0	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	52	25	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	0	20	20			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	52	114			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	36	63	36	75			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	30	33	17	35			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	53	94	54	95			
76	Ashugani 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	41	42	50	50			
**	Impoprt (Tripura)	India		160	160	124	106	146	151			
Cumilla Zone Total				2937	2929	1834	1827	1675	1977	187	163	
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	108	97	100	100			
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	96	50	97			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	56	104	56	108			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	40	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	18	18	12	22			
Mymensingh Zone Total				600	592	272	315	270	327	0	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.05.24 (Yesterday)		03.05.24 (Today)		02.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	42	43	43		28	Under maint.	
84	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	29	28	28	28		62	GT-4 Under maint.	
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	50	50				
86	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	5	5				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	62	60	60				
89	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
90	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	202	206	210	210				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	16	17	17				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	25	25				
93	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	285	300	300				
94	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	363	366	400	400				
95	Bibiyana South 363 MW CCPP	Gas (PDB)	1x252+1x131	383	383	345	345	380	380				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	37	37	44	44				
Sylhet Zone Total					2376	2331	1574	1576	1674	1674	0	420	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	345	355	400	410				
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	29	25	42				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	49	44	62				
102	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	55	90	90				
104	Machumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
105	Monoria Orion 100 MW Solar PP	Solar (IPP)	100	100	78	0	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	309	307	375	375				
107	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	925	875	940	651				
Khulna Zone Total					3703	3699	1674	1670	1974	1630	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	48	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	8	10	10	10				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	126	130	130	130		64	ST under maint.	
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	740	1160	1244	1244				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	27				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	230	200	307				
114	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2265	2235	1277	1815	1869	2048	0	64	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	50	50	50	50	21		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	39	40	38	38				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	11	0	25				
118	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	85	50	95				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	31	40	40	50				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	25	25	42	42				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	23	23	33				
122	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	174	167	0	0				
123	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	194	204	185	200				
124	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	5	180	200	215		Gas Shortage	
125	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
127	Natore 52 MW PP (Rajanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	75	95	35	95				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	57	113	35	113				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0				
131	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1166	436	1200	1200				
Rajshahi Zone Total					3453	3431	2240	1719	2317	2574	236	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	72	72	70	75				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	53	85	56	80				
136	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara, Tahisa 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	55	115	35	115				
139	Lalmoinhat 30 MW Solar (Intraac)	Solar (IPP)	1*30	30	30	32	0	30	0				
140	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	170	0	130	0				
Rangpur Zone Total					1030	950	619	502	559	500	0	85	
Sub-total: Plants in operation					26354	25903	14149.0	15360	15266	17276	1043	2007	
(B) Plants under long term maintenance/ contract expired													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	14149	15360	15266	17276	1043	2007	
(C) Actual data of 02.05.24 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	: 15850 MW, at = 19:30 hrs											
02.	Max. Demand at eve. peak (Sub-station end)	: 14991 MW, at = 19:30 hrs											
03.	Highest Generation (Generation end)	: 15360 MW, at = 19:30 hrs											
04.	Minimum Generation (Generation end)	: 13298 MW, at = 7:00 hrs											
05.	Day-peak Generation (Generation end)	: 14149 MW, at = 11:00 hrs											
06.	Evening-peak Generation (Generation end)	: 15360 MW, at = 19:30 hrs											
07.	Evening Peak Load-shed (Sub-station end)	: 468 MW, at = 19:30 hrs											
08.	Minimum Generation Forecast up to 8:00 hrs.	: 11149 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
	a) Gas/LF limitation	: 843 MW											
	d) Coal supply Limitation	: 0 MW											
	b) Low water level in Kaptai lake	: 200 MW											
	c) Plants under shut down/ maintenance	: 2007 MW											
10.	Total Energy (Generation + India Import)	: 342.84 MMkWh											
	By Gas = 180.147 MMkWh	By Oil = 52.347 MMkWh											
	By Coal = 84.202 MMkWh	By Hydro = 0.676 MMkWh											
	By Solar = 2.955 MMkWh												
11.	Total Gas Supplied	: 1306.01 MMCFD											
(D) Forecast of 03.05.24 (Today) Friday :													
01.	Maximum Demand	: 16000 MW (Generation end)											
02.	Maximum Generation	: 17276 MW (Generation end)											
03.	Reserve / Shortage	: 1276 MW (Generation end)											
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :												
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW					
	Dhaka	5482	5321	161	Mymensingh	1368	1173	195					
	Chattogram	1344	1344	0	Sylhet	499	499	0					
	Khulna	1938	1938	0	Barishal	468	468	0					
	Rajshahi	1761	1761	0	Rangpur	1044	932	112					
	Cumilla	1087	1087	0									
					Total	14991	14523	468					
	13.	Fuel cost :	(a) Gas = 500985240 Taka	(c) Coal = 573172018 Taka									
			(b) Oil = 961314844 Taka	Total = 2035472101 Taka									
	14.	Maximum Temperature in Dhaka :	38.3°C										
	15.	Export through East-West interconnections :											
		At evening peak-hour	: 14149 MW, at 19:30 hrs										
		Maximum	: 500 MW, at 24:00										
		Energy	: 0 MMkWh										
(E) Forecast of 03.05.24 (Today) Friday :													
04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)											
05.	Total Generation	: 357.12 MMkWh											
06.	Probable Max. Temperature in Dhaka :	: 38.3°C											

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation