

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2024			Day : Monday				Date : 06.05.24					
Probable Maximum Demand : 14000 MW			Yesterday = 73.53 ft				Today = 73.43 ft				Rule Curve = 81.05 ft.	
Water Level of Kaptai Lake at 06:00 AM							Probable Maximum Generation : 16789 MW					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.05.24 (Yesterday)		06.05.24 (Today)		05.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oi/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	100	100	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	77	77	75	80	31	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	400	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	400	402	400	400			
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	311	312	335	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	304	301	310	310			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	4	40	40	40			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	49	90	48	90			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	42	41	42	42			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	30	32	32			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	16	16			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	35	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	131	32	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	17	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	83	253	210	300			
24	Kodda 149 MW PP Unit-1(Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	51	149	52	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	34	17	53			
28	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	120	162	90	162			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	15			
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	460	460	350	500	500			
	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	0	0	16	69	60	80			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	25	95	80	80			
	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	0	0	16	96	90	100			
	Meghnaghat 589 MW CCGP(Summit)	Gas				350	300	360	450		Test run	
Dhaka Zone Total				5526	5332	3110	3722	3601	4308	421	845	
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Inadequate Water Level	
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	77	118	118			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
35	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	1	25	8	25			
37	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	20	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	6	19			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	51	17	34			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	210	210	210	210			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x6.04	300	300	16	16	16	16			
43	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	49	62	36	60			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	50	51			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	57	40	64			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	0	5	20			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	19	51	20	90			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	19	54	17	54			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	51	17	51			
50	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	49	60	40	70			
51	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	0	0	0			
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	67	35	72			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	163	54	163			
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	270	270	270	270			
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	375	430	350	760			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	11	20	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				76	0	33	0			
Chattogram Zone Total				4464	4404	1487	1755	1447	2227	200	330	
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	34	34	34			
58	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	215	182	205	205			
59	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	175	170	240	240			
60	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	290	310	300	300			
61	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	335	320	350	350			
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	90	90	195	Gas Shortage	
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	8	23	36	41			
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	85	130	100	136			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	28	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	40	25	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	14	20	20			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	70	97	70	114			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	37	84	36	75			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	34	17	42			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	62	96	54	95			
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	48	20	50	50			
**	Impoprt (Tripura)	India		160	160	102	126	146	151			
Cumilla Zone Total				2937	2929	1602	1765	1863	2085	195	163	
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	100	111	100	100			
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	96	50	97			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	56	105	56	108			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	18	18	12	22			
Mymensingh Zone Total				600	592	274	330	270	327	0	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.05.24 (Yesterday)		06.05.24 (Today)		05.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchuganj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	43	43		40	Under maint.	
84	Fenchuganj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	20	28	28		70	GT-4 Under maint.	
85	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	50	50	50				
86	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	80	112	112				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	0	5	5				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	63	60	60				
89	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
90	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	100	100	162	162				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	25	25				
93	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	285	300	300				
94	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	316	330	400	400				
95	Bibiyana South 363 MW CCPP	Gas (PDB)	1x252+1x131	383	383	350	360	340	360				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	37	40	44	44				
Sylhet Zone Total					2376	2331	1372	1392	1587	1607	0	440	
98	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	345	370	400	410				
100	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	5	0	42				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	52	44	62				
102	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	9	17	9	90				
104	Mechumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
105	Morola Orion 100 MW Solar PP	Solar (IPP)	100	100	100	93	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIP/CL)	2x617	1234	1234	310	306	375	375				
107	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	920	920	940	655				
Khulna Zone Total					3703	3699	1677	1670	1949	1634	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	48	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	7	10	10	10				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	126	80	130	130		114	ST under maint.	
111	Pavra 1320 MW TPP	Coal (BCP/CL)	2x622	1244	1244	960	910	1244	1244				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	27				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	200	200	307				
114	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	180	220	220				
Barishal Zone Total					2265	2235	1463	1396	1869	2048	0	114	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	33	0	33				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	25				
118	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	0	90				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	42	42				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	25	25	34	34				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	0	28				
122	Siraiganj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0				
123	Siraiganj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	189	149	170	200	71		Gas Shortage	
124	Siraiganj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	181	153	180	200	67		Gas Shortage	
125	Siraiganj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	315	346	414	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
127	Natore 52 MW PP (Rajanka)	HFO (IPP)	6x8.92	52	52	8	0	8	8				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	95	95	35	95				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	92	94	35	113				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0				
131	Siraiganj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	758	753	748	748				
Rajshahi Zone Total					3453	3431	1675	1816	1683	2041	209	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	73	70	70	75				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	67	92	56	92				
136	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	90	115	35	115				
139	Lalmohanhat 30 MW Solar (Intraac)	Solar (IPP)	1*30	30	30	10	0	30	0				
140	Teesla Solar Limited	Solar (IPP)	1 x 200	200	200	72	0	130	0				
Rangpur Zone Total					1030	950	547	507	559	512	0	85	
Sub-total: Plants in operation					26354	25903	13207.0	14353	14828	16789	1025	2077	
(B) Plants under long term maintenance/ contract expired													
141	Katobti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	13207	14353	14828	16789	1025	2077	
(C) Actual data of 05.05.24 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	: 14400	MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 13887	MW, at = 19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	: 14353	MW, at = 19:00 hrs		MW	MW	MW		MW	MW	MW		
04.	Minimum Generation (Generation end)	: 10874	MW, at = 8:00 hrs	Dhaka	5525	5490	35	Mymensingh	849	849	0		
05.	Day-peak Generation (Generation end)	: 13207	MW, at = 12:00 hrs	Chattogram	1416	1416	0	Sylhet	163	163	0		
06.	Evening-peak Generation (Generation end)	: 14353	MW, at = 19:00 hrs	Khulna	1816	1806	10	Barishal	482	482	0		
07.	Evening Peak Load-shed (Sub-station end)	: 45	MW, at = 19:00 hrs	Rajshahi	1640	1640	0	Rangpur	717	717	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9606	MW, at = 5:00 hrs	Cumilla	1281	1281	0						
09.	Generation shortfall at evening peak due to :							Total	13887	13842	45		
a)	Gas/LF limitation	: 825	MW	13.	Fuel cost :	(a) Gas = 44616331	Taka	(c) Coal = 539387686		Taka			
d)	Coal supply Limitation	: 0	MW			(b) Oil = 645481196	Taka	Total = 1630985212		Taka			
b)	Low water level in Kaplai lake	: 200	MW										
c)	Plants under shut down/ maintenance	: 2077	MW	14.	Maximum Temperature in Dhaka was : 36.7°C								
10.	Total Energy (Generation + India Import)	: 299.12	MKWh	15.	Export through East-West interconnections :								
	By Gas = 159.382	MKWh	By Oil = 35.188		At evening peak-hour : 13207 MW, at 19:00 hrs								
	By Coal = 79.286	MKWh	By Hydro = 0.676		Maximum : -360 MW, at 23:00 hrs								
	By Solar = 2.417	MKWh			Energy : 2166.45 MKWh								
11.	Total Gas Supplied	: 1170.65	MMCFD										
(D) Forecast of 06.05.24 (Today) Monday :													
01.	Maximum Demand	: 14000	MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 16789	MW (Generation end)	05.	Total Generation : 291.76 MKWh								
03.	Reserve / Shortage	: 2789	MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 36.8°C								

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation