

**EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

Date : 13-May-24

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity		Peak Hour Generation	Energy Generated	Remarks
				MW	MW			
				<b>Unit No. X Capacity</b>		<b>KWH</b>		
1	Ghorasal Repowered CAPP Unit-3 (GT)	PDB	1260	250	0	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1210	160	0	0	0	Gas shortage
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4299750		
4	Ghorasal 365 MW CAPP Unit-7	PDB	1243+1122	365	0	0	0	Air Compressor problem
5	Ghorasal 78.5 MW PPMAX	QRPP	240	0	0	0	0	Contract Expired
6	Ghorasal 108 MW PP (Regent)	IPP	343.35	108	79	1622545		Engine problem
7	Harpur GTPP	SBU, PDB	232	20	0	0	0	Under maint.
8	Harpur 412 MW CAPP	EGCB	1273+1139	400	409	965200		
9	Harpur 350 MW CAPP(HPL)	IPP	1235+1125	0	0	0	0	
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2150+1150	450	380	9824500		Contract Expired
11	Meghnaghat 100 MW(EL)	NENP	128.9	0	99	931200		Frequency control
12	Meghnaghat CAPP(Summit)	IPP	2110+1110	335	301	7186036		FGMO
13	Madangan 102 PP(Summit)	NENP	617	0	80	929707		Engine problem
14	Madangan-55 MW PP(Summit)	IPP	317.08+111.3	55	55	721007		
15	Keraniganj 100 MW PP (Powerpac)	NENP	813.45	75	0	0	0	Reserve.
16	Narainigda 22 MW PP (Doreen)	SIPP, REB	82.90	22	0	0	0	Contract Expired
17	1210 MW Sashim MW PP	PDB	11210	115	0	0	0	Under maint.
18	Siddhirganj 2120 MW GTPP	EGCB	2105	210	0	0	0	Gas shortage
19	Siddhirganj 100 PP(Dutuh Bangla)	NENP	129.9	0	85	827520		Engine problem
20	Siddhirganj 335 MW CAPP	EGCB	1217+1118	335	316	7254412		Machine problem
21	Ganpasaar 102 MW PP (Digital Power)	IPP	128.924	102	90	946388		Engine problem
22	Katpodi 52 MW PP (Sinha)	IPP	77.9	0	0	0	0	Fuel shortage
23	Kanaiyaghat 54 MW PP(Banco Energy)	IPP	318	54	54	307440		
24	Kodda 150 MW PP 1	BPDB-RPCL	917.08	149	95	1313290		
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	55	734609		
26	Nababganj 55 MW PP (Southern power)	IPP	319.3	55	55	653357		
27	Basla 100 MW PP(CLC)	IPP	123.75+113.5	0	0	0	0	Fuel shortage
28	Summit Power, Madhupur(Ashulia)	SIPP, REB	33.67+48.73	80	39	871560		Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	48.73	33	33	567200		
30	Rupganj 33 MW PP(Summit)	SIPP, REB	48.73	33	31	735500		
31	Gazipur 52 MW PP 1	RPCL	118.9	52	8	204660		Fuel shortage
32	Tongi 80 MW GTPP	PDB	1105	105	0	0	0	Gas shortage
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	95	361309		Low demand
34	Banishanganj 100 MW PP (Aggreko)	IPP	1140.969	100	0	0	0	Contract Expired
35	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	0	0	0	0	Contract Expired
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.45+8.97	149	134	2030256		
37	Gazipur 100 MW PP	RPCL	617.5	105	105	832320		
38	Meghnaghat 104 MW PP (OPCL)	IPP	1815.945	104	72	1423890		Fuel shortage
39	Manikganj 162MW PP(MPGL)	IPP	918	162	162	1038900		
40	Spectra Solar Plant Ltd.	IPP	35	35	0	214054		
41	Kanchan Purbachha Power Generation Ltd.	IPP	18.43	35	0	0	0	Under maint.
42	Meghnaghat Unopower	IPP	586	584	0	2485600		
43	Summit Meghnaghat-2 589 MW(Gas)	IPP	589	0	450	10270000		Frequency control
<b>Dhaka area Total</b>				<b>5332</b>	<b>3517</b>	<b>68134570</b>		
39	Chattogram TPP-1	PDB	1210	180	100	2400000		Gas shortage
40	Chattogram TPP-2	PDB	1210	180	0	0	0	Gas shortage
41	Raozan 25 MW PP	RPCL	38.9	25	25	169475		
42	Teknaf 20MW PP (SolarTech)	IPP	20	20	0	106920		
43	Zhatenga 20MW PP (Benaki)	IPP	619.38	50	19	224160		
44	Kapali Hydro Unit-1, 2, 3, 4, 5	PDB	2400*3*50	230	30	676140		Fuel shortage
45	Sikalbaha 225MW	PDB	1150+175	225	212	5090185		Low water level
46	Sikalbaha Peaking GT	PDB	1150	150	0	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka Sikalabaha)	IPP	617.5	118.9	34	545654		Fuel shortage
48	Hathazari 100 MW peaking PP	PDB	118.9	98	72	1629552		
49	Dohazari -Kalaish 100 MW Peaking	PDB	617	102	85	927942		Fuel shortage
50	Judish 100 MW Unit-1 (Azom)	NENP	813.45	100	46	519720		Fuel shortage
51	Judish 100 MW Unit-2 (Azom)	IPP	813.45	100	62	1189440		Fuel shortage
52	Barakunda 22 MW PP (Regent)	SIPP, PDB	82.90	22	13	246384		Engine problem
53	Malanaha Ctg. EPZ (United)	IPP	58.73+9.34	0	22	425280		
54	Chattogram 160 MW PP (ECPV)	IPP	160	160	60	694720		Engine problem
55	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	35641		
56	Anwara 300 MW PP (United)	IPP	1717+24	300	52	1267091		Fuel shortage
57	Joidia Power	IPP	318.55+13.6	54	54	694323		
58	Komolaha Power Ltd	IPP	18.415+94.5	110	34	519720		Fuel shortage
59	Juidah unit-2 (Acorn)	IPP	613.6	100	62	1231680		Fuel shortage
60	Anilma Energy Ltd.	IPP	621.2	116	17	417764		Fuel shortage
61	Mishra 150 MW	BPDB-RPCL	18.59	163	126	518545		Low demand
62	S3 Power 1	S3 Power	2362	1234	370	2633681		Under maint.
63	Cox's Bazar Wind	IPP	66	60	0	35220		On test
64	Matarani 2600 MW (CPGCL)	CPGCL	0	575	638	16807272		Meghnaghat bus section limit
65	Mishra 150 MW (Gas)	BPDB-RPCL	18.59	0	0	0	0	On test
66	Sonazari 75 MW Solar Plant	EGCB	75	0	0	459684		
<b>Chattogram area Total</b>				<b>4404</b>	<b>2153</b>	<b>39765633</b>		
67	Ashuganj TPP Unit-3	APSCL	1150	0	0	0	0	Contract Expired
68	Ashuganj TPP Unit-4	APSCL	1150	0	0	0	0	Contract Expired
69	Ashuganj TPP Unit-5	APSCL	1150	0	0	0	0	Contract Expired
70	Ashuganj 225 MW CAPP	APSCL	1142+175	221	215	5048000		FGMO
71	Ashuganj 450 MW CAPP(North)	APSCL	1360	360	295	7566400		FGMO
72	Ashuganj 450 MW CAPP(South)	APSCL	1360	360	270	6895000		FGMO
73	Ashuganj 420 MW CAPP(East)	APSCL	2841+1161	420	250	7111500		FGMO
74	Ashuganj 50 MW PP	APSCL	143.968	45	35	829584		Engine problem
75	Ashuganj 55 MW PP (Precision)	QRPP	0	55	41	1125600		Engine problem
76	Ashuganj 105 MW PP (United)	IPP	2074.73+116	105	82	2001270		Gas shortage
77	Ashuganj 51 MW PP (Midland)	IPP	619.34	51	51	1058955		
78	Ashuganj 150 MW PP (Midland)	IPP	237.015	150	125	699200		Transformer overload.
79	Titas 50 MW Peaking PP	PDB	619.34	52	23	196432		Engine problem
80	Chandpur 150 MW CAPP	PDB	1110+1157	163	0	0	0	Under maint.
81	Chandpur 200 MW (Desh energy)	IPP	1218.4	200	17	410880		Fuel shortage
82	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	0	0	0	
83	Imported (Tribeni)	Imported power	0	160	100	2434000		
84	Jangalia 52 MW PP (Summit)	SIPP, PDB	48.73	33	32	701600		
85	Jangalia 52 MW PP (Lakshana)	IPP	619.34	52	40	673166		Engine problem
86	Cumilla 25 MW PP (Summit)	SIPP, REB	33.67+61.97	25	14	314900		Engine problem
87	Daudkandi 200 MW PP (B. Trac)	IPP	1547.4	0	0	0	0	
88	Feni Lanka Power	IPP	718.415+19.78	114	98	1938000		Fuel shortage
89	Chowmuhani 113 MW	IPP	129.78+23.1	113	75	1438920		Fuel shortage
90	Bharob 54.5 MW	IPP	818.2	54	35	538640		
91	Chandpur 115(Doreen)	IPP	418.5+222.5	115	75	1915150		Low demand
<b>Cumilla Area Total</b>				<b>2929</b>	<b>1799</b>	<b>41065004</b>		
92	RPCL 210MW CAPP	IPP	435+170	202	108	260320		Gas shortage
93	Jamapur 55 MW Powerpac	IPP	0	0	0	0	0	
94	Sarehabari 3 MW Solar Plant	IPP	13	3	0	13550		
95	Mymensingh 200 MW PP (United)	IPP	9.78*21	200	105	1759200		Fuel shortage
96	Jamapur 115 MW PP (United)	IPP	9.78*12	115	99	1599600		Fuel shortage
97	Satkhali 50 MW Solar	IPP	50	50	0	369590		
98	Tangail Palli Power Gen 22 MW	IPP	4.6*22	22	24	537120		
<b>Mymensingh Area Total</b>				<b>592</b>	<b>336</b>	<b>6886380</b>		
99	Fenchuganj CAPP Phase-1	PDB	232+133	70	40	971000		Machine problem
100	Fenchuganj CAPP Phase-2	PDB	232+133	90	0	37168		Machine problem
101	Kushara 163 MW CAPP (KP)	IPP	1109+154	163	112	2386145		ST Under maint.
102	Shajibazar 330 MW CAPP	PDB	3110	330	0	0	0	Under maint.
103	Fenchuganj 51 MW PP (Feni/Jatuli)	RPP	1192.90	51	62	1035600		
104	Fenchuganj 44 MW (Energytime)	NENP	123.3+52	50	39	811224		Engine problem
105	Hobiganj 11 MW PP Confidence-E	SIPP, REB	42.90	11	8	192384		Engine problem
106	Shajibazar GTTP Unit-8 & 9	PDB	235	66	57	1285536		
107	Shajibazar 80 MW PP (Shajibazar)	RPP	322.90	100	0	0	0	Contract Expired
108	Shajibazar 100 MW GTTP	PDB	1100	100	0	0	0	Gas shortage
109	Sylhet 225 MW CAPP	PDB	1142+189	231	131	3183430		ST Under maint.
110	Sylhet 20 MW GTTP	PDB	120	20	0	0	0	Under maint.
111	Sylhet 50 MW PP (EPL)	NENP	212	0	0	0	0	Contract Expired
112	Shahjahanulla 25 MW PP	SIPP, REB	39.34	25	24	558912		
113	Bibiana-II 341 MW CAPP (Summit)	IPP	1222+1119	341	280	7160000		FGMO
114	Bibiana-I 400 MW CAPP	PDB	2851+1341	400	367	8796000		FGMO
115	Sylhet 10MW PP (Desh)	RPP	61.95	0	0	0	0	Contract Expired
116	Bibiana South 400 MW	PDB	400 MW	383	340	8148400		FGMO
<b>Sylhet Area Total</b>				<b>2321</b>	<b>1450</b>	<b>34569399</b>		
<b>Khulna Area Total</b>				<b>3689</b>	<b>1854</b>	<b>40743299</b>		
117	Bansal 110 MW PP (Summit)	IPP	717.076	110	0	0	0	Meghnaghat bus section limit
118	Bhola 33 MW PP (Venture)	NENP	134.50	10	10	183648		Engine problem
119	Bhola 225 MW CAPP	PDB	263+168	194	65	2343000		Engine problem
120	Bhola 85 MW PP (Aggreko)	QRPP	861.10	0	0	0	0	Contract Expired
121	Payra 1320 MW	BCPCL	2622	1244	1080	23293000		Meghnaghat bus section limit
122	Bhola Nutan Biddut BD LTD	IPP	220	220	220	5140814		
123								