

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2024				Day : Friday				Date : 17.05.24			
Probable Maximum Demand : 15600 MW				Probable Maximum Generation : 16717 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.00 ft				Today = 73.15 ft			
				Rule Curve = 78.96 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.05.24 (Yesterday)		17.05.24 (Today)		16.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	11	12	75	75	96	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	0	450		
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	400	400	400	400		
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	310	314	310	335		
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	307	310	150	150		
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	30	55		
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	82	90	90	90		
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0		
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	38	39	40	41		
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33		
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	33	33		
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	8	16		
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	70	17	70		
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	149	32	150		
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54		
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	195	300	300	300		
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	69	149	70	149		
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	55	55		
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	51	70	53	72		
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	54	162		
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	35	0		
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0		
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	0	15		
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	400	260	400	350	400		
	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	0	0	80	75	85	85		
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	80	80	96	96		
	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	0	0	85	93	90	100		
	Meghnaghat 589 MW CCGP(Summit)	Gas				250	450	300	400		Test run
Dhaka Zone Total				5526	5332	3195	4096	2995	4021	486	845
33	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	103	98	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0		
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25		
37	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	26	6	26		
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	34	17	34		
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	209	208	210	210		
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	52	52	52	52		
43	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	49	62	49	62		
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	82	85	85	85		
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	56	64	80	80		
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	3	10	20		
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	40	55	45	100		
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	44	54	54	54		
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	46	51	51	51		
50	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	48	62	48	62		
51	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	36	58	58	58		
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	22	53	17	53		
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	163	54	163		
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	486	490	490	490		
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	674	555	555	555		
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	6	0	40	40		
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				54	0	33	0		
Chattogram Zone Total				4464	4404	2175	2244	2133	2366	200	330
57	Ashugani 50 MW PP	Gas (APSCL)	14x3.968	53	45	35	37	38	38		
58	Ashugani 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	212	211	220	220		
59	Ashugani 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	270	240	300	300		
60	Ashugani 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	290	290	300	300		
61	Ashugani 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	250	230	300	300		
62	Ashugani 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	35	8	8	160	Gas Shortage
63	Ashugani 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
64	Ashugani 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	92	41	70	135		
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	30	37	37	37		
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	70	50	70	70	113	Gas Shortage
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0		
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	31	30	33	33		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	50	34	52		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	14	20	20		
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	80	80	98	98		
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	60	94	55	95		
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	33	16	50	50		
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	53	114	115	115		
76	Ashugani 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	45	41	50	50		
**	Impoptri (Tripura)	India		160	160	116	100	146	151		
Cumilla Zone Total				2937	2929	1783	1778	2012	2140	273	0
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	56	70	60	70	132	Gas Shortage
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	57	98	57	100		
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	57	106	58	106		
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0		
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	22	24		
Mymensingh Zone Total				600	592	231	286	249	300	132	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.05.24 (Yesterday)		17.05.24 (Today)		16.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	37	37	43	43		33	Under maint.	
84	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	Under maint.	
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	52	52				
86	Kushiana 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	3	8	8				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	58	60	60				
89	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
90	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	128	129	130	130				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	25	25				
93	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	305	300	300				
94	Bibiana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	368	368	400	400				
95	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	375	383	340	360				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	38	38	42	42				
Sylhet Zone Total					2376	2331	1510	1540	1542	1562	0	423	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	345	360	400	400				
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	35	0	42				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	55	44	62				
102	Khulna 225 MW CCGP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	35	90	90				
104	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
105	Monira Orion 100 MW Solar PP	Solar (IPP)		100	100	105	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	380	505	400	500				
107	Khulna 330 MW CCGP	Gas/HSD (BIFPCL)	1x220+1x116	336	336	0	0	0	0				
108	Nocapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	0	0	0	0	0	0				
109	Khulna 115 PP MW (KPCL-2)	HFO (NENP)	7x17	0	0	0	16	0	0				
**	Bheramara (HVDC)	India		1000	1000	926	640	944	654				
Khulna Zone Total					3703	3699	1756	1646	1978	1748	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	48	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	7	10	10	10				
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	126	130	130	130		64	ST under maint.	
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	700	1100	1244	1244				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	17				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	307	250	250	307				
114	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	110	220	220				
Barishal Zone Total					2265	2235	1250	1616	1919	2038	0	64	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	27	40	39	39				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	25	0	25				
118	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	41	90	0	90				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	36	23	42	42				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	34	34	34	34				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	30	0	28				
122	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
123	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	179	199	200	200				
124	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	173	198	200	200				
125	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	413	400	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
127	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	95	113	70	113				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	75	113	70	113				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	35	35	0	28				
131	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	772	0	760	760				
Raishahi Zone Total					3453	3431	1920	1321	1832	2097	281	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	68	0	0	0				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	40	93	85	100				
136	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara Tabilis 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	115	115	115	115				
139	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	30	0	30	0				
140	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	178	0	130	0				
Rangpur Zone Total					1030	950	668	438	598	445	0	85	
Sub-total: Plants in operation					26354	25903	14488.0	14965	15258	16717	1372	1847	
(B) Plants under long term maintenance/ contract expired													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	14488	14965	15258	16717	1372	1847	
(C) Actual data of 16.05.24 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	15850 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	15180 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	15001 MW, at =	22:00 hrs	Dhaka	5615	5410	205	Mymensingh	1323	1143	180	
04.	Minimum Generation (Generation end)	:	13000 MW, at =	8:00 hrs	Chattogram	1553	1473	80	Sylhet	659	624	35	
05.	Day-peak Generation (Generation end)	:	14488 MW, at =	12:00 hrs	Khulna	1861	1861	0	Barishal	463	463	0	
06.	Evening-peak Generation (Generation end)	:	14965 MW, at =	21:00 hrs	Rajshahi	1254	1164	90	Rangpur	1009	884	125	
07.	Evening Peak Load-shed (Sub-station end)	:	845 MW, at =	21:00 hrs	Cumilla	1443	1313	130					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	12760 MW, at =	5:00 hrs					Total	15180	14335	845	
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :			(c) Coal =	616846977	Taka		
a)	Gas/LF limitation	:	1172 MW			(a) Gas = 468958021			Total =	2239715799	Taka		
d)	Coal supply Limitation	:	0 MW			(b) Oil = 1153910801							
b)	Low water level in Kaptai lake	:	200 MW										
c)	Plants under shut down/ maintenance	:	1847 MW		14.	Maximum Temperature in Dhaka was :		37.7°C					
10.	Total Energy (Generation + India Import)	:	347.86 MKWh		15.	Export through East-West interconnections :							
	By Gas = 166.224 MKWh	By Oil =	62.750 MKWh			At evening peak-hour		: 14488 MW, at	21:00 hrs				
	By Coal = 91.529 MKWh	By Hydro =	0.726 MKWh			Maximum		: 148 MW, at	19:30 hrs				
	By Solar = 3.471 MKWh					Energy		: 3535.95 MKWh					
11.	Total Gas Supplied	:	1240.85 MIMCFD										
(D) Forecast of 17.05.24 (Today) Friday :													
01.	Maximum Demand	:	15600 MW	(Generation end)	04.	Maximum Load-shed		: 0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	16717 MW	(Generation end)	05.	Total Generation		: 361.75 MKWh					
03.	Reserve / Shortage	:	1117 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :		37.7°C					

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation