

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2024				Day : Saturday				Date : 18.05.24				
Probable Maximum Demand : 14800 MW				Probable Maximum Generation : 16818 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.15 ft				Today = 72.99 ft				
								Rule Curve = 78.77 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.05.24 (Yesterday)		18.05.24 (Today)		17.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	11	12	12	97	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	110	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	400	400	403	400	400			
10	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	307	316	310	335			
12	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	145	150	150	150			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	30	55			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	78	90	90	90			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	30	31	43	40	40	41			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	31	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	16			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	70	17	70			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	146	32	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	90	195	300	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	149	149	70	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	52	72	53	72			
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	35			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	0	15			
32	Unique Meghnaghat 584MW CCPP	Gas	1x400+1x184	584	584	300	430	350	400			
	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	0	0	55	56	85	85			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	80	80	80	80			
	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	0	0	80	99	90	100			
	Meghnaghat 589 MW CCPP(Summit)	Gas				250	300	250	300			Test run
Dhaka Zone Total				5526	5332	2862	3741	3441	3877	487	845	
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	101	100	100			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25			
37	Teknaf 20MW PP (Solaritech)	Solar (IPP)	1x20	20	20	19	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	26			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	34			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
41	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	209	211	210	210			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	52	51	52	52			
43	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	49	62	49	62			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	49	85	85	85			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	56	64	55	64			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	35	10	20			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	37	75	45	100			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	51	51	51			
50	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	48	60	48	62			
51	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	24	36	58	58			
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	35	72	35	53			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	163	54	163			
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	470	490	490	490			
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	501	729	720	720			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	9	0	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				69	0	33	0			
Chattogram Zone Total				4464	4404	1890	2433	2291	2515	200	330	
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	34	36	38	38			
58	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	205	194	220	220			
59	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	320	310	300	300			
60	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	305	315	300	300			
61	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	280	250	300	300			
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	45	95	70	135			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	37	37	37			
66	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	70	50	50	70	113		Gas Shortage
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	31	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	51	34	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	16	20	20			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	80	55	80			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	53	85	55	85			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	16	16	50	50			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	112	115	115	115			
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	42	46	50	50			
**	Impoprt (Tripura)	India		160	160	104	104	146	151			
Cumilla Zone Total				2937	2929	1790	1907	1949	2112	300	0	
77	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	66	100	80	100	102		Gas Shortage
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	98	57	100			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	105	58	106			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	50	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	22			
Mymensingh Zone Total				600	592	236	315	259	328	102	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.05.24 (Yesterday)		18.05.24 (Today)		17.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date
83	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	39	36	43	43	34	Under maint.		
84	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	20	30	30	70	Under maint.		
85	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	49	49	52	52				
86	Kushnara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	112	112				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	57	54	60	60				
89	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
90	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	132	130	130	130				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	25	25				
93	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	300	300	300				
94	Bibiana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	368	379	400	400				
95	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	368	350	340	360				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		Test run		
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	35	38	42	42				
Sylhet Zone Total					2376	2331	1458	1492	1542	1562	0	434	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CCGP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	365	385	400	400				
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	40	0	42				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	58	44	62				
102	Khulina 225 MW CCGP	HSD/ Gas (NWP/CGCL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	10	84	90	90				
104	Machumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	0	0	0				
105	Morla Orion 100 MW Solar PP	Solar (IPP)	100	100	100	94	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	429	384	400	500				
107	Khulina 330 MW CCGP	Gas/HSD (B/PDB)	1x220+1x116	336	336	0	0	0	0				
108	Nocapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	0	0	0	0	0	0				
109	Khulina 115 PP MW (KPCL-2)	HFO (NENP)	7x17	0	0	0	20	0	20				
**	Bheramara (HVDC)	India		1000	1000	925	638	944	654				
Khulina Zone Total					3703	3699	1823	1609	1978	1768	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	0	48	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	7	10	10	10				
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	126	130	130	130	64	ST under maint.		
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	650	860	1244	1244				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	17				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	250	230	250	307				
114	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2265	2235	1269	1450	1919	2038	0	64	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.		
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	40	40	40				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	24	0	25				
118	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	0	90				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	42	42				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	34	24	34	34				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	28				
122	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
123	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/CGCL)	1x150 + 1x75	220	220	190	198	200	200				
124	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	189	197	200	200				
125	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	400	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11				
127	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	103	113	70	113				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	15	113	35	113				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	14	0	0	28				
131	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	3	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	768	770	760	760				
Rajshahi Zone Total					3453	3431	1735	2050	1798	2098	281	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	62	62	62				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	211	230	230				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	48	113	35	113				
136	Sardpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara Taktia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	90	115	115	115				
139	Lalmohona 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0				
140	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	195	0	130	0				
Rangpur Zone Total					1030	950	604	501	610	520	0	85	
Sub-total: Plants in operation					26354	25903	13667.0	15498	15787	16818	1370	1858	
(B) Plants under long term maintenance/ contract expired													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	13667	15498	15787	16818	1370	1858	
(C) Actual data of 17.05.24 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	: 15700 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 15116 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 15577 MW, at = 22:00 hrs											
04.	Minimum Generation (Generation end)	: 12654 MW, at = 9:00 hrs	Dhaka	5190	5190	0	Mymensingh	1282	1192	90			
05.	Day-peak Generation (Generation end)	: 13667 MW, at = 12:00 hrs	Chattogram	1484	1484	0	Sylhet	569	569	0			
06.	Evening-peak Generation (Generation end)	: 15498 MW, at = 21:00 hrs	Khulina	1872	1872	0	Barishal	488	488	0			
07.	Evening Peak Load-shed (Sub-station end)	: 193 MW, at = 21:00 hrs	Rajshahi	1677	1677	0	Rangpur	1045	992	53			
08.	Minimum Generation Forecast up to 8:00 hrs.	: 12101 MW, at = 5:00 hrs	Cumilla	1510	1460	50							
09.	Generation shortfall at evening peak due to :		13. Fuel cost : (a) Gas = 455548862 Taka (c) Coal = 582607374 Taka (b) Oil = 1183226042 Taka Total = 2221382279 Taka										
a)	Gas/LF limitation	: 1170 MW											
d)	Coal supply Limitation	: 0 MW											
b)	Low water level in Kaptai lake	: 200 MW											
c)	Plants under shut down/ maintenance	: 1858 MW											
10.	Total Energy (Generation + India Import)	: 340.67 MKWh	14. Maximum Temperature in Dhaka was : 37.3°C										
	By Gas = 162.505 MKWh	By Oil = 64.438 MKWh	15. Export through East-West interconnections :										
	By Coal = 85.668 MKWh	By Hydro = 0.718 MKWh	At evening peak-hour : 13667 MW, at 21:00 hrs										
	By Solar = 3.542 MKWh		Maximum : 148 MW, at 19:30 hrs										
11.	Total Gas Supplied	: 1206.51 MCF	Energy : 3535.95 MKWh										
(D) Forecast of 18.05.24 (Today) Saturday :													
01.	Maximum Demand	: 14800 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)										
02.	Maximum Generation	: 16818 MW (Generation end)	05. Total Generation : 323.67 MKWh										
03.	Reserve / Shortage	: 2018 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 37.3°C										

* Captive Power ** Imported Power
#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation