

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month May, 2024				Day : Sunday				Date : 19.05.24			
Probable Maximum Demand : 15000 MW				Probable Maximum Generation : 16896 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 72.99 ft				Today = 78.82 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.05.24 (Yesterday)		19.05.24 (Today)		18.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	420	450	450		
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	354	419	400	410		
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	270	332	310	335		
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	154	153	150	150	182	Under maint.
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	30	55		
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	91	90	90		
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0		
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	41	41	42	42		
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	31	33	33	33		
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	8	16		
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	70	17	70		
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	149	32	150		
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	54	54		
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	60	300	300		
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	34	134	70	149		
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	34	70	53	72		
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	108	162	162		
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	3	0	35	0		
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	35		
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	15	0	15		
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	260	260	350	350	350		
	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	0	0	0	50	85	85		
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	0	0	80	80		
	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	0	0	0	50	90	100		
	Meghnaghat 589 MW CCGP(Summit)	Gas		200	250	250	250				Test run
<b>Dhaka Zone Total</b>				<b>5526</b>	<b>5332</b>	<b>2240</b>	<b>3264</b>	<b>3443</b>	<b>3788</b>	<b>486</b>	<b>1027</b>
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	102	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	2	0	5	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	17	8	25		
37	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0		
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	26		
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	68	17	34		
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	210	208	210	210		
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	52	51	52	52		
43	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	49	62	49	62		
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	68	51	85		
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	55	55	55	55		
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	16	16	16		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	17	10	20		
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	84	45	100		
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	35	54	54		
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	51	51	51		
50	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	48	60	48	62		
51	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	43	58	58		
52	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	35	72	35	53		
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	127	54	163		
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	420	481	490	490		
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	730	727	720	720		
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	0	4	40	40		
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				55	0	33	0		
<b>Chattogram Zone Total</b>				<b>4464</b>	<b>4404</b>	<b>1893</b>	<b>2397</b>	<b>2257</b>	<b>2506</b>	<b>200</b>	<b>330</b>
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	31	35	38	38		
58	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	188	219	220	220		
59	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	270	270	270	280	90	Gas Shortage
60	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	285	310	300	300		
61	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	285	170	300	300	230	Gas Shortage
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	26	8	8	169	Gas Shortage
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	43	43	51		
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	20	84	70	135		
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	39	39	39		
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	50	70	50	80	93	Gas Shortage
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0		
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	30	31	33	33		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	25	34	52		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	2	20	20		
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	80	55	80		
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	37	84	55	85		
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	16	33	50	50		
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	70	115	115	115		
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	47	54	50	55		
**	Impoport (Tripura)	India		160	160	114	90	146	151		
<b>Cumilla Zone Total</b>				<b>2937</b>	<b>2929</b>	<b>1629</b>	<b>1797</b>	<b>1913</b>	<b>2109</b>	<b>582</b>	<b>0</b>
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	106	102	80	100	100	Gas Shortage
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	97	57	100		
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	107	58	106		
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	3	0	50	0		
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	22		
<b>Mymensingh Zone Total</b>				<b>600</b>	<b>592</b>	<b>229</b>	<b>318</b>	<b>259</b>	<b>328</b>	<b>100</b>	<b>0</b>

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.05.24 (Yesterday)		19.05.24 (Today)		18.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)				
83	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	42	43	43	28	Under maint.			
84	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	30	30	30	60	Under maint.			
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	49	49	52	52					
86	Kushiana 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	112	112					
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	8	8					
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	62	64	64					
89	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.			
90	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	80	204	204	204					
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0					
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	25	25					
93	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	265	300	300					
94	Bibiana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	318	305	400	400					
95	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	310	313	340	360					
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		Test run			
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	37	40	42	42					
<b>Sylhet Zone Total</b>					<b>2376</b>	<b>2331</b>	<b>1278</b>	<b>1443</b>	<b>1620</b>	<b>1640</b>	<b>0</b>	<b>418</b>		
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
99	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	350	345	350	350					
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	42					
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	44	62					
102	Khulina 225 MW CCGP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	90	90					
104	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	101	0	101					
105	Monira Orion 100 MW Solar PP	Solar (IPP)		100	100	44	0	100	0					
106	Maitree Super Thermal 1320 MW PP	Coal (BIFCL)	2x617	1234	1234	364	360	400	500					
107	Khulina 330 MW CCGP	Gas/HSD (BIFCL)	1x220+1x116	336	336	0	0	0	0					
108	Ncopara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	0	0	0	0	0	0					
109	Khulina 115 PP MW (KPCL-2)	HFO (NENP)	7x17	0	0	0	0	0	20					
**	Bheramara (HVDC)	India		1000	1000	927	927	944	654					
<b>Khulina Zone Total</b>					<b>3703</b>	<b>3699</b>	<b>1682</b>	<b>1750</b>	<b>1928</b>	<b>1819</b>	<b>0</b>	<b>0</b>		
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	48	110					
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	8	9	10	10					
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	72	130	130	130	64	ST under maint.			
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	580	790	1244	1244					
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	17					
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	200	200	307					
114	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220					
<b>Barishal Zone Total</b>					<b>2265</b>	<b>2235</b>	<b>1040</b>	<b>1365</b>	<b>1869</b>	<b>2038</b>	<b>0</b>	<b>64</b>		
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	50	50	50	21	Gas Shortage			
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.			
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	36	40	40	40					
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	25					
118	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	90					
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	42	42					
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	8	34	34					
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	28					
122	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage			
123	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	160	183	180	200					
124	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	160	182	180	200					
125	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	304	370	310	414					
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	5	11	11					
127	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0					
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	50	70	113					
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	50	35	113					
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	28					
131	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	765	724	760	760					
<b>Raishahi Zone Total</b>					<b>3453</b>	<b>3431</b>	<b>1433</b>	<b>1819</b>	<b>1718</b>	<b>2148</b>	<b>231</b>	<b>100</b>		
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	66	66	62	62					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling			
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230					
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	34	104	35	113					
136	Sardpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
137	Majpara, Tabilis 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0					
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	75	115	115					
139	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	16	0	30	0					
140	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	119	0	130	0					
<b>Rangpur Zone Total</b>					<b>1030</b>	<b>950</b>	<b>501</b>	<b>475</b>	<b>610</b>	<b>520</b>	<b>0</b>	<b>85</b>		
<b>Sub-total: Plants in operation</b>					<b>26354</b>	<b>25903</b>	<b>11925.0</b>	<b>14628</b>	<b>15617</b>	<b>16896</b>	<b>1599</b>	<b>2024</b>		
<b>(B) Plants under long term maintenance/ contract expired</b>														
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0		Contract Expired			
142	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0		Contract Expired			
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0		Contract Expired			
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0		Contract Expired			
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0		Contract Expired			
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>700</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>		
<b>Gross Total</b>					<b>27054</b>	<b>25903</b>	<b>11925</b>	<b>14628</b>	<b>15617</b>	<b>16896</b>	<b>1599</b>	<b>2024</b>		
<b>(C) Actual data of 18.05.24 (Yesterday) Saturday :</b>														
01.	Max. Demand at eve. peak (Generation end)	:	14628	MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	14111	MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	14740	MW, at =	1:00 hrs	Dhaka	5154	5154	0	Mymensingh	1128	1128	0	
04.	Minimum Generation (Generation end)	:	11925	MW, at =	9:00 hrs	Chattogram	1434	1434	0	Sylhet	523	523	0	
05.	Day-peak Generation (Generation end)	:	11925	MW, at =	9:00 hrs	Khulina	1738	1738	0	Barishal	372	372	0	
06.	Evening-peak Generation (Generation end)	:	14628	MW, at =	19:30 hrs	Rajshahi	1527	1527	0	Rangpur	935	935	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:30 hrs	Cumilla	1301	1301	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11810	MW, at =	5:00 hrs	Total						14111	14111	0
09.	Generation shortfall at evening peak due to :	:				a) Gas = 460936599 Taka						c) Coal = 589715980 Taka		
a)	Gas/LF limitation	:	1399	MW		b) Oil = 818780495 Taka						Total = 1869433075 Taka		
d)	Coal supply Limitation	:	0	MW										
b)	Low water level in Kaptai lake	:	200	MW										
c)	Plants under shut down/ maintenance	:	2024	MW										
10.	Total Energy (Generation + India Import)	:	318.05	MKWh		14. Maximum Temperature in Dhaka was :						31.4°C		
	By Gas = 161.805 MKWh			By Oil = 45.040 MKWh		15. Export through East-West interconnections :								
	By Coal = 86.707 MKWh			By Hydro = 0.726 MKWh		At evening peak-hour						: 11925 MW, at 19:30 hrs		
	By Solar = 2.675 MKWh					Maximum						: 210 MW, at 5:00 hrs		
11.	Total Gas Supplied	:	1220.36	MMCFD		Energy						: 2463.45 MKWh		
<b>(D) Forecast of 19.05.24 (Today) Sunday :</b>														
01.	Maximum Demand	:	15000	MW	(Generation end)	04. Maximum Load-shed						: 0 MW At evening peak (Sub-station end)		
02.	Maximum Generation	:	16896	MW	(Generation end)	05. Total Generation						: 323.66 MKWh		
03.	Reserve / Shortage	:	1896	MW	(Generation end)	06. Probable Max. Temperature in Dhaka :						31.4°C		

\* Captive Power \*\* Imported Power  
#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation