

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2024				Day : Monday				Date : 20.05.24				
Probable Maximum Demand : 15000 MW				Probable Maximum Generation : 16950 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 78.82 ft				Today = 72.66 ft				
				Rule Curve = 78.58 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.05.24 (Yesterday)		20.05.24 (Today)		19.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	403	415	400	410			
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	320	323	310	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	152	153	310	310		182	Under maint.
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	20	50	30	55			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	70	50	90	90			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	41	34	42	42			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	12	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	32	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	16			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	52	17	52			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	149	32	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	6	54	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	30	300	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	133	115	70	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	35	55	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	70	70	53	72			
28	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	95	162	162	162			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	26	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	35	17	35			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	15			
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	300	300	350	350			
	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	0	0	58	24	85	90			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	80	45	80	80			
	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	0	0	57	45	90	100			
	Meghnaghat 589 MW CCGP(Summit)	Gas				250	300	250	250			Test run
Dhaka Zone Total				5526	5332	2956	3190	3603	3935	486	1027	
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	109	100	100			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	0	0	5	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	1	25	8	25			
37	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	26			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	10	85	17	34			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	207	206	210	210			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	51	51	52	52			
43	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	49	62	49	62			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	48	57	51	85			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	56	57	55	55			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	19	10	20			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	18	45	100			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	43	54	54	54			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	34	51	51			
50	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	48	60	48	62			
51	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	12	80	80			
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	35	72	35	72			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	54	54	163			
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	490	490	490	490			
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	730	667	575	575			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	16	0	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				35	0	33	0			
Chattogram Zone Total				4464	4404	2081	2197	2134	2402	200	330	
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	24	36	38	38			
58	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	214	220	200	220			
59	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	270	250	270	280	110		Gas Shortage
60	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	305	285	300	300			
61	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	185	240	320	300	160		Gas Shortage
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	8	8	8	187		Gas Shortage
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	51			
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	100	70	135			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	46	39	46			
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	80	85	80	80	78		Gas Shortage
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	100	17	17			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	16	34	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	7	10	20	20			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	70	55	80			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	46	75	55	85			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	16	16	50	50			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	79	115	115	115			
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	44	51	50	55			
**	Impoport (Tripura)	India		160	160	114	98	146	151			
Cumilla Zone Total				2937	2929	1566	1896	1942	2135	535	0	
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	73	94	80	100	108		Gas Shortage
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	97	57	100			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	106	58	106			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	36	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6			
Mymensingh Zone Total				600	592	224	303	253	312	108	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.05.24 (Yesterday)		20.05.24 (Today)		19.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	40	42	43	43	28	Under maint.		
84	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30	60	Under maint.		
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	49	49	50	50				
86	Kushiana 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	112	80	112	112				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	3	5	8	8				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	51	61	64	64				
89	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
90	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	203	203	204	204				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	25	25				
93	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	320	300	300				
94	Bibiana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	366	302	400	400				
95	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	390	310	340	360				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3+5*2	50	50	34	34	34	42				
Sylhet Zone Total					2376	2331	1602	1460	1610	1638	0	418	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	345	345	350	350				
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	0	42			
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	44	62				
102	Khulina 225 MW CCGP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	90	90				
104	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	101				
105	Monira Orion 100 MW Solar PP	Solar (IPP)		100	100	97	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	380	380	400	500				
107	Khulina 330 MW CCGP	Gas/HSD (B/PDB)	1x220+1x116	336	336	0	0	0	0				
108	Nocapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	0	0	0	0	0	0				
109	Khulina 115 PP MW (KPCL-2)	HFO (NENP)	7x17	0	0	0	0	0	20				
**	Bheramara (HVDC)	India		1000	1000	923	923	945	655				
Khulina Zone Total					3703	3699	1745	1665	1929	1820	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	48	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	8	10	10	10				
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	130	80	90	130	114	ST under maint.		
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	630	700	1244	1244				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	17				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	200	200	307				
114	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	180	220	220				
Barishal Zone Total					2265	2235	1188	1170	1829	2038	0	114	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	50	50	50	50	21	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.		
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	40	40	40				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	25				
118	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	8	88	0	90				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	42	42				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	34	34				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	30				
122	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
123	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	183	175	180	200	45	Gas Shortage		
124	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	195	160	180	200	60	Gas Shortage		
125	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	380	340	310	414	74	Gas Shortage		
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	0	11	11				
127	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	50	70	113				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	70	35	113				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	28				
131	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	768	770	760	760				
Raishahi Zone Total					3453	3431	1593	1813	1718	2150	410	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	69	64	62	62				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	220	230	230				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	0	113	35	113				
136	Sardpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara Talsia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	50	115	115	115				
139	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	31	0	30	0				
140	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	198	0	130	0				
Rangpur Zone Total					1030	950	585	512	610	520	0	85	
Sub-total: Plants in operation					26354	25903	13540.0	14206	15628	16950	1739	2074	
(B) Plants under long term maintenance/ contract expired													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	13540	14206	15628	16950	1739	2074	
(C) Actual data of 19.05.24 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	: 14300 MW, at = 19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 13661 MW, at = 19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 14206 MW, at = 19:30 hrs	Dhaka	5151	5061	90	Mymensingh	965	965	0			
04.	Minimum Generation (Generation end)	: 11810 MW, at = 8:00 hrs	Chattogram	1337	1337	0	Sylhet	536	536	0			
05.	Day-peak Generation (Generation end)	: 13540 MW, at = 12:00 hrs	Khulina	1652	1652	0	Barishal	316	316	0			
06.	Evening-peak Generation (Generation end)	: 14206 MW, at = 19:30 hrs	Rajshahi	1488	1488	0	Rangpur	976	976	0			
07.	Evening Peak Load-shed (Sub-station end)	: 90 MW, at = 19:30 hrs	Cumilla	1240	1240	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10691 MW, at = 5:00 hrs	13. Fuel cost : (a) Gas = 474488770 Taka (c) Coal = 580628082 Taka (b) Oil = 720813563 Taka Total = 13661 13571 90										
09.	Generation shortfall at evening peak due to :	:	14. Maximum Temperature in Dhaka was : 35.4°C										
	a) Gas/LF limitation	: 1539 MW	15. Export through East-West interconnections :										
	d) Coal supply Limitation	: 0 MW	At evening peak-hour : 13540 MW, at 19:30 hrs										
	b) Low water level in Kaptai lake	: 200 MW	Maximum : 268 MW, at 20:00 hrs										
	c) Plants under shut down/ maintenance	: 2074 MW	Energy : 3328.05 MKWh										
10.	Total Energy (Generation + India Import)	: 318.37 MKWh	By Gas = 165.824 MKWh By Oil = 40.061 MKWh										
			By Coal = 85.243 MKWh By Hydro = 0.722 MKWh										
			By Solar = 2.955 MKWh										
11.	Total Gas Supplied	: 1235.55 MMCFD											
(D) Forecast of 20.05.24 (Today) Monday :													
01.	Maximum Demand	: 15000 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)										
02.	Maximum Generation	: 16950 MW (Generation end)	05. Total Generation : 336.16 MKWh										
03.	Reserve / Shortage	: 1950 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 35.4°C										

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation