

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2024				Day : Thursday				Date : 23.05.24				
Probable Maximum Demand : 16000 MW				Probable Maximum Generation : 16810 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 72.32 ft				Today = 72.16 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.05.24 (Yesterday)		23.05.24 (Today)		22.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	401	404	400	400		400	
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	318	315	310	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	315	320	320	320			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	30	55			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	82	90	90			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	40	41	42	43			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	31	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	8			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	51	17	52			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	150	48	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	192	300	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	113	149	149	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	20	55	55	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	35	70	53	72			
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	22	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	35			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	14	0	15			
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	380	450	400	500			
	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	0	0	5	85	85	90			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	2	80	80	80			
	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	0	0	0	86	90	100			
	Meghnaghat 589 MW CCGP(Summit)	Gas				350	400	400	500			Test run
Dhaka Zone Total				5526	5332	3013	4001	3908	4328	486	845	
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	112	110	110	110			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25			
37	Teknaf 20MW PP (Solaritech)	Solar (IPP)	1x20	20	20	18	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	6	6	20			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	68	17	51			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	119	0	0			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	49	52	52	52			
43	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	49	62	49	62			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	34	51	85			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	35	63	55	64			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	11	13	13			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	28	10	20			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	58	45	60			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	35	34	36			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	21	110	51	110			
50	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	48	60	48	60			
51	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	68	80	80			
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	53	35	35			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	90	54	163			
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	492	482	490	490			
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	273	232	270	270			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	3	0	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				71	0	33	0			
Chattogram Zone Total				4464	4404	1305	1791	1601	1871	205	330	
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	35	36	35	36			
58	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	179	214	200	220			
59	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	325	260	270	280	100		Gas Shortage
60	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	335	300	300	300			
61	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	260	320	320	140		Gas Shortage
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195		Gas Shortage
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	2	51	12	50			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	38	39	40			
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	85	85	85	85	78		Gas Shortage
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	155	100	155			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	24	32	32	32			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	50	16	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	17	20	20			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	79	80	55	80			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	42	75	55	85			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	4	34	50	50			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	84	115	115	115			
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	44	51	50	50			
**	Impoport (Tripura)	India		160	160	88	88	146	151			
Cumilla Zone Total				2937	2929	1641	1984	1943	2164	513	0	
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	62	82	80	80	120		Gas Shortage
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	98	57	100			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	107	58	105			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	43	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	9	12	12	12			
Mymensingh Zone Total				600	592	223	299	259	297	120	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.05.24 (Yesterday)		23.05.24 (Today)		22.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	39	37	40	40		33	Under maint.	
84	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	40	60	60		50	Under maint.	
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	46	50	50				
86	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	56	60	60				
89	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
90	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	197	202	204	204				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	23	24				
93	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	300	300				
94	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	401	367	400	400				
95	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	360	340	340	360				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3+5*2	50	50	10	42	34	37				
Sylhet Zone Total					2376	2331	1549	1561	1628	1652	0	413	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	400	340	350	350				
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	0	42				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	44	62				
102	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	75	90	90				
104	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	50	0	100				
105	Monira Orion 100 MW Solar PP	Solar (IPP)		100	100	98	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	376	483	400	500				
107	Khulna 330 MW CAPP	Gas/HSD (BIFPCL)	1x220+1x116	336	336	0	0	0	0				
108	Ncopara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	0	0	0	0	0	0				
109	Khulna 115 PP MW (KPCL-2)	HFO (NENP)	7x17	0	0	0	0	0	20				
**	Bheramara (HVDC)	India		1000	1000	926	641	945	655				
Khulna Zone Total					3703	3699	1800	1627	1929	1819	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	7	10	10	10				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	124	130	90	130		64	ST under maint.	
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	640	980	1244	1244				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	17				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	191	307	250	307				
114	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2265	2235	1182	1695	1941	2038	0	64	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	50	50	50	50	21		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	41	40	42				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	25	0	25				
118	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	0	81				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	42	42				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	34	34				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	30				
122	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
123	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	200	188	180	180				
124	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	205	190	180	190				
125	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	394	381	310	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	2	5	11	11				
127	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	70	70	113				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	70	35	113				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	28				
131	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	591	767	760	760				
Raishahi Zone Total					3453	3431	1445	1944	1718	2113	231	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	69	68	62	70				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	0	113	35	113				
136	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara Talsia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	115	115	115				
139	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	14	0	30	0				
140	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	89	0	130	0				
Rangpur Zone Total					1030	950	405	526	610	528	0	85	
Sub-total: Plants in operation					26354	25903	12563.0	15428	15537	16810	1555	1837	
(B) Plants under long term maintenance/ contract expired													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	12563	15428	15537	16810	1555	1837	
(C) Actual data of 22.05.24 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	: 15550 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 14922 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 15428 MW, at = 21:00 hrs	Dhaka	5338	5313	25	Mymensingh	1256	1164	92			
04.	Minimum Generation (Generation end)	: 10853 MW, at = 7:00 hrs	Chattogram	1560	1560	0	Sylhet	645	645	0			
05.	Day-peak Generation (Generation end)	: 12563 MW, at = 12:00 hrs	Khulna	1811	1811	0	Barishal	474	474	0			
06.	Evening-peak Generation (Generation end)	: 15428 MW, at = 21:00 hrs	Rajshahi	1439	1439	0	Rangpur	908	908	0			
07.	Evening Peak Load-shed (Sub-station end)	: 117 MW, at = 21:00 hrs	Cumilla	1492	1492	0	Total	14922	14805	117			
08.	Minimum Generation Forecast up to 8:00 hrs.	: 12609 MW, at = 5:00 hrs	13. Fuel cost : (a) Gas = 472751683 Taka (c) Coal = 542737811 Taka (b) Oil = 912184964 Taka Total = 1927674458 Taka										
09.	Generation shortfall at evening peak due to :	:	14. Maximum Temperature in Dhaka was : 34.9°C										
	a) Gas/LF limitation	: 1350 MW	15. Export through East-West interconnections :										
	d) Coal supply Limitation	: 0 MW	At evening peak-hour : 12563 MW, at 21:00 hrs										
	b) Low water level in Kaptai lake	: 205 MW	Maximum : 380 MW, at 1:00 hrs										
	c) Plants under shut down/ maintenance	: 1837 MW	Energy : 6169.35 MKWh										
10.	Total Energy (Generation + India Import)	: 327.87 MKWh	By Gas = 173.881 MKWh By Oil = 49.982 MKWh										
			By Coal = 78.159 MKWh By Hydro = 0.584 MKWh										
			By Solar = 2.914 MKWh										
11.	Total Gas Supplied	: 1248.47 MMCFD											
(D) Forecast of 23.05.24 (Today) Thursday :													
01.	Maximum Demand	: 16000 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)										
02.	Maximum Generation	: 16810 MW (Generation end)	05. Total Generation : 340.03 MKWh										
03.	Reserve / Shortage	: 810 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 34.9°C										

* Captive Power ** Imported Power
#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation