

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2024				Day : Thursday				Date : 30.05.24				
Probable Maximum Demand : 15000 MW				Probable Maximum Generation : 15897 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 74.22 ft				Today = 78.00 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.05.24 (Yesterday)		30.05.24 (Today)		29.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	71	72	72	72			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	403	360	400	400			
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	315	250	320	330			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Under maint.	
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	15	55	55			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	82	82	80	92			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	24	38	33	38			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	28	28	28			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	8			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	50	17	50			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	48	149			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	30	54	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	145	260	270			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	129	133	135	135			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	17	35			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	55	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	67	70	70	70			
28	Manikgonj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	162	162	162	162			
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	14	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	35			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	25	0	25			
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	584	584	580	580			
	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	0	0	50	33	75	80			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	34	78	80	80			
	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	0	0	51	73	74	74			
	Meghnaghat 589 MW CCGP(Summit)	Gas		0	0	0	0	0	0			
Dhaka Zone Total				5526	5332	2830	3146	3338	3540	390	1180	
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	25	30	30	205	Inadequate Water Level	
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
35	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	25			
37	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	26	6	26			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	105	85	105			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	145	143	150	150			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	52	52	52	52			
43	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	85	51	85			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	67	80	75	80			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	16	5	25			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	38	44	44	44			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	35	35	35			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	68	110	51	110			
50	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	24	24	24			
51	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	0	68	68	68			
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	35	72	35	72			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	163	54	163			
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	550	524	450	550			
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	1254	575	0	565	565	565			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	37	26	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				66	0	70	0			
Chattogram Zone Total				4464	4404	1356	2205	1948	2274	205	330	
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	31	33	35	35			
58	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	188	213	200	220			
59	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	300	280	300	310			
60	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Under maint.	
61	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	325	324	330	330			
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	175	36	8	8			
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	35	43	43	43			
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	58	119	30	30			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	45	39	45			
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	85	85	85	85			
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	51	51	68			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	24	32	32			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	43	43			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	12	20	20			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	70	107	88	114			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	26	76	65	105			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	16	17	17	17			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	40	104	90	115			
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	35	37	50	50			
**	Impoport (Tripura)	India		160	160	66	82	146	151			
Cumilla Zone Total				2937	2929	1526	1731	1672	1821	0	360	
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	142	127	145	145	75	Gas Shortage	
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	77	96	57	96			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	32	101	58	105			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	17	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total				600	592	282	336	324	358	75	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.05.24 (Yesterday)		30.05.24 (Today)		29.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	25	28	28	28		42	Under maint.	
84	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	58	58	58		32	Under maint.	
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	5	5	5				
86	Kushiana 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	163	120	163	163				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	2	5	5				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	61	60	60				
89	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
90	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	208	209	210	210				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
93	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	285	310	310				
94	Bibiana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	366	366	300	400				
95	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	230	230	235	235				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	42	10	42	42				
Sylhet Zone Total					2376	2331	1470	1390	1432	1532	0	404	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CCGP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	355	350	350	350				
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	41	30	45				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	62	50	70				
102	Khulina 225 MW CCGP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	72	35	53	70				
104	Machumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	105	100				
105	Monira Orion 100 MW Solar PP	Solar (IPP)		100	100	44	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	550	544	550	550				
107	Khulina 330 MW CCGP	Gas/HSD (B/PDB)	1x220+1x116	336	336	0	0	0	0				
108	Nocapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	0	0	0	16	32	40				
109	Khulina 115 PP MW (KPCL-2)	HFO (NENP)	7x17	0	0	5	16	20	90				
**	Bheramara (HVDC)	India		1000	1000	921	637	943	653				
Khulina Zone Total					3703	3699	1947	1701	2123	1968	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	2	2	10	10				
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	124	130	130	130		64	ST under maint.	
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	600	600	620	620				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	17	35				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140				
114	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	200	220				
Barishal Zone Total					2265	2235	1086	1143	1117	1265	0	64	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0				
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	30	32				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	25				
118	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	0	90				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	44	0	45				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	0	0				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	0	22				
122	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	185	175	210	210				
123	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
124	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	116	150	180				
125	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	5	5	5				
127	Natore 52 MW PP (Rajanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	113	50	113				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	92	50	94				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	28	14	28				
131	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	766	1313	1200	1400				
Raishahi Zone Total					3453	3431	1368	2444	2129	2658	220	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	58	54	60	60				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	15	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	34	105	106	106				
136	Sardpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara Tabilis 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	94	115	115	115				
139	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	29	0	30	0				
140	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	174	0	130	0				
Rangpur Zone Total					1030	950	594	489	649	481	0	85	
Sub-total: Plants in operation					26354	25903	12459.0	14585	14732	15897	890	2523	
(B) Plants under long term maintenance/ contract expired													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	12459	14585	14732	15897	890	2523	
(C) Actual data of 29.05.24 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	14700	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	14097	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	14920	MW, at =	23:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	11296	MW, at =	7:00 hrs	Dhaka	5175	5175	0	Mymensingh	1195	1150	45
05.	Day-peak Generation (Generation end)	:	12459	MW, at =	12:00 hrs	Chattogram	1408	1408	0	Sylhet	425	425	0
06.	Evening-peak Generation (Generation end)	:	14585	MW, at =	21:00 hrs	Khulina	1734	1734	0	Barishal	234	234	0
07.	Evening Peak Load-shed (Sub-station end)	:	110	MW, at =	21:00 hrs	Rajshahi	1614	1614	0	Rangpur	1007	942	65
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11253	MW, at =	5:00 hrs	Cumilla	1305	1305	0				
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost : (a) Gas = 409484210 Taka (c) Coal = 539090020 Taka (b) Oil = 1089449468 Taka Total = 2038023699 Taka							
	a) Gas/LF limitation	:	685	MW		14. Maximum Temperature in Dhaka was : 27.7°C							
	d) Coal supply Limitation	:	0	MW		15. Export through East-West interconnections :							
	b) Low water level in Kaptai lake	:	205	MW		At evening peak-hour : 12459 MW, at 21:00 hrs							
	c) Plants under shut down/ maintenance	:	2523	MW		Maximum : 190 MW, at 1:00 hrs							
10.	Total Energy (Generation + India Import)	:	304.40	MKWh		Energy : 5313 MKWh							
	By Gas = 144.863 MKWh			By Oil = 59.826 MKWh									
	By Coal = 78.339 MKWh			By Hydro = 1.016 MKWh									
	By Solar = 2.337 MKWh												
11.	Total Gas Supplied	:	1076.00	MMCFD									
(D) Forecast of 30.05.24 (Today) Thursday :													
01.	Maximum Demand	:	15000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15897	MW	(Generation end)	05.	Total Generation	:	306.03	MKWh			
03.	Reserve / Shortage	:	897	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	27.1°C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation