

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month June, 2024		Day : Tuesday				Date : 11.06.24							
Probable Maximum Demand :		16500 MW		Probable Maximum Generation :		16840 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 81.37 ft		Today = 81.52 ft		Rule Curve = 78.60 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.06.24 (Yesterday)		11.06.24 (Today)		10.06.24 (Yesterday) Gen. shortfall for :	78.60 (Yesterday) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
<b>(A) Plants in operation:</b>													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under Repowering project	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGP1	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0				
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
9	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	400	404	374	400	400				
10	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
11	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	330	325	320	330				
12	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	151	130	150	150	205		Gas Shortage	
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
14	Gaganraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	82	48	82	82				
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)		22	22	0	0	0	0				
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	41	39	41				
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	31	33	33				
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	8				
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	70	52	88				
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	149	100	150				
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54				
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	45	195	270	300				
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	97	92	90	97				
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	35	55				
26	Manikgonj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	72	50	70				
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	60	35	54	108				
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	25	0	35	0				
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	35	35				
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	25				
32	Unique Meghnaghat 584MW CCPP	Gas	1x400+1x184	584	584	0	0	0	0	584		Gas Shortage	
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	55	39	70	85				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	50	36	64	64				
35	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	30	51	50	100				
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0	589		Gas Shortage	
<b>Dhaka Zone Total</b>				<b>5828</b>	<b>5634</b>	<b>2356</b>	<b>2578</b>	<b>2744</b>	<b>3048</b>	<b>1876</b>	<b>740</b>		
36	Karnaphuli Hydro PP Unit-1, 2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	115	115	115	115	115		Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0				
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17				
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0				
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	18				
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	68	51	51				
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
44	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	216	224	220	220				
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	52	52	52				
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	23	23	25	25				
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	85	50	85				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	25	57	48	64				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	25	6	20				
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	31	38	30	38				
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	35	35				
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	110	85	110				
52	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
53	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	36	68	70	70				
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	53	35	53				
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	17	54	163				
56	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	905	1011	1000	1000				
57	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	402	275	340	340				
58	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	4	11	40	40				
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)		75	75	18	0	70	0				
<b>Chattogram Zone Total</b>				<b>4517</b>	<b>4457</b>	<b>2048</b>	<b>2310</b>	<b>2390</b>	<b>2541</b>	<b>295</b>	<b>330</b>		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	36	36	37	37		9	Gas Shortage	
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1'175	221	221	219	218	220	220				
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	315	270	280	280		90	Gas Shortage	
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	280	280	300		80	Gas Shortage	
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	285	240	320		115	Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	0	8	8	8	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	16	10	12	50				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	6	27	40	41				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	85	85	85	85				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	51	33	51				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	5	6	6	6				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	52	114	114	114				
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	40	86	38	85				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	49	115	115	115				
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	0	36	5	5	19		Gas Shortage	
**	Impoport (Tripura)	India		160	160	74	82	146	151				
<b>Cumilla Zone Total</b>				<b>2883</b>	<b>2875</b>	<b>1523</b>	<b>1809</b>	<b>1759</b>	<b>1968</b>	<b>500</b>	<b>0</b>		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	29	70	60	80	132		Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	79	68	80				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	93	121	97	120				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	13	0	50	0				
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	16	52	34	52				
85	Tangali 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	24						

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.06.24 (Yesterday)		11.06.24 (Today)		10.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	35	35	40	40		35	Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	58	58	58	58		32	Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	50	50				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
90	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	2	5	5				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	59	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	207	206	210	210				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under maint.	
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	300	280	300				
97	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	365	365	400	400				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	396	340	370	375				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under Construction Project	
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	40	40	40	40				
<b>Sylhet Zone Total</b>					<b>2376</b>	<b>2331</b>	<b>1702</b>	<b>1637</b>	<b>1692</b>	<b>1717</b>	<b>0</b>	<b>417</b>	
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	200	235	200	200	175		Gas shortage	
103	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	42	30	50				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	51	50	60				
105	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
106	Russha 105 MW PP (Orion russha)	HFO (IPP)	6x18.445	105	105	17	73	17	73				
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)	2x617	100	100	82	0	100	0				
109	Maitree Super Thermal 1320 MW PP	Coal (BIF/CL)	1234	1234	711	955	1000	1000					
110	Khulna 330 MW CCPP	Gas/HSD (RPP)	1x220+1x116	336	336	0	0	0	0				
111	Nasipara 40 MW PP (Khanjahan Ali)	HFO NENP	5x8.5	40	40	0	24	32	40				
112	Khulna 115 PP MW (KPOL-2)	HFO NENP	7x17	115	115	0	15	20	50				
**	Bheramara (HVDC)	India		1000	1000	926	781	943	798				
<b>Khulna Zone Total</b>					<b>3858</b>	<b>3854</b>	<b>1936</b>	<b>2176</b>	<b>2392</b>	<b>2271</b>	<b>175</b>	<b>0</b>	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	8	10	10	10				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	63	126	130	130		68	ST under maint.	
116	Pavra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	660	1100	1000	1244				
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	307	307	307				
119	Barisal 1 MW Solar PP	Solar (PDB)	1 x 1	1	1	0	0	0	0				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
<b>Barishal Zone Total</b>					<b>2266</b>	<b>2236</b>	<b>1091</b>	<b>1763</b>	<b>1700</b>	<b>2056</b>	<b>0</b>	<b>68</b>	
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
121	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	7	0	0	40				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	0	10				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	40	50	88				
125	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	45	0	45				
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	30				
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	140	145	200	180	65		Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	350	414	350	350	0		Gas Shortage	
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5				
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
133	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	50	113	113				
134	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	50	94	113				
135	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	14	35				
136	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	1	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1226	1363	1200	1400				
<b>Rangpur Zone Total</b>					<b>3403</b>	<b>3381</b>	<b>1729</b>	<b>2157</b>	<b>2032</b>	<b>2409</b>	<b>576</b>	<b>100</b>	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	63	60	62	64				
137	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	220	210	210				
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16.2*3	113	113	0	107	70	106				
141	Sardpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
142	Majpara Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
143	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	78	94	35	94				
144	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	29	0	30	0				
145	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	188	0	130	0				
<b>Rangpur Zone Total</b>					<b>1030</b>	<b>950</b>	<b>591</b>	<b>481</b>	<b>545</b>	<b>474</b>	<b>0</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>					<b>26815</b>	<b>26364</b>	<b>13193.0</b>	<b>15257</b>	<b>15571</b>	<b>16840</b>	<b>3554</b>	<b>1740</b>	
<b>(B) Plants under long term maintenance/ contract expired</b>													
146	Katoboti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
147	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>700</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>					<b>27515</b>	<b>26364</b>	<b>13193</b>	<b>15257</b>	<b>15571</b>	<b>16840</b>	<b>3554</b>	<b>1740</b>	
<b>(C) Actual data of 10.06.24 (Yesterday) Monday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 15450 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 14842 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 15257 MW, at = 21:00 hrs											
04.	Minimum Generation (Generation end)	: 10963 MW, at = 8:00 hrs	Dhaka	5195	5145	50	Mymensingh	1262	1152	110			
05.	Day-peak Generation (Generation end)	: 13193 MW, at = 12:00 hrs	Chattogram	1470	1470	0	Sylhet	564	564	0			
06.	Evening-peak Generation (Generation end)	: 15257 MW, at = 21:00 hrs	Khulna	1834	1834	0	Barishal	552	552	0			
07.	Evening Peak Load-shed (Sub-station end)	: 184 MW, at = 21:00 hrs	Rajshahi	1616	1616	0	Rangpur	984	957	24			
08.	Minimum Generation Forecast up to 8.00 hrs.	: 12517 MW, at = 5:00 hrs	Cumilla	1369	1369	0							
09.	Generation shortfall at evening peak due to :	:	13.	Fuel cost :			Total	14658	184				
	a) Gas/LF limitation	: 3439 MW		a) Gas =	418641014 Taka		(c) Coal =	79877469	Taka				
	d) Coal supply Limitation	: 0 MW		b) Oil =	865634927 Taka		Total =	2083053410	Taka				
	b) Low water level in Kaptai lake	: 115 MW											
	c) Plants under shut down/ maintenance	: 1740 MW	14.	Maximum Temperature in Dhaka was : 30.5°C									
10.	Total Energy (Generation + India Import)	: 328.54 MKWh	15.	Export through East-West interconnections :									
	By Gas = 136.733 MKWh	By Oil = 47.297 MKWh		At evening peak-hour	: 13193 MW, at 21:00 hrs								
	By Coal = 115.984 MKWh	By Hydro = 2.764 MKWh		Maximum	: 394 MW, at 7:00 hrs								
	By Solar = 2.485 MKWh			Energy	: 4172.85 MKWh								
11.	Total Gas Supplied	: 1026.43 MMCFD											
<b>(D) Forecast of 11.06.24 (Today) Tuesday :</b>													
01.	Maximum Demand	: 16500 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 16840 MW (Generation end)	05.	Total Generation : 355.31 MKWh									
03.	Reserve / Shortage	: 340 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 33.5°C									

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation