

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month June, 2024		Day : Thursday				Date : 13.06.24						
Probable Maximum Demand :		16400 MW		Probable Maximum Generation :		17185 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 81.42 ft		Today = 81.28 ft		Rule Curve = 79.14 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.06.24 (Yesterday)		13.06.24 (Today)		Rule Curve		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under Repowering project
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			Gas Shortage
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	390	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	400	335	400	400	400			
10	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
11	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	313	310	320	330			
12	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	147	147	150	150	188		Gas Shortage
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	50	55	55			
14	Gaganraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	74	16	82	85			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)		22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	36	33	41	41			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	13	13	33	33			
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	12	6	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	8	8			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	70	52	88			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	146	100	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	293	278	270	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	69	96	96	97			
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	35	35	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	71	55	70			
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	72	72	108			
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	35	35			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	0	25			
32	Unique Meghnaghat 584MW CAPP	Gas	1x400+1x184	584	584	0	0	0	0	584		Gas Shortage
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	47	55	70	85			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	51	51	64	64			
35	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	6	37	50	85			
	Meghnaghat 589 MW CAPP(Summit)	Gas				0	0	0	0	589		Gas Shortage
<b>Dhaka Zone Total</b>				<b>5828</b>	<b>5634</b>	<b>2438</b>	<b>2620</b>	<b>2775</b>	<b>3036</b>	<b>1859</b>	<b>740</b>	
36	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	115	112	115	115	118		Inadequate Water Level
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	8	17			
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	5	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	19			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	34	51	51			
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	223	221	220	220			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	51	52	52			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	24	24	25	25			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	85	50	85			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	42	64	48	64			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			8	28	8	25			
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	24	19	18	24			
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	35	35			
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	92	110	110			
52	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	25	25	25			
53	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	58	48	35	70			
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	32	53	35	53			
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	144	54	163			
56	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	890	990	1000	1040			
57	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	343	363	365	365			
58	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	13	18	40	40			
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)		75	75	11	0	70	0			
<b>Chattogram Zone Total</b>				<b>4517</b>	<b>4457</b>	<b>2007</b>	<b>2444</b>	<b>2395</b>	<b>2598</b>	<b>298</b>	<b>330</b>	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	3	3	5	5	42		Gas Shortage
61	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1'175	221	221	200	198	220	220			
62	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	260	260	280	280			Gas Shortage
63	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	295	280	300	300	80		Gas Shortage
64	Ashuganj 420 MW CAPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	230	300	320	170		Gas Shortage
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	56	68	92	145			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	41	36	40	41			
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	80	70	85	85			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	153	100	150			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	50	33	51			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	52	80	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	38	85	38	85			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	48	104	115	115			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	0	0	0	0	55		Gas Shortage
**	Impoport (Tripura)	India		160	160	92	88	146	151			
<b>Cumilla Zone Total</b>				<b>2883</b>	<b>2875</b>	<b>1606</b>	<b>1808</b>	<b>1971</b>	<b>2165</b>	<b>634</b>	<b>0</b>	
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	11	27	28	50	175		Gas Shortage
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	57	77	68	80			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	92	125	97	120			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0			
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	35	35	35			
85	Tangali 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	12	6	6			
<b>Mymensingh Zone Total</b>				<b>654</b>	<b>646</b>	<b>207</b>	<b>276</b>	<b>286</b>	<b>291</b>	<b>175</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.06.24 (Yesterday)		13.06.24 (Today)		12.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)			
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	35	36	35	35		34	Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	58	58	58	58		32	Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	21	50	50				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
90	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	10	10	5	5				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	53	50	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	206	201	210	210				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under maint.	
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	16	16	16				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	315	300	300				
97	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	326	366	400	400				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	345	370	385				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under Construction Project	
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	42	42	40	40				
<b>Sylhet Zone Total</b>					<b>2376</b>	<b>2331</b>	<b>1605</b>	<b>1623</b>	<b>1707</b>	<b>1722</b>	<b>0</b>	<b>416</b>	
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	220	170	230	235		240	Gas shortage	
103	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	42	30	50				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	52	50	60				
105	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
106	Russha 105 MW PP (Orion russha)	HFO (IPP)	6x18.445	105	105	0	72	17	73				
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)	2x617	100	100	47	0	100	0				
109	Maitree Super Thermal 1320 MW PP	Coal (BIF/CL)	12x110	1234	1234	724	819	1000	1000				
110	Khulna 330 MW PP	Gas/HSD (RPP)	1x220+1x116	336	336	0	0	0	0				
111	Nasipara 40 MW PP (Khanjahan Ali)	HFO NENP	5x8.5	40	40	0	40	32	40				
112	Khulna 115 PP MW (KPOL-2)	HFO NENP	7x17	115	115	0	16	20	50				
**	Bheramara (H/VD)	India		1000	1000	924	781	943	798				
<b>Khulna Zone Total</b>					<b>3858</b>	<b>3854</b>	<b>1915</b>	<b>1992</b>	<b>2422</b>	<b>2306</b>	<b>240</b>	<b>0</b>	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	9	10	10	10				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	130	130	130		64	ST under maint.	
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1000	1000	1244	1244				
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	271	294	307	307				
119	Barisal 1 MW Solar PP	Solar (PDB)	1 x 1	1	1	0	0	0	0				
120	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
<b>Barishal Zone Total</b>					<b>2266</b>	<b>2236</b>	<b>1580</b>	<b>1914</b>	<b>1800</b>	<b>2056</b>	<b>0</b>	<b>64</b>	
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	15	38	32	40				
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	0	10				
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	88	50	88				
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	45	0	45				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	0	35				
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	140	200	160	200				
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	0	0	0	0		220	Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	400	414				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	5	8				
133	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
134	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	113	113	113				
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	92	94	113				
136	Amnara 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	28	35	14	35				
137	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1424	1461	1228	1400				
<b>Rangpur Zone Total</b>					<b>3403</b>	<b>3381</b>	<b>2095</b>	<b>2540</b>	<b>2102</b>	<b>2501</b>	<b>511</b>	<b>100</b>	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	60	63	62	62				
138	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	210	200	220	220				
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16.2*3	113	113	34	113	70	113				
142	Sardpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	32	115	35	115				
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	8	0	30	0				
146	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	150	0	130	0				
<b>Rangpur Zone Total</b>					<b>1030</b>	<b>950</b>	<b>501</b>	<b>491</b>	<b>555</b>	<b>510</b>	<b>0</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>					<b>26815</b>	<b>26364</b>	<b>13954.0</b>	<b>15708</b>	<b>16013</b>	<b>17185</b>	<b>3717</b>	<b>1735</b>	
<b>(B) Plants under long term maintenance/ contract expired</b>													
146	Katoboti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
147	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
148	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>700</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>					<b>27515</b>	<b>26364</b>	<b>13954</b>	<b>15708</b>	<b>16013</b>	<b>17185</b>	<b>3717</b>	<b>1735</b>	
<b>(C) Actual data of 12.06.24 (Yesterday) Wednesday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 16450 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 15780 MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 15726 MW, at = 23:00 hrs		Dhaka	5607	5397	210	Mymensingh	1249	1010	239		
04.	Minimum Generation (Generation end)	: 12936 MW, at = 8:00 hrs		Chattogram	1479	1379	100	Sylhet	692	692	0		
05.	Day-peak Generation (Generation end)	: 13954 MW, at = 12:00 hrs		Khulna	1999	1989	10	Barishal	511	511	0		
06.	Evening-peak Generation (Generation end)	: 15708 MW, at = 21:00 hrs		Rajshahi	1744	1744	0	Rangpur	1016	916	100		
07.	Evening Peak Load-shed (Sub-station end)	: 709 MW, at = 21:00 hrs		Cumilla	1482	1432	50						
08.	Minimum Generation Forecast up to 8.00 hrs.	: 12555 MW, at = 5:00 hrs						Total	15780	15071	709		
09.	Generation shortfall at evening peak due to :	:		13.	Fuel cost :			(a) Gas = 411907022 Taka	(c) Coal = 847147920 Taka				
	a) Gas/LF limitation	: 3599 MW						(b) Oil = 1156661115 Taka	Total = 2415716057 Taka				
	d) Coal supply Limitation	: 0 MW											
	b) Low water level in Kaptai lake	: 118 MW											
	c) Plants under shut down/ maintenance	: 1735 MW		14.	Maximum Temperature in Dhaka was : 35.9°C								
10.	Total Energy (Generation + India Import)	: 349.25 MCKWh		15.	Export through East-West interconnections :								
	By Gas = 134.338 MCKWh	By Oil = 62.860 MCKWh			At evening peak-hour	: 13954 MW, at 21:00 hrs							
	By Coal = 123.195 MCKWh	By Hydro = 2.747 MCKWh			Maximum	: 514 MW, at 2:00 hrs							
	By Solar = 2.410 MCKWh				Energy	: 6270 MCKWh							
11.	Total Gas Supplied	: 986.46 MCMCFD											
<b>(D) Forecast of 13.06.24 (Today) Thursday :</b>													
01.	Maximum Demand	: 16400 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 17185 MW (Generation end)	05.	Total Generation	: 364.22 MCKWh								
03.	Reserve / Shortage	: 785 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	35.9°C								

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation