

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month June, 2024		Day : Saturday				Date : 15.06.24								
Probable Maximum Demand : 14600 MW		Probable Maximum Generation : 16078 MW												
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 81.39 ft		Today = 81.76 ft		Rule Curve = 79.41 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.06.24 (Yesterday)		15.06.24 (Today)		14.06.24 (Yesterday)		15.06.24 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)	Description/ Remarks		Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under Repowering project	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	Awaiting for HGP1	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0					
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	400	420	450	450					
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling	
9	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	400	408	372	400	400					
10	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
11	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	327	320	330	330					
12	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	131	147	150	150	188			Gas Shortage	
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55					
14	Gaganraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	74	92	82	85					
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)		22	22	0	0	0	0					
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	15	31	41	41					
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	17	33	33					
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	10	10	33	33					
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	8					
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	100	105	35	52	52	70					
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	148	100	150					
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	2	54	54	54					
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	140	275	270	300					
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	96	47	96	97					
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55					
26	Manikgonj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	35	55					
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	70	55	70					
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162					
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	35	0					
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	35	17	35	35					
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	0	25					
32	Unique Meghnaghat 584MW CAPP	Gas	1x400+1x184	584	584	0	0	0	0	584			Gas Shortage	
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	43	70	70	85					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	50	65	64	64					
35	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	41	66	50	85					
	Meghnaghat 589 MW CAPP(Summit)	Gas				0	0	0	0	589			Gas Shortage	
Dhaka Zone Total				5828	5634	2360	2781	2785	3072	1859	740			
36	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	114	112	115	115	118			Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0					
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	8	17					
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	3	0	20	0					
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	6	6	19					
42	Sikalbaha 105 MW PP (Baraka Sikalabaha)	HFO (IPP)	6x18.415	105	105	39	51	51	51					
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	222	223	224	224					
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	51	50	52	52					
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	24	24	25	25					
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	75	50	85					
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	72	48	64					
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			19	42	40	40					
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	19	25	18	24					
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	35	35					
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	108	110	110					
52	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	24	25	25					
53	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	25	12	35	46					
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	35	35	53					
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	145	54	163					
56	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	925	1070	1000	1070					
57	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	0	0	0	0					
58	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	18	36	40	40					
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)		75	75	24	0	70	0					
Chattogram Zone Total				4517	4457	1652	2135	2066	2258	298	330			
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0	45			Gas Shortage	
61	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	221	215	220	220					
62	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	270	270	280	280				Gas Shortage	
63	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	280	280	300	300	80			Gas Shortage	
64	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	240	280	280	160			Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	0	195			Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	8	118	92	150					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	38	40	41					
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	70	70	50	70					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	155	100	150					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0					
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	1	25	16	51					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	43	70	114	114					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	42	86	42	85					
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	34	59	34	115					
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	0	0	0	0	55			Gas Shortage	
**	Impoport (Tripura)	India		160	160	80	76	146	151					
Cumilla Zone Total				2883	2875	1474	1797	1809	2102	625	0			
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	12	40	40	50	162			Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	58	79	68	80					
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	94	121	97	120					
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0					
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	13	0	50	0					
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	17	35	35					
85	Tangali 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	12	6						

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.06.24 (Yesterday)		15.06.24 (Today)		14.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	37	35	35	35		35	Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	58	58	58	58		32	Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	53	50	50				
89	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163				
90	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	2	5	5				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	61	60	60				
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	206	205	210	210				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under maint.	
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	16	16				
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	295	300	300				
97	Bibiyana-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	287	324	400	400				
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	256	15	150	400				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under Construction Project	
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	10	42	40	40				
Sylhet Zone Total					2376	2331	1314	1269	1487	1737	0	417	
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	175	165	160	170	245		Gas shortage	
103	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	37	30	50				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	51	50	60				
105	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
106	Russha 105 MW PP (Orion russha)	HFO (IPP)	6x18.445	105	105	0	91	17	73				
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)	2x617	100	100	93	0	100	0				
109	Maitree Super Thermal 1320 MW PP	Coal (BIF/PCL)	1234	1234	657	358	350	350	350				
110	Khulna 330 MW CAPP	Gas/HSD (RPP)	1x220+1x116	336	336	0	0	0	0				
111	Nasipara 40 MW PP (Khanjahan Ali)	HFO NENP	5x8.5	40	40	0	40	32	40				
112	Khulna 115 PP MW (KPOL-2)	HFO NENP	7x17	115	115	0	94	20	50				
**	Bheramara (HVDC)	India		1000	1000	451	784	932	782				
Barisal Zone Total					3858	3854	1376	1620	1691	1575	245	0	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	16	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	10	10	9	10	10	10				
115	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	130	128	130	130		66	ST under maint.	
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	920	1190	1100	1244				
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	17	35				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	307	307	307				
119	Barisal 1 MW Solar PP	Solar (PDB)	1 x 1	1	1	0	0	0	0				
120	Bhola 220MW CAPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2266	2236	1429	2000	1800	2056	0	66	
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	40	32	40				
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	10				
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	50	88				
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	47	0	45				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	0	35				
128	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	140	140	170	170	70		Gas Shortage	
129	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
131	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	250	270	400	414	144		Gas Shortage	
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	8				
133	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	25	35	113	113				
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	1	35	94	113				
136	Amnara 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	14	14	35				
137	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	1	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1114	1420	1228	1400				
Rajshahi Zone Total					3403	3381	1536	2120	2112	2471	725	100	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	64	61	62	62				
138	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	230	220	220				
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16.2*3	113	113	34	49	70	113				
142	Sardpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	114	95	35	115				
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	16	0	30	0				
146	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	140	0	130	0				
Rangpur Zone Total					1030	950	570	435	555	510	0	85	
Sub-total: Plants in operation					26815	26364	11929.0	14426	14603	16078	3914	1738	
(B) Plants under long term maintenance/ contract expired													
146	Katoboti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
147	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27515	26364	11929	14426	14603	16078	3914	1738	
(C) Actual data of 14.06.24 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	: 14510 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 14020 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 14753 MW, at = 24:00											
04.	Minimum Generation (Generation end)	: 10682 MW, at = 9:00 hrs	Dhaka	4703	4703	0	Mymensingh	1109	1029	80			
05.	Day-peak Generation (Generation end)	: 11929 MW, at = 12:00 hrs	Chattogram	1363	1363	0	Sylhet	487	487	0			
06.	Evening-peak Generation (Generation end)	: 14426 MW, at = 21:00 hrs	Khulna	1984	1984	0	Barishal	535	535	0			
07.	Evening Peak Load-shed (Sub-station end)	: 80 MW, at = 21:00 hrs	Rajshahi	1581	1581	0	Rangpur	895	895	0			
08.	Minimum Generation Forecast up to 8.00 hrs.	: 10854 MW, at = 5:00 hrs	Cumilla	1363	1363	0							
09.	Generation shortfall at evening peak due to :	:	13.	Fuel cost :			Total	14020	13940	80			
	a) Gas/LF limitation	: 3796 MW		a) Gas =	393320038 Taka		(c) Coal =	755961980 Taka					
	d) Coal supply Limitation	: 0 MW		b) Oil =	864248089 Taka		Total =	2013530107 Taka					
	b) Low water level in Kaptai lake	: 118 MW											
	c) Plants under shut down/ maintenance	: 1738 MW	14.	Maximum Temperature in Dhaka was : 32.5°C									
10.	Total Energy (Generation + India Import)	: 307.01 MKWh	15.	Export through East-West interconnections :									
	By Gas = 127.377 MKWh	By Oil = 47.418 MKWh		At evening peak-hour		: 11929 MW, at 21:00 hrs							
	By Coal = 108.971 MKWh	By Hydro = 2.762 MKWh		Maximum		: 514 MW, at 2:00 hrs							
	By Solar = 1.877 MKWh			Energy		: 6270 MKWh							
11.	Total Gas Supplied	: 969.74 MMCFD											
(D) Forecast of 15.06.24 (Today) Saturday :													
01.	Maximum Demand	: 14600 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 16078 MW (Generation end)	05.	Total Generation : 303.82 MKWh									
03.	Reserve / Shortage	: 1478 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 32.5°C									

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation