

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month June, 2024		Day : Tuesday				Date : 18.06.24							
Probable Maximum Demand :		13500 MW		Probable Maximum Generation :		16760 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 82.01 ft		Today = 82.32 ft		Rule Curve = 80.49 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.06.24 (Yesterday)		18.06.24 (Today)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under Repowering project		
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	130	150	140	150				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	22	21	22	86		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0				
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	420	450	450				
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
9	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	400	302	379	400	400				
10	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
11	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	240	317	320	320				
12	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	243	273	300	300				
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55				
14	Gaganraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	82	85				
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)		22	22	0	0	0	0				
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	15	17	33	33				
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	7	8	33	33				
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	8	8	33	33				
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	8	8				
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	52	52				
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	16	100	150				
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	54	54				
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	30	270	300				
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	0	114	96	149				
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	35	35				
26	Manikgonj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	35	55				
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	50	55	70				
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	72	162				
29	Manikgonj 35MW Solar PP (Inspecta Solar Ltd.)	Solar (IPP)	1x35	35	35	11	0	35	0				
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	35	35				
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	25				
32	Unique Meghnaghat 584MW CAPP	Gas	1x400+1x184	584	584	255	500	400	500				
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	70	85				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	15	64	64				
35	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	0	0	50	80				
	Meghnaghat 589 MW CAPP(Summit)	Gas				0	0	0	0	589		Gas Shortage	
Dhaka Zone Total				5828	5634	1691	2589	3478	3885	885	740		
36	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	115	115	115	115	115		Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0				
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17				
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0				
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	6	6	18				
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	0	51	100				
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	218	220	220				
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	49	52	52				
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	12	25	25				
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	50	80				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	39	48	64				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			42	42	40	40				
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	38	18	38				
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	35	35				
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
52	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	12	25	25				
53	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	0	35	45				
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	17	35	35				
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	54	163				
56	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	351	562	600	600				
57	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	0	0	0	0				
58	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	1	39	40	40				
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)		75	75	32	0	70	0				
Chattogram Zone Total				4517	4457	764	1200	1662	1822	295	330		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	37	36	37				
61	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1'75	221	221	188	190	220	220				
62	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	270	270	280	280	90		Gas Shortage	
63	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	285	305	300	300				
64	Ashuganj 420 MW CAPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	335	300	330				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	55	48	55	140		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	92	130				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	40	40				
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	80	86	80	86				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	85	100	150				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	34	50	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	6	12	12				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	52	88	17	17				
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	37	84	42	85				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	17	115	34	115				
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	0	42	10	42	13		Gas Shortage	
**	Impoport (Tripura)	India		160	160	56	90	146	144				
Cumilla Zone Total				2883	2875	1270	1905	1890	2178	243	0		
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	202	201	200	200				
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	16	45	68	80				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	16	32	97	120				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0				
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0				
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	35	35				
85	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	12	6	12				
Mymensingh Zone Total				654	646	237	290						

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.06.24 (Yesterday)		18.06.24 (Today)		17.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	37	29	29	29		41	Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	58	58	58	58		32	Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	53	50	52				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163				
90	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	2	5	5				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	59	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	208	210	0	0				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under maint.	
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	16	16				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	260	260	260	260				
97	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	240	238	240	400				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	300	300	300	340				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under Construction Project	
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	36	36	36				
Sylhet Zone Total					2376	2331	1265	1408	1217	1419	0	423	
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	230	345	300	350				
103	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	30	40				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	50	60				
105	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
106	Russha 105 MW PP (Orion russha)	HFO (IPP)	6x18.445	105	105	0	18	17	73				
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)	2x617	100	100	37	0	100	0				
109	Maitree Super Thermal 1320 MW PP	Coal (BIF/PCL)	1234	1234	368	526	360	360					
110	Khulna 330 MW CCPP	Gas/HSD (PDB)	1x220+1x116	336	336	0	0	0	0				
111	Nasipara 40 MW PP (Khanjahan Ali)	HFO NENP	5x8.5	40	40	0	0	32	40				
112	Khulna 115 PP MW (KPCL-2)	HFO NENP	7x17	115	115	0	16	20	98				
**	Bheramara (HVDC)	India		1000	1000	913	902	930	930				
Khulna Zone Total					3858	3854	1548	1807	1839	1951	0	0	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	10	10	10	10				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	126	130	130		68	ST under maint.	
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	500	910	1100	1244				
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	250	307	307				
119	Barisal 1 MW Solar PP	Solar (PDB)	1 x 1	1	1	0	0	0	0				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220				
Barishal Zone Total					2266	2236	910	1516	1800	2056	0	68	
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	32	40				
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	10				
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	90				
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	45				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	0	36				
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	159	162	150	160				
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	85	150	150		135	Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	220			Gas Shortage	
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	347	347	400	414		67	Gas Shortage	
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	5	8				
133	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	113	113				
135	Bagura 113 MW (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	94	113				
136	Amnara 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	15	35				
137	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	1	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	867	1314	1228	1400		493	100	
Raishahi Zone Total					3403	3381	1374	1952	2243	2614	493	100	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0				
138	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160				
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16.2*3	113	113	0	70	70	113				
142	Sardpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	70	35	115				
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	0	0	30	0				
146	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	15	0	130	0				
Rangpur Zone Total					1030	950	175	300	433	388	0	85	
Sub-total: Plants in operation					26815	26364	9234.0	12967	15020	16760	1916	1746	
(B) Plants under long term maintenance/ contract expired													
146	Katoboti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
147	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27515	26364	9234	12967	15020	16760	1916	1746	
(C) Actual data of 17.06.24 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	: 12967 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 12545 MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 13025 MW, at = 24:00											
04.	Minimum Generation (Generation end)	: 9234 MW, at = 9:00 hrs		Dhaka	3594	3594	0	Mymensingh	1130	1130	0		
05.	Day-peak Generation (Generation end)	: 9234 MW, at = 9:00 hrs		Chattogram	1070	1070	0	Sylhet	462	462	0		
06.	Evening-peak Generation (Generation end)	: 12967 MW, at = 21:00 hrs		Khulna	1905	1905	0	Barishal	526	526	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 21:00 hrs		Rajshahi	1568	1568	0	Rangpur	814	814	0		
08.	Minimum Generation Forecast up to 8.00 hrs.	: 9691 MW, at = 5:00 hrs		Cumilla	1476	1476	0						
09.	Generation shortfall at evening peak due to :	:		13.	Fuel cost :			Total	12545	12545	0		
	a) Gas/LF limitation	: 1801 MW			(a) Gas =	444308240	Taka	(c) Coal =	526019549	Taka			
	d) Coal supply Limitation	: 0 MW			(b) Oil =	284755513	Taka	Total =	1255083302	Taka			
	b) Low water level in Kaptai lake	: 115 MW											
	c) Plants under shut down/ maintenance	: 1746 MW		14.	Maximum Temperature in Dhaka was : 34.8°C								
10.	Total Energy (Generation + India Import)	: 271.52 MKWh		15.	Export through East-West interconnections :								
	By Gas = 150.928 MKWh	By Oil = 15.561 MKWh			At evening peak-hour	: 9234 MW, at	21:00 hrs						
	By Coal = 76.678 MKWh	By Hydro = 2.768 MKWh			Maximum	: 166 MW, at	6:00 hrs						
	By Solar = 1.501 MKWh				Energy	: 1522.95 MKWh							
11.	Total Gas Supplied	: 1121.40 MMCFD											
(D) Forecast of 18.06.24 (Today) Tuesday :													
01.	Maximum Demand	: 13500 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 16760 MW (Generation end)	05.	Total Generation : 281.43 MKWh									
03.	Reserve / Shortage	: 3260 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 34.8°C									

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation