

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month June, 2024		Day: Wednesday				Date: 19.06.24						
Probable Maximum Demand :		12500 MW		Probable Maximum Generation :		16012 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 82.32 ft		Today = 82.48 ft		Rule Curve = 80.86 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.06.24 (Yesterday)		19.06.24 (Today)		18.06.24 (Yesterday) Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	19.06.24 (Yesterday) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)				
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under Repowering project	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	138	0	0	0			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	61	50	70			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	420	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	400	321	382	400	400			
10	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	250	321	320	320			
12	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	265	300	300	300			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55			
14	Gaganraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	82	85			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	16	16	33	33			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	8	8	33	33			
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	8	8	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	8	8			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	100	100	0	0	52	52			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	16	100	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	270	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	0	91	96	149			
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	35	35			
26	Manikgonj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	35	35			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	55	70			
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	72	162			
29	Manikgonj 35MW Solar PP (Inspecta Solar Ltd.)	Solar (IPP)	1x35	35	35	2	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	35	35			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	25			
32	Unique Meghnaghat 584MW CAPP	Gas	1x400+1x184	584	584	305	500	584	584			
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	70	85			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	64	64			
35	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	0	0	50	80			
	Meghnaghat 589 MW CAPP(Summit)	Gas				0	0	0	0	589	Gas Shortage	
Dhaka Zone Total				5828	5634	1815	2303	3551	3867	799	740	
36	Karnaphuli Hydro PP Unit-1, 2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	115	115	115	115	115	Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	8	17			
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	6	18			
42	Sikalbaha 105 MW PP (Baraka Sikalabaha)	HFO (IPP)	6x18.415	105	105	0	0	51	100			
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	220	226	225	225			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	0	52	52			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	0	25	25			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	34	51			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	71	48	64			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			42	31	40	40			
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	0	18	38			
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	35	35			
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
52	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	0	25	25			
53	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	0	35	45			
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	0	35	35			
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	54	163			
56	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	384	501	612	612			
57	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	0	0	0	0			
58	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	13	26	40	40			
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)		75	75	17	0	70	0			
Chattogram Zone Total				4517	4457	817	1012	1663	1810	295	330	
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	36	37	10	37			
61	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1'175	221	221	186	0	140	140			
62	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	270	305	280	300			
63	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	285	305	300	300			
64	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	285	325	300	330			
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'116	195	195	0	83	0	0	112	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	40	20	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	150	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	40	40			
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	85	85	85	86			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	77	17	100			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	8	50	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	11	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	34	17	0	114			
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	38	77	42	85			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	86	96	34	115			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	10	52	0	0	3	Gas Shortage	
**	Impoport (Tripura)	India		160	160	70	74	146	144			
Cumilla Zone Total				2883	2875	1512	1624	1658	2088	115	0	
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	160	165	150	160			
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	35	68	80			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	8	97	120			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0			
84	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	35	35			
85	Tangali 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	12	6	12			
Mymensingh Zone Total				654	646	160	220	408	407	0	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.06.24 (Yesterday)		19.06.24 (Today)		18.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	29	30	30	30		40	Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	58	58	58	58		32	Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	25	50	50	52				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163				
90	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	0	5	5				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	61	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under maint.	
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	16	16				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	260	260	300	300				
97	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	235	240	320	350				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	310	320	330	350				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under Construction Project	
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	10	39	39	39				
Sylhet Zone Total				2376	2331	1089	1221	1371	1423	0	422		
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	260	355	360	380				
103	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	30	40				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	50	60				
105	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
106	Russha 105 MW PP (Orion russha)	HFO (IPP)	6x18.445	105	105	0	17	17	73				
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)	2x617	100	100	60	0	100	0				
109	Maitree Super Thermal 1320 MW PP	Coal (BIF/PCL)	1234	1234	365	455	500	500	0				
110	Khulna 330 MW PP (Khanjahan Ali)	Gas/HSD (IPP)	1x220+1x116	336	336	0	0	0	0				
111	Nasipara 40 MW PP (Khanjahan Ali)	HFO NENP	5x8.5	40	40	0	0	32	40				
112	Khulna 115 PP MW (KPCL-2)	HFO NENP	7x17	115	115	0	16	20	98				
**	Bheramara (HVDC)	India		1000	1000	924	922	944	944				
Khulna Zone Total				3858	3854	1609	1765	2053	2135	0	0		
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	96	16	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	10	10	10	10				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	126	130	130		68	ST under maint.	
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	540	900	1100	1244				
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	200	307	307				
119	Barisal 1 MW Solar PP	Solar (PDB)	1 x 1	1	1	0	0	0	0				
120	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	110	110	110				
Barishal Zone Total				2266	2236	960	1442	1690	1946	0	68		
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
121	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	32	40				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	10				
124	Chapaiawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	90				
125	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	45				
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	0	36				
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	130	158	155	160		52	Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	150	161	160	160		59	Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	260	347	350	380		67	Gas Shortage	
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	5	8				
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
133	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	113	113				
134	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	94	113				
135	Amnara 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	15	35				
136	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	0	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	821	1060	748	748				
Raishahi Zone Total				3403	3381	1366	1770	1728	1938	469	100		
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0				
137	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	170	170	170				
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16.2*3	113	113	0	34	70	113				
141	Sardpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
142	Majpara Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
143	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	35	115				
144	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	0	0	30	0				
145	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	2	0	130	0				
Rangpur Zone Total				1030	950	162	276	443	398	0	85		
Sub-total: Plants in operation				26815	26364	9490.0	11633	14565	16012	1678	1745		
(B) Plants under long term maintenance/ contract expired													
146	Katoboti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
147	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired				700	0	0	0	0	0	0	0	0	
Gross Total				27515	26364	9490	11633	14565	16012	1678	1745		
(C) Actual data of 18.06.24 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	: 11633 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 11261 MW, at = 21:00 hrs		Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	: 12671 MW, at = 1:00 hrs			MW	MW	MW		MW	MW	MW		
04.	Minimum Generation (Generation end)	: 9490 MW, at = 9:00 hrs		Dhaka	3318	3318	0	Mymensingh	914	914	0		
05.	Day-peak Generation (Generation end)	: 9490 MW, at = 9:00 hrs		Chattogram	920	920	0	Sylhet	363	363	0		
06.	Evening-peak Generation (Generation end)	: 11633 MW, at = 21:00 hrs		Khulna	1876	1876	0	Barishal	510	510	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 21:00 hrs		Rajshahi	1469	1469	0	Rangpur	643	643	0		
08.	Minimum Generation Forecast up to 8.00 hrs.	: 9072 MW, at = 5:00 hrs		Cumilla	1248	1248	0						
09.	Generation shortfall at evening peak due to :	:		13.	Fuel cost :			Total	11261	11261	0		
	a) Gas/LF limitation	: 1563 MW			(a) Gas =	425049402 Taka		(c) Coal =	486479279 Taka				
	d) Coal supply Limitation	: 0 MW			(b) Oil =	242935606 Taka		Total =	1154464287 Taka				
	b) Low water level in Kaptai lake	: 115 MW											
	c) Plants under shut down/ maintenance	: 1745 MW		14.	Maximum Temperature in Dhaka was : 32.0°C								
10.	Total Energy (Generation + India Import)	: 258.65 MKWh		15.	Export through East-West interconnections :								
	By Gas = 146.268 MKWh	By Oil = 13.405 MKWh			At evening peak-hour	: 9490 MW, at 21:00 hrs							
	By Coal = 70.655 MKWh	By Hydro = 2.644 MKWh			Maximum	: 178 MW, at 24:00							
	By Solar = 1.094 MKWh				Energy	: 2805 MKWh							
11.	Total Gas Supplied	: 1064.82 MMCFD											
(D) Forecast of 19.06.24 (Today) Wednesday :													
01.	Maximum Demand	: 12500 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 16012 MW (Generation end)	05.	Total Generation	: 255.16 MKWh								
03.	Reserve / Shortage	: 3512 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	32.0°C								

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation