

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month June, 2024		Day: Friday				Date: 21.06.24							
Probable Maximum Demand :		12000 MW		Probable Maximum Generation :		16324 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 82.87 ft		Today = 83.19 ft		Rule Curve = 81.30 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.06.24 (Yesterday)		21.06.24 (Today)		20.06.24 Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	21.06.24 (Yesterday) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Day	Evening					
										Day	Evening	Day	Evening
<b>(A) Plants in operation:</b>													
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under Repowering project	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	50	50	60				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0				
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	420	450	450				
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	344	403	400	400				
10	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	270	325	320	320				
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	280	295	300	300				
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55				
14	Gaganraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	82	80				
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)		22	22	0	0	0	0				
16	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	15	25	25	25				
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	8	8	8	8				
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	8	33	33				
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	8	8				
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	52	52				
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	0	100	150				
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	54	54				
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	270	300				
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	14	96	149				
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	35	35				
26	Manikgonj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	35	55				
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	17	50				
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	72	162				
29	Manikgonj 35MW Solar PP (Inspecta Solar Ltd.)	Solar (IPP)	1x35	35	35	4	0	35	0				
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	35	35				
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	25				
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	280	280	280	280				
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	70	80				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	64	80				
35	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	0	0	50	80				
	Meghnaghat 589 MW CCGP(Summit)	Gas				300	584	300	400		5	Gas Shortage	
<b>Dhaka Zone Total</b>				<b>5828</b>	<b>5634</b>	<b>2004</b>	<b>2609</b>	<b>3476</b>	<b>3906</b>	<b>215</b>	<b>740</b>		
36	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	112	115	115	115		115	Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	8	17				
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	6	18				
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	51	100				
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
44	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	174	176	220	220				
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	30	51	52	52				
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	24	24	25	25				
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	34	50				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	40	48	60				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			30	14	40	40				
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	38	18	38				
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	35	35				
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
52	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	28	25	28				
53	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	0	35	45				
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17				
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	54	163				
56	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	300	280	612	612				
57	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	0	0	0	0				
58	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	8	7	40	40				
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)		75	75	10	0	70	0				
<b>Chattogram Zone Total</b>				<b>4517</b>	<b>4457</b>	<b>764</b>	<b>807</b>	<b>1640</b>	<b>1785</b>	<b>295</b>	<b>330</b>		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	10	38	10	38				
61	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	31	220	220	220				
62	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	280	270	280	300				
63	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	285	285	300	300				
64	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	285	270	300	330				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0		195	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	51	20	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	150	150				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	40	40				
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	87	88	85	88				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	51	17	100				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	24	4	32	32				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	8	50	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	10	12	12				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	52	70	114				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	40	77	42	80				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	66	115	34	115				
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	3	0	10	10		55	Gas Shortage	
**	Impoport (Tripura)	India		160	160	59	64	146	144				
<b>Cumilla Zone Total</b>				<b>2883</b>	<b>2875</b>	<b>1258</b>	<b>1603</b>	<b>1818</b>	<b>2176</b>	<b>250</b>	<b>0</b>		
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	204	202	170	200				
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	45	68	80				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	0	97	120				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	5	0	50	0				
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	35	35				
85	Tangali 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	0	6	12				
<b>Mymensingh Zone Total</b>				<b></b>									

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.06.24 (Yesterday)		21.06.24 (Today)		20.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	28	28	28	28		42	Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	58	58	58	58		32	Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	53	50	52				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163				
90	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	5	5				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	61	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	18	18	18		2	Under maint.	
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	16	16				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	275	295	300	300				
97	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	318	319	350	370				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	320	330	350				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under Construction Project	
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	36	39	39				
<b>Sylhet Zone Total</b>				<b>2376</b>	<b>2331</b>	<b>1159</b>	<b>1367</b>	<b>1417</b>	<b>1459</b>	<b>0</b>	<b>406</b>		
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	345	405	300	400				
103	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	30	40				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	50	60				
105	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
106	Russha 105 MW PP (Orion russha)	HFO (IPP)	6x18.445	105	105	0	0	17	73				
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)	2x617	100	100	37	0	100	0				
109	Maitree Super Thermal 1320 MW PP	Coal (BIF/PCL)	1234	1234	356	360	360	360	360				
110	Khulna 330 MW PP (Khanjahan Ali)	Gas/HSD (PDB)	1x220+1x116	336	336	0	0	0	0				
111	Nasipara 40 MW PP (Khanjahan Ali)	HFO NENP	5x8.5	40	40	0	0	32	40				
112	Khulna 115 PP MW (KPCL-2)	HFO NENP	7x17	115	115	0	0	20	98				
**	Bheramara (HVDC)	India		1000	1000	921	925	944	944				
<b>Khulna Zone Total</b>				<b>3858</b>	<b>3854</b>	<b>1659</b>	<b>1690</b>	<b>1853</b>	<b>2015</b>	<b>0</b>	<b>0</b>		
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	8	10	10	10				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130		64	ST under maint.	
116	Pavra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	500	520	1100	1244				
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	307	307				
119	Barisal 1 MW Solar PP	Solar (PDB)	1 x 1	1	1	0	0	0	0				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	110	220	220				
<b>Barishal Zone Total</b>				<b>2266</b>	<b>2236</b>	<b>888</b>	<b>910</b>	<b>1800</b>	<b>2056</b>	<b>0</b>	<b>64</b>		
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	32	40				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	10				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	90				
125	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	45				
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	36				
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	149	214	150	210		-4	Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	156	210	150	210		10	Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	220			Gas Shortage	
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	325	414	350	414		0	Gas Shortage	
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	2	5	8				
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
133	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	113	113				
134	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	94	113				
135	Amnara 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	15	35				
136	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	2	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	424	620	500	748				
<b>Raishahi Zone Total</b>				<b>3403</b>	<b>3381</b>	<b>1056</b>	<b>1460</b>	<b>1465</b>	<b>2072</b>	<b>297</b>	<b>100</b>		
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85 Under Overhauling	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	180	170	180				
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16.2*3	113	113	0	34	70	113				
141	Sardpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	10	0	0	0				
142	Majpara Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
143	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	35	115				
144	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	28	0	30	0				
145	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	144	0	130	0				
<b>Rangpur Zone Total</b>				<b>1030</b>	<b>950</b>	<b>354</b>	<b>286</b>	<b>443</b>	<b>408</b>	<b>0</b>	<b>85</b>		
<b>Sub-total: Plants in operation</b>				<b>26815</b>	<b>26364</b>	<b>9352.0</b>	<b>10979</b>	<b>14340</b>	<b>16324</b>	<b>1057</b>	<b>1725</b>		
<b>(B) Plants under long term maintenance/ contract expired</b>													
146	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
147	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>				<b>700</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>				<b>27515</b>	<b>26364</b>	<b>9352</b>	<b>10979</b>	<b>14340</b>	<b>16324</b>	<b>1057</b>	<b>1725</b>		
<b>(C) Actual data of 20.06.24 (Yesterday) Thursday :</b>													
01.	Max. Demand at eve. peak (Generation end)	:	10979 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10675 MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	11156 MW, at =	23:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	8396 MW, at =	8:00 hrs	Dhaka	2997	2997	0	Mymensingh	949	949	0	
05.	Day-peak Generation (Generation end)	:	9352 MW, at =	12:00 hrs	Chattogram	1297	1297	0	Sylhet	414	414	0	
06.	Evening-peak Generation (Generation end)	:	10979 MW, at =	21:00 hrs	Khulna	1372	1372	0	Barishal	387	387	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	21:00 hrs	Raishahi	1320	1320	0	Rangpur	783	783	0	
08.	Minimum Generation Forecast up to 8.00 hrs.	:	8961 MW, at =	5:00 hrs	Cumilla	1157	1157	0					
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :			Total	10675	0		
	a) Gas/LF limitation	:	942 MW			(a) Gas =	410933856 Taka		(c) Coal =	343981428 Taka			
	d) Coal supply Limitation	:	0 MW			(b) Oil =	156654450 Taka		Total =	911569734 Taka			
	b) Low water level in Kaptai lake	:	115 MW										
	c) Plants under shut down/ maintenance	:	1725 MW		14.	Maximum Temperature in Dhaka was : 30.1°C							
10.	Total Energy (Generation + India Import)	:	234.81 MCKWh		15.	Export through East-West interconnections :							
	By Gas = 148.147 MCKWh		By Oil = 8.618 MCKWh			At evening peak-hour : 9352 MW, at 21:00 hrs							
	By Coal = 49.421 MCKWh		By Hydro = 2.756 MCKWh			Maximum : 100 MW, at 21:00 hrs							
	By Solar = 1.792 MCKWh					Energy : 1145.1 MCKWh							
11.	Total Gas Supplied	:	1108.52 MCMCFD										
<b>(D) Forecast of 21.06.24 (Today) Friday :</b>													
01.	Maximum Demand	:	12000 MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	16324 MW	(Generation end)	05.	Total Generation : 252.57 MCKWh							
03.	Reserve / Shortage	:	4324 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 30.1°C							

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation