

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month June, 2024													Day : Tuesday			Date : 25.06.24		
Probable Maximum Demand : 15700 MW				Probable Maximum Generation : 14103 MW														
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 83.44 ft			Today = 83.21 ft			Rule Curve = 82.38 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.06.24 (Yesterday)		25.06.24 (Today)		24.06.24 (Yesterday)		25.06.24 (Today)		Status of Machines under shut-down/ Maintenance					
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :		Machines shut down (MW)	Description/ Remarks	Probable start-up date							
							Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)										
				Day	Evening	Day	Evening											
<b>(A) Plants in operation:</b>																		
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under Repowering project					
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240			Gas Shortage					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110									
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	Awaiting for HGPI					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0									
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0									
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0									
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	330	350	420	420									
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling					
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	370	362	400	400									
10	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage					
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	308	280	300	300									
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	270	260	250	250									
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	40									
14	Gaganraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	90	24	92									
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)		22	22	0	0	0	0									
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	30	29	31	31									
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	7	7	7	7									
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	12	14	14									
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	8									
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	100	105	17	52	17	50									
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	109	142	100	149									
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54									
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	268	278	250	275									
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	120	149	135	149									
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55									
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55									
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	17	52									
28	Manikgonj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	162	162	72	162									
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	35	0									
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	33	35	35	35									
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	12									
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584			Under maintenance					
33	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	42	57	40	60									
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	65	80	64	80									
35	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	24	58	50	80									
	Meghnaghat 589 MW CCGP(Summit)	Gas				0	0	0	0	589			Gas Shortage					
<b>Dhaka Zone Total</b>				<b>5828</b>	<b>5634</b>	<b>2581</b>	<b>2778</b>	<b>2583</b>	<b>2940</b>	<b>1039</b>	<b>1324</b>							
36	Karnaphuli Hydro PP Unit-1, 2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	145	145	145	145	85			Inadequate Water Level					
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.					
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0									
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17									
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0									
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	20	20									
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	68	51	51	51									
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.					
44	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	218	220	220	220									
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	52	52	52									
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	24	24	24	24									
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	68	34	68									
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	31	79	48	72									
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	20	5	20									
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	31	32	25	32									
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54									
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	72	110	68	110									
52	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	25	25	25									
53	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	10	25	25	25									
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	35	72	17	72									
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	163	54	163									
56	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	480	481	612	612									
57	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	564	568	570	570									
58	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	0	2	40	40									
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)		75	75	28	0	70	0									
<b>Chattogram Zone Total</b>				<b>4517</b>	<b>4457</b>	<b>1946</b>	<b>2227</b>	<b>2192</b>	<b>2392</b>	<b>265</b>	<b>330</b>							
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0	45			Gas Shortage					
61	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1'175	221	221	201	209	190	210									
62	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	250	240	240	250	120			Gas Shortage					
63	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	280	280	280	280	80			Gas Shortage					
64	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	230	230	230	170			Gas Shortage					
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'116	195	195	0	0	0	0	195			Gas Shortage					
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51									
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	117	90	100	135									
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	22	35	36	36									
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	50	40	40	50									
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17									
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0									
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32									
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	51	25	52									
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12									
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	34	98	50	98									
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	32	74	36	75									
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	48	115	90	115									
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	0	0	0	0	55			Gas Shortage					
**	Import (Tripura)	India		160	160	84	90	146	142									
<b>Cumilla Zone Total</b>				<b>2883</b>	<b>2875</b>	<b>1485</b>	<b>1664</b>	<b>1575</b>	<b>1785</b>	<b>665</b>	<b>0</b>							
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	5	0	0	0	202			Gas Shortage					
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	56	87	68	80									
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	92	139	100	140									
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0									
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0									
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	36	40	35	35									
85	Tangali 22 MW PP(PPGL)	HFO (IPP)	4x6															

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.06.24 (Yesterday)		25.06.24 (Today)		24.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	27	28	28	28		42	Under maint.
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	68	68	68	68		22	Under maint.
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	50	52			
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163			
90	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	5	2	2			
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	60	60	60			
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	100	100	100	100			
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	12	12	12	12			
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	18	18	18	18			
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	310	300	300			
97	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	385	384	365	365			
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	370	356	350	350			
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under Construction Project
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	36	39	39	39			
<b>Sylhet Zone Total</b>				<b>2376</b>	<b>2331</b>	<b>1588</b>	<b>1596</b>	<b>1555</b>	<b>1557</b>	<b>0</b>	<b>394</b>	
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
102	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	210	165	170	180	245		Gas Shortage
103	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	39	30	45			
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	61	50	60			
105	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0			
106	Russha 105 MW PP (Orion russha)	HFO (IPP)	6x18.445	105	105	17	58	36	53			
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0			
108	Mongla Orion 100 MW Solar PP	Solar (IPP)	2x617	100	100	65	0	100	0			
109	Maitree Super Thermal 1320 MW PP	Coal (BIF/PCL)	1234	1234	563	593	600	610	0			
110	Khulna 330 MW CCPP	Gas/HSD (BIF/PCL)	1x220+1x116	336	336	0	0	0	0			
111	Nasipara 40 MW PP (Khanjahan Ali)	HFO NENP	5x8.5	40	40	0	40	32	40			
112	Khulna 115 PP MW (KPCL-2)	HFO NENP	7x17	115	115	16	92	16	98			
**	Bheramara (HVDC)	India		1000	1000	919	918	936	936			
<b>Barisal Zone Total</b>				<b>3858</b>	<b>3854</b>	<b>1790</b>	<b>1966</b>	<b>1970</b>	<b>2022</b>	<b>245</b>	<b>0</b>	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110			
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	8	10	10	10			
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	126	130	130	130		64	ST under maint.
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1110	622	622	622			
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	17	35			
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	200	200	200			
119	Barisal 1 MW Solar PP	Solar (PDB)	1 x 1	1	1	0	0	0	0			
120	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
<b>Barishal Zone Total</b>				<b>2266</b>	<b>2236</b>	<b>1664</b>	<b>1327</b>	<b>1309</b>	<b>1327</b>	<b>0</b>	<b>64</b>	
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	40	38	32	40			
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	10			
125	Chapaiawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	85	50	90			
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	15	42	0	45			
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	30			
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	178	140	0	0	70		Gas Shortage
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	139	130	130	130	90		Gas Shortage
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	400	414			
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	2	5	5			
133	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0			
134	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	95	113	113	113			
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	113	113	113	113			
136	Amnara 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	28	28	20	35			
137	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0			
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	373	371	370	370			
<b>Raishahi Zone Total</b>				<b>3403</b>	<b>3381</b>	<b>1405</b>	<b>1510</b>	<b>1239</b>	<b>1395</b>	<b>451</b>	<b>100</b>	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Maintenance
138	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	190	197	180	190			
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16.2*3	113	113	113	113	113	113			
142	Sardpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
143	Majpara Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	115	115	35	115			
145	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0			
146	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	65	0	130	0			
<b>Rangpur Zone Total</b>				<b>1030</b>	<b>950</b>	<b>523</b>	<b>425</b>	<b>496</b>	<b>418</b>	<b>0</b>	<b>170</b>	
<b>Sub-total: Plants in operation</b>				<b>26815</b>	<b>26364</b>	<b>13225.0</b>	<b>13771</b>	<b>13186</b>	<b>14103</b>	<b>2867</b>	<b>2382</b>	
<b>(B) Plants under long term maintenance/ contract expired</b>												
146	Katobott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired
147	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>				<b>700</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>				<b>27515</b>	<b>26364</b>	<b>13225</b>	<b>13771</b>	<b>13186</b>	<b>14103</b>	<b>2867</b>	<b>2382</b>	
<b>(C) Actual data of 24.06.24 (Yesterday) Monday :</b>												
01.	Max. Demand at eve. peak (Generation end)	: 15200 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 14481 MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	: 14254 MW, at = 1:00 hrs		Dhaka	4968	4788	180	Mymensingh	1219	1059	160	
04.	Minimum Generation (Generation end)	: 12024 MW, at = 6:00 hrs		Chattogram	1404	1284	120		595	505	90	
05.	Day-peak Generation (Generation end)	: 13225 MW, at = 12:00 hrs		Khulna	1869	1579	290	Barishal	502	442	60	
06.	Evening-peak Generation (Generation end)	: 13771 MW, at = 21:00 hrs		Rajshahi	1580	1400	180	Rangpur	958	853	105	
07.	Evening Peak Load-shed (Sub-station end)	: 1365 MW, at = 21:00 hrs		Cumilla	1385	1205	180					
08.	Minimum Generation Forecast up to 8.00 hrs.	: 12257 MW, at = 5:00 hrs						Total	14481	13116	1365	
09.	Generation shortfall at evening peak due to :			13.	Fuel cost :	(a) Gas = 423227232 Taka	(c) Coal = 55549998 Taka					
	a) Gas/LF limitation	: 2782 MW			(b) Oil = 1323809444 Taka	Total = 2302586674 Taka						
	d) Coal supply Limitation	: 0 MW										
	b) Low water level in Kaptai lake	: 85 MW										
	c) Plants under shut down/ maintenance	: 2382 MW		14.	Maximum Temperature in Dhaka was : 35.7°C							
10.	Total Energy (Generation + India Import)	: 320.91 MCKWh		15.	Export through East-West interconnections :							
	By Gas = 136.518 MCKWh	By Oil = 72.057 MCKWh			At evening peak-hour	: 13225 MW, at 21:00 hrs						
	By Coal = 81.901 MCKWh	By Hydro = 3.200 MCKWh			Maximum	: 58 MW, at 6:00 hrs						
	By Solar = 2.913 MCKWh				Energy	: 2088.9 MCKWh						
11.	Total Gas Supplied	: 1001.52 MCMCFD										
<b>(D) Forecast of 25.06.24 (Today) Tuesday :</b>												
01.	Maximum Demand	: 15700 MW (Generation end)	04.	Maximum Load-shed	: 1510 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 14103 MW (Generation end)	05.	Total Generation	: 353.46 MCKWh							
03.	Reserve / Shortage	: -1597 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	35.7°C							

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation