

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month June, 2024		Day : Friday				Date : 28.06.24							
Probable Maximum Demand :		14200 MW		Probable Maximum Generation :		14555 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 82.52 ft		Today = 82.34 ft		Rule Curve = 83.19 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.06.24 (Yesterday)		28.06.24 (Today)		27.06.24 (Yesterday)		28.06.24 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0			260	Under Repowering project	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	0	0	0	0	240			Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	110	110	110	110	80			Gas Shortage	
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	0	0	0	0			365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	0	0	0	0					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	0	0	0	0					
6	Haripur GTPP	Gas (PDB)	1 x 32	32	0	0	0	0					
7	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	400	390	400	400					
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0			115	Under Overhauling	
9	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	400	405	400	400					
10	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	0	0	150	0	210			Gas Shortage	
11	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	278	276	0	300				
12	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	150	136	150	150		199	Gas Shortage	
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55					
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	90	24	92				
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0				
16	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	28	30	31	31				
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	7	7	25	25				
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	12	12	14	14				
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	16	16	16				
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	90	52	90				
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	146	48	149				
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	260	268	263	280				
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	132	122	135	149				
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	17	55	55				
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	18	53	17	52				
28	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	162	162	162	162				
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	19	0	35	0				
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	35	35				
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	0	13				
32	Unique Meghnaghat 584MW CAPP	Gas	1x400+1x184	584	584	0	0	0	584			Gas Shortage	
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	48	50	70	70				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	82	80	68	80				
35	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	16	31	16	34				
	Meghnaghat 589 MW CAPP(Summit)	Gas				0	0	0	589			Gas Shortage	
Dhaka Zone Total				5828	5634	2499	2703	2440	2871	1902	740		
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	145	106	145	145	124		Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0				
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17				
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	10	0	20	0				
41	Patenga 50MW PP (Baraka)	HFO (IPP)	6x6.89	50	50	6	20	20	20				
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	68	68	68	68				
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	220	220	220				
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	52	52	52				
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	48	62	37	62				
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	67	68	68	68				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	54	72	54	72				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	31	30	30				
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	19	19	25	32				
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
52	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	50	50	50	62				
53	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	35	35	35	25				
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	35	35	17	72				
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	163	54	163				
56	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	593	606	612	612				
57	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	470	519	570	570				
58	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	40	59	44	59				
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)		75	75	74	0	70	0				
Chattogram Zone Total				4517	4457	2205	2366	2368	2513	304	330		
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	37	37		45	Gas Shortage	
61	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1'175	221	221	203	211	210	210				
62	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	240	260	280	280			Gas Shortage	
63	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	280	285	280	280		75	Gas Shortage	
64	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	270	285	300		130	Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'116	195	195	0	0	0	0		195	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	55	122	55	135				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	29	36	36	36				
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	40	40	50	50				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	0	0	0				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	32	51	25	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'19.78	114	114	52	114	50	114				
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	36	101	36	101				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	49	107	90	115				
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	0	0	0	55			Gas Shortage	
**	Impoport (Tripura)	India		160	160	94	80	146	142				
Cumilla Zone Total				2883	2875	1412	1749	1660	1932	600	0		
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	5	17	18	18		185	Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	68	87	68	85				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	116	144	116	145				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0	50	0				
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	18	36	35	35				
85	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	12	12	12	</			

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.06.24 (Yesterday)		28.06.24 (Today)		27.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)			
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	29	28	28	28		42	Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	68	68	68	68		22	Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	50	52				
89	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
90	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	2	2	2				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	40	60	60				
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	210	207	205	205				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	18	18				
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	300	300				
97	Bibiyana-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	367	329	365	365				
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	345	345	350	350				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under Construction Project	
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	36	34	39	39				
Sylhet Zone Total				2376	2331	1626	1567	1648	1650	0	394		
101	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	245	250	285	285	160		Gas Shortage	
103	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	8	41	30	45				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	30	51	50	60				
105	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	45	55	45	55				
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)	2x617	100	100	21	0	100	0				
109	Maitree Super Thermal 1320 MW PP	Coal (BIF/CL)	1234	1234	861	867	850	850					
110	Khulna 330 MW PP (Khanjahan Ali)	Gas/HSD (RPP)	1x220+1x116	336	336	0	0	0	0				
111	Nasipara 40 MW PP (Khanjahan Ali)	HFO NENP	5x8.5	40	40	0	32	32	40				
112	Khulna 115 PP MW (KPCL-2)	HFO NENP	7x17	115	115	0	48	16	98				
**	Bheramara (H/VD)	India		1000	1000	911	918	927	927				
Khulna Zone Total				3858	3854	2129	2262	2335	2360	160	0		
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	110	110	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	8	10	10	10				
115	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	126	80	130	130		114	ST under maint.	
116	Pavra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	622	540	622	622		622	Unit-1 under maint.	
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	35	35	35				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	271	307	200	200				
119	Barisal 1 MW Solar PP	Solar (PDB)	1 x 1	1	1	0	0	0	0				
120	Bhola 220MW CAPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total				2266	2236	1298	1302	1327	1327	0	736		
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
121	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	28	32	32	40				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	10				
124	Chapaiawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	45	85	50	90				
125	Katakhalai 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	12	45	36	45				
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	30				
127	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
128	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	207	187	200	200				
129	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
130	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	318	400	414				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	2	5	5				
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
133	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	95	113	113	113				
134	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	99	113	113	113				
135	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	35	35	35	35				
136	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	375	518	0	0		978	Unit-2 under maint.	
Raishahi Zone Total				3403	3381	1320	1483	990	1095	501	1078		
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	58	60	64	64				
137	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	190	220	200	220				
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16.2*3	113	113	106	113	113	113				
141	Sardpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
142	Majpara Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
143	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	95	94	95	115				
144	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	32	0	30	0				
145	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	129	0	130	0				
Rangpur Zone Total				1030	950	614	487	640	512	0	85		
Sub-total: Plants in operation				26815	26364	13362.0	14215	13709	14555	3652	3363		
(B) Plants under long term maintenance/ contract expired													
146	Katoboti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
147	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired				700	0	0	0	0	0	0	0	0	
Gross Total				27515	26364	13362	14215	13709	14555	3652	3363		
(C) Actual data of 27.06.24 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	: 14800 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 14230 MW, at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	: 14393 MW, at = 22:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW			
04.	Minimum Generation (Generation end)	: 12300 MW, at = 8:00 hrs	Dhaka	5063	4933	130	Mymensingh	1138	1013	125			
05.	Day-peak Generation (Generation end)	: 13362 MW, at = 12:00 hrs	Chattogram	1337	1337	0	Sylhet	569	569	0			
06.	Evening-peak Generation (Generation end)	: 14215 MW, at = 21:00 hrs	Khulna	1762	1758	4	Barishal	428	428	0			
07.	Evening Peak Load-shed (Sub-station end)	: 559 MW, at = 21:00 hrs	Rajshahi	1591	1466	125	Rangpur	1007	952	55			
08.	Minimum Generation Forecast up to 8.00 hrs.	: 11182 MW, at = 5:00 hrs	Cumilla	1335	1215	120							
09.	Generation shortfall at evening peak due to :	:	13.	Fuel cost :	Total		14230		13671		559		
a)	Gas/LF limitation	: 3528 MW		a) Gas =	405942958 Taka		(c) Coal =		569448352 Taka				
d)	Coal supply Limitation	: 0 MW		b) Oil =	1358455022 Taka		Total =		2333846333 Taka				
b)	Low water level in Kaptai lake	: 124 MW											
c)	Plants under shut down/ maintenance	: 3363 MW	14.	Maximum Temperature in Dhaka was : 34.2°C									
10.	Total Energy (Generation + India Import)	: 318.26 MCKWh	15.	Export through East-West interconnections :									
	By Gas = 132.461 MCKWh	By Oil = 73.684 MCKWh		At evening peak-hour	: 13362 MW, at 21:00 hrs								
	By Coal = 81.804 MCKWh	By Hydro = 2.928 MCKWh		Maximum	: 86 MW, at 21:00 hrs								
	By Solar = 2.710 MCKWh			Energy	: 3182.85 MCKWh								
11.	Total Gas Supplied	: 957.14 MCMCFD											
(D) Forecast of 28.06.24 (Today) Friday :													
01.	Maximum Demand	: 14200 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 14555 MW (Generation end)	05.	Total Generation : 313.99 MCKWh									
03.	Reserve / Shortage	: 355 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 32.0°C									

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation